# Temperature Considerations for trouble free Oil Free Screw Operation

Presented by

Shreekant Shah Lead Design Engineer


Co-Authored by Jim Hudson Principle Engineer

William Egan Lead Engineer

# **Case Study Overview**


- Oil Free Screw compressors clearances.
  - Interlobal (rotor to rotor)
  - Tip (rotor to casing)
  - Endwall (rotor end wall to casing end wall)
- Compression process scenarios (volume matching)
  - Fixed Volume (Vi) Compressors
- Start Up considerations
  - Nitrogen start up
  - Air start up
  - Recycle Loops
- Parameters affecting internal temperature distribution
  - Water Injection
  - Seal Buffer Gas
  - Process gas K value
  - Discharge temperature monitoring
  - Jacket cooling scheme
- Shut down considerations

#### **Oil Free Screw Cross Section**




#### **Volume Matched**

#### Volumetrically Matched Case




#### **Under Compression**

Under Compressed




#### **Over Compression**



# Isentropic Exponent (k value)

- Field start up gas k (Air, Nitrogen) values are typically higher than process gas k values.
- Compression process in OFS PV<sup>k</sup>= C
- Impact of k value on discharge temperature



# **Recycle Loop and Control Scheme**

- Why use recycle loop?
- Recycle loop design.
  - Cooler sizing
  - Loop sizing
  - Recycle valve response time and control on trip
- Need for pressure ratio monitoring.



# **Liquid Injection and Control Scheme**

- Liquid (water) injection used to reduce discharge temperature of gas and clean rotors.
- Importance of atomizing the water into fine spray form.
- Accurate determination of the injected water quantity.
- •Variable speed compressor may require two nozzles to handle wide range of water quantity.
- •Trip on loss of water injection.



### **Seal Buffer Medium**

- Seal buffer medium temperature considerations.
  Steam
- Seal buffer medium k values considerations.
  - k value higher than process
- Effect on process gas k value.
  Gas mixing


#### **Discharge Temperature Measurement**

- Temperature measurement location.
  - Water Injected
  - Dry
- Understanding of internal compression process.
  - Over Compression



# **Jacket Cooling and Control Scheme**

- Cooling jacket used to stabilize compressor casing thermal growth.
  - Flow Through
  - Standpipe
- Impact of cooling jacket fluid medium temperature and velocity on rotor to casing clearances.



### Shutdown

- Concerns
  - Rotor thermal growth
    - -Thermal Equilibrium
    - -Rotor sitting on lowermost position
    - -Casing Bore Shrinkage due to cooling
- Measures to prevent rotor seizure.
  - Cooling time before restart

### Recommendations and Lessons Learned

- Understanding of internal compression process (Vi matching)
- Clear definition of all operating conditions including start up conditions.
- Jacket cooling medium cooling effects on operating clearances.
- Understanding the effect of seal buffer medium on rotor clearances.
- Understanding of liquid injection and its control scheme.
- Design and control of recycle loop.
- Location and number of temperature measurement devices.