

STATEWIDE AIR EMISSIONS CALCULATIONS FROM WIND AND OTHER RENEWABLES


SUMMARY REPORT

A Report to the
Texas Commission on Environmental Quality
For the Period September 2008 – August 2009




**Jeff Haberl, Ph.D., P.E.; Zi Liu, Ph.D.; Juan-Carlos Baltazar-Cervantes, Ph.D.
Don Gilman, P.E.; Charles Culp, Ph.D., P.E.
Bahman Yazdani, P.E.; Dan Turner, Ph.D., P.E.; Vivek Chandrasekaran**

**August 2009
Revised November 2009**



**ENERGY SYSTEMS
LABORATORY**

**Texas Engineering Experiment Station
Texas A&M University System**



ENERGY SYSTEMS LABORATORY

Texas Engineering Experiment Station

Texas A&M University System

3581 TAMU
College Station, Texas 77843-3581

August 31, 2009

Chairman Buddy Garcia
Texas Council on Environmental Quality
P. O. Box 13087
Austin, TX 78711-3087

Dear Chairman Garcia:

The Energy Systems Laboratory (ESL) at the Texas Engineering Experiment Station of the Texas A&M University System is pleased to provide its third annual report, "Statewide Emissions Calculations From Wind and Other Renewables," as required by the 79th Legislature. This work has been performed through a contract with the Texas Environmental Research Consortium (TERC).

In this work the ESL is required to obtain input from public/private stakeholders, and develop and use a methodology to annually report the energy savings from Wind and Other Renewables. This report summarizes the work performed by the ESL on this project from September 2008 to August 2009.

Please contact me at (979) 845-1280 should you or any of the TCEQ staff have questions concerning this report or the work presently being done to quantify emissions reductions from energy efficiency and renewable energy measures as a result of the TERP implementation.

Sincerely,

David Claridge, P.E.
Director

Enclosure

cc: Commissioner Larry R. Soward
 Commissioner Bryan W. Shaw
 Executive Director Mark R. Vickery

Disclaimer

This report is provided by the Texas Engineering Experiment Station (TEES) as required under Section 388.003 (e) of the Texas Health and Safety Code and is distributed for purposes of public information. The information provided in this report is intended to be the best available information at the time of publication. TEES makes no claim or warranty, express or implied, that the report or data herein is necessarily error-free. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not constitute or imply its endorsement, recommendation, or favoring by the Energy Systems Laboratory or any of its employees. The views and opinions of authors expressed herein do not necessarily state or reflect those of the Texas Engineering Experiment Station or the Energy Systems Laboratory.

SUMMARY REPORT

Statewide Air Emissions Calculations from Wind and Other Renewables

1. EXECUTIVE SUMMARY

The 79th Legislature, through Senate Bill 20, House Bill 2481 and House Bill 2129, amended Senate Bill 5 to enhance its effectiveness by adding 5,880 MW of generating capacity from renewable energy technologies by 2015 and 500 MW from non-wind renewables.

This legislation also requires the Public Utilities Commission of Texas (PUCT) to establish a target of 10,000 megawatts of installed renewable capacity by 2025, and requires the Texas Commission on Environmental Quality (TCEQ) to develop methodology for computing emissions reductions from renewable energy initiatives and the associated credits. Table 1-1 lists the statutory mandates and total wind power generation capacity (including installed and announced) in Texas from 2001 to 2025. It shows that Texas will achieve its milestone of 10,000 MW by the end of 2009 according to the information from PUCT.

Table 1-1: Installed/Announced Wind Power Capacity and The Statutory Mandates

| Installed and Announced | | SB20 Plan | |
|-------------------------|--------|-----------|---------------|
| Month-Yr | MW | Month-Yr | MW |
| Dec-2001 | 1,019 | | |
| Jan-2002 | 1,098 | | |
| Dec-2003 | 1,299 | | |
| Dec-2005 | 1,972 | | |
| Dec-2006 | 3,033 | Jan-2007 | 2,280 |
| Dec-2007 | 5,007 | | |
| Dec-2008 | 8,869 | Jan-2009 | 3,272 |
| Dec-2009 | 11,759 | | |
| Dec-2010 | 12,909 | Jan-2011 | 4,264 |
| Dec-2011 | 13,209 | | |
| Jul-2012 | 13,609 | | |
| | | Jan-2013 | 5,256 |
| | | Jan-2015 | 5,880 |
| | | Jan-2025 | 10,000 |

In this Legislation the Energy Systems Laboratory (ESL) is to assist the TCEQ in quantifying emissions reductions credits from energy efficiency and renewable energy programs, through a contract with the Texas Environmental Research Consortium (TERC) to develop and annually calculate creditable emissions reductions from wind and other renewable energy resources for the State Implementation Plan (SIP).

The Energy Systems Laboratory, in fulfillment of its responsibilities under this Legislation, submits its third annual report, "Statewide Air Emissions Calculations from Wind and Other Renewables," to the Texas Commission on Environmental Quality.

The report is organized in several deliverables:

- A Summary Report, which details the key areas of work;
- Supporting Documentation; and

- Supporting data files, including weather data, and wind production data, which have been assembled as part of the third year's effort.

This executive summary provides summaries of the key areas of accomplishment this year, including:

- Continuation of stakeholder's meetings;
- Analysis of power generation from wind farms using improved method and 2006 data;
- Analysis of emissions reduction from wind farms;
- Updates on degradation analysis;
- Analysis of other renewables, including: PV, solar thermal, hydroelectric, geothermal and landfill gas;
- Review of electricity generation by renewable sources and transmission planning study reported by ERCOT;
- Review of combined heat and power projects in Texas; and
- Preliminary reporting of NOx emissions savings in the 2007 Integrated Savings report to the TCEQ.

1.1 Development of Stakeholder's meetings

Legislation passed during the regular session of the 79th Legislature directed the Energy Systems Laboratory to work with the TCEQ to develop a methodology for computing emissions reductions attributable to renewable energy and for the ESL to quantify the emissions reductions attributable to renewables for inclusion in the State Implementation Plan annually. HB 2921 directed the Texas Environmental Research Consortium (TERC) to engage the Texas Engineering Experiment Station for the development of this methodology.

During the 2008-2009 periods, Texas A&M held continuing Stakeholder's meetings and made several presentations to EPA, TCEQ and other interested parties regarding the analysis and the results. The presentations for those meetings are contained in Appendix A of this report.

1.2 Analysis of wind farms using improved method and 2007 data

In this report, the weather normalization procedures developed together with the Stakeholders were presented and applied to all the wind farms that reported their data to ERCOT during the 2007 measurement period, together with wind data from the nearby NOAA weather stations. In the 2008 Wind and Renewables report to the TCEQ (Haberl et al. 2008), weather normalization analysis methods were reviewed; an analysis was shown for the Sweetwater I wind farm in Nolan, Texas, and then applied to all the wind farms in the ERCOT region.

The wind farm (Sweetwater III) was used as an example in this report to present the same weather normalization procedure, including the processing of weather and power generation data, modeling of daily power generation versus daily wind speed using the ASHRAE Inverse Model Toolkit (IMT) for two separate periods, i.e., Ozone Season Days period (OSP), from July 15 to September 15, and Non-Ozone Season days period (Non-OSP); prediction of 1999 wind power generation using developed coefficients from 2007 daily OSP and Non-OSP models; and the analysis on monthly capacity factors generated using the models.

Then, a summary of total predicted wind power production in the base year (1999) for all of the wind farms in the ERCOT region using the developed procedure is presented and the new wind farms which started operation in 2007 were added. Figure 1-1 shows the measured annual wind power generation in 2007 and the estimated wind power generation in 1999 using the developed method for each wind farm in the ERCOT region. The total measured wind power generation in 2007 is 8,752,498 MWh, which is 17% less than what the same wind farms would have produced in 1999. Figure 1-2 shows the same comparison but

for the Ozone Season Period. The measured wind power generation in the OSP of 2007 is 20,094 MWh/day, which is 25% lower than the estimated 1999 OSD wind production.

This report also includes an uncertainty analysis that was performed on all the daily regression models for the entire year and Ozone Season Period. The detailed analysis for each wind farm is provided in the Appendix B to this report. The original data used in the analysis is included in the accompanying CD-ROM with this report.




Figure 1-1: Comparison of 2007 Measured and 1999 Estimated Power Production for Each Wind Farm




Figure 1-2: Comparison of 2007 OSD Measured and 1999 OSD Estimated Power Production for Each Wind Farm

1.3 Analysis of emissions reduction from wind farms

In this report, the procedure for calculating annual and peak-day, county-wide NOx reductions from electricity savings from wind projects implemented in the Power Control Areas in ERCOT listed in the EPA's eGRID was presented , including assigning the wind farms to PCA based on the information provided by the PUCT, and calculating the NOx emission reductions based on the special version of 2007 eGRID developed by the EPA for the TCEQ. According to the developed models, the total MWh savings in the base year 1999 for the wind farms within the ERCOT region are 10,226,401 MWh and 25,152 MWh/day in the Ozone Season Period. The total NOx emissions reductions across all the counties amount to 6,051 tons/yr and 15 tons/day for the Ozone Season Period. Figure 1-3 and Figure 1-4 show the estimated emissions reductions from wind power in each county of Texas.

The ESL has been working with the EPA and TCEQ regarding a new version of eGRID for all ERCOT counties in Texas. A new version of eGRID was developed and presented in this report, which is based on the ERCOT congestion management zones. As the TCEQ moves the base year to more recent years, this updated version of eGRID, representing the current Texas market, may be used to estimate the emissions reduction from wind power in the next year's report.




Figure 1-3: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map




Figure 1-4: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map

1.4 Development of a degradation analysis

This report contains an updated analysis to determine what amounts of degradation could be observed in the measured power from Texas wind farms. Currently, the TCEQ uses a very conservative 5% degradation per year for the power output from a wind farm when making future projections from existing wind farms. Accordingly, the TCEQ asked the ESL to evaluate any observed degradation from the measured data for Texas wind farms. To accomplish this, nine wind farms (12 sites) from 2002 to 2007 and two wind farms (Brazos wind ranch and Sweetwater) from 2004 to 2007 were evaluated with a total capacity of 1208 MW.

In this analysis, a sliding statistical index was established for each site that uses 10th, 25th, 50th, 75th, 90th, and 99th percentiles of the hourly power generation over a 12-month sliding period, as well as mean, minimum and maximum hourly power generation of the same 12-month period. These indices are then displayed using one data symbol for each 12-month slide, beginning from the first 12-month period until the last 12-month period for each of the wind farms.

As shown in Table 1-2, of the 14 sites analyzed, ten sites showed an increase when one compares the 90th percentile of whole period to the 90th percentile of the first 12-month period, ranging from 3.5% to 23.7%. The remaining four sites showed a decrease from -3.2% to -18.1%. The weighted average of this increase across all wind farms studied is 8.7% (positive), which indicates that no degradation was observed from the aggregate energy production from these wind farms over the studied operation period.

Table 1-2: Summary of 90th Percentile Hourly Wind Power Analysis for Nine Wind Farms (14 Sites) in Texas

| Wind Farm | First 12-mo 90th Percentile Hourly Wind Power | | Average of the Sliding 12-mo 90th Percentile Hourly Wind Power | | Minimum of the Sliding 12-mo 90th Percentile Hourly Wind Power | | Maximum of the Sliding 12-mo 90th Percentile Hourly Wind Power | | No. of Month of Data | Capacity (MW) |
|--------------------------|---|-------|--|-------------------------|--|-------------------------|--|-------------------------|----------------------|---------------|
| | First 12-mo Ending Mo. | MW | MW | % Diff. vs. First 12-mo | MW | % Diff. vs. First 12-mo | MW | % Diff. vs. First 12-mo | | |
| Brazos Wind Ranch | Dec-04 | 127.5 | 131.9 | 3.5% | 125.1 | -1.9% | 137.2 | 7.6% | 48 | 160 |
| Indian Mesa | Dec-02 | 48.0 | 55.2 | 15.1% | 42.1 | -12.2% | 66.0 | 37.5% | 72 | 82.5 |
| Delaware | Dec-02 | 18.6 | 19.2 | 3.5% | 15.6 | -15.8% | 21.5 | 15.7% | 72 | 30 |
| Desert Sky | Dec-02 | 89.0 | 110.1 | 23.7% | 83.1 | -6.7% | 134.4 | 50.9% | 72 | 160 |
| King Mountain-NE | Dec-02 | 41.8 | 45.0 | 7.7% | 36.3 | -13.2% | 52.5 | 25.5% | 72 | 79 |
| King Mountain-NW | Dec-02 | 44.7 | 51.8 | 16.0% | 40.2 | -10.1% | 63.8 | 42.7% | 72 | 79 |
| King Mountain-SE | Dec-02 | 21.6 | 22.5 | 4.1% | 18.4 | -15.0% | 25.8 | 19.1% | 72 | 40 |
| King Mountain-SW | Dec-02 | 41.6 | 46.4 | 11.7% | 38.4 | -7.6% | 53.4 | 28.5% | 72 | 79 |
| Sweetwater Wind 1 | Dec-04 | 34.1 | 33.0 | -3.2% | 32.3 | -5.0% | 34.2 | 0.4% | 48 | 37.5 |
| Trent | Dec-02 | 108.8 | 125.4 | 15.2% | 108.2 | -0.6% | 132.8 | 22.0% | 72 | 150 |
| Woodward | Dec-02 | 85.3 | 90.6 | 6.3% | 80.4 | -5.7% | 100.3 | 17.6% | 72 | 160 |
| Kunitz | Dec-02 | 25.2 | 20.6 | -18.1% | 11.6 | -54.0% | 25.2 | 0.0% | 72 | 35 |
| Big Spring | Dec-02 | 27.2 | 25.6 | -6.1% | 23.9 | -12.0% | 27.2 | 0.0% | 72 | 41 |
| Southwest Mesa | Dec-02 | 51.1 | 48.0 | -5.9% | 38.5 | -24.6% | 55.3 | 8.2% | 72 | 75 |
| Weighted Average: | | | 8.7% | | -9.4% | | 23.2% | | Total: | 1208 |

1.5 Analysis of other renewable source

Other renewable energy projects throughout the state of Texas were located to determine NOx emissions reduction and are included in this section. Searches were conducted on five specific categories which include solar photovoltaic, solar thermal, geothermal, hydroelectric, and Landfill Gas-Fired Power Plants. Many newly located renewable energy projects are assembled for inclusion in this report (Table 1-3).

Table 1-3: New Projects Added in This Report

| Renewable Energy Source | No of New Projects identified and reported in May 2009 |
|-------------------------|--|
| Solar Photo-Voltaic | 114 |
| Solar Thermal | 3 |
| Land fill gas | 0 |
| Hydro-Electric | 0 |
| Geothermal | 24 |

1.6 Review of electricity savings and transmission planning study reported by ERCOT

In this report, the information posted on ERCOT's Renewable Energy Credit Program site www.texasrenewables.com is reviewed. In particular, information posted under the "Public Reports" tab was downloaded and assembled into an appropriate format for review. This includes ERCOT's 2001 through 2008 reports to the Legislature and information from ERCOT's listing of REC generators.

Each year ERCOT is required to compile a list of grid-connected sources that generate electricity from renewable energy and report them to the Legislature. Table 1-4 contains the data reported by ERCOT from 2001- 2008. Figure 1-5 is included to better illustrate the annual data collected by ERCOT.

Table 1-4: Electricity Generation by Renewable Resources (2001 to 2008)

| Technology Type | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 |
|-----------------|---------|-----------|-----------|-----------|-----------|-----------|------------|------------|
| Wind | 565,597 | 2,451,484 | 2,515,482 | 3,209,629 | 4,221,568 | 6,530,928 | 9,339,756 | 16,286,383 |
| Hydro | | 312,093 | 239,684 | 234,791 | 310,302 | 210,077 | 382,882 | 445,428 |
| Landfill gas | | 29,412 | 154,206 | 203,443 | 213,777 | 306,087 | 356,339 | 386,606 |
| Biomass | | | 39,496 | 36,940 | 58,637 | 60,569 | 51,823 | 70,833 |
| Solar | | 87 | 220 | 211 | 227 | 136 | 1,844 | 3,338 |
| Totals | 565,597 | 2,793,076 | 2,949,088 | 3,685,014 | 4,804,511 | 7,107,797 | 10,132,645 | 17,192,588 |




Figure 1-5: Electricity Generation by Renewable Resources (2001 to 2008)

1.7 Review of Combined Heat and Power Projects in Texas

A summary of all the Combined Heat and Power (CHP) applications in Texas and analysis on how it can impact the NOx emissions was provided in this section. As of 2007, 16,829 MW of CHP technologies were integrated into infrastructure served by the Texas electrical grid according to the database maintained by the DOE and Oak Ridge National Laboratory.

1.8 Preliminary reporting of NOx emissions savings in the 2008 Integrated Savings report to the TCEQ

In this report, the NOx emissions savings from the energy-efficiency programs from multiple Texas State Agencies working under Senate Bill 5 and Senate Bill 7 in a uniform format to allow the TCEQ to consider the combined savings for Texas' State Implementation Plan (SIP) planning purposes. This required that the analysis should include the cumulative savings estimates from all projects projected through 2020 for both the annual and Ozone Season Day¹ (OSD) NOx reductions. The NOx emissions reduction from all these programs were calculated using estimated emissions factors for 2007 from the US Environmental Protection Agency (US EPA) eGRID database, which had been specially prepared for this purpose.

In 2008, the cumulative total annual electricity savings from all programs is 20,380,240 MWh/year (12,727 tons-NOx/year). The total cumulative OSD electricity savings from all programs is 48,602 MWh/day, which would be a 2,025 MW average hourly load reduction during the OSD period (31.38 tons-NOx/day), as shown in Figure 1-6. By 2013, the total cumulative annual electricity savings from will be 32,736,151 MWh/year (20,395 tons-NOx/year). The total cumulative OSD electricity savings from all programs will be 80,866 MWh/day, which would be a 3,369 MW average hourly load reduction during the OSD period (52.10 tons-NOx/day).




Figure 1-6: Cumulative OSD NOx Emissions Reduction Projections through 2020

¹ An ozone season day (OSD) represents the daily average emissions during the period that runs from mid-July to mid -September.

TABLE OF CONTENTS

| | | |
|-------|--|----|
| 1. | EXECUTIVE SUMMARY..... | 3 |
| 1.1 | Development of Stakeholder's meetings | 4 |
| 1.2 | Analysis of wind farms using improved method and 2007 data..... | 4 |
| 1.3 | Analysis of emissions reduction from wind farms | 6 |
| 1.4 | Development of a degradation analysis..... | 7 |
| 1.5 | Analysis of other renewable source..... | 8 |
| 1.6 | Review of electricity savings and transmission planning study reported by ERCOT | 8 |
| 1.7 | Review of Combined Heat and Power Projects in Texas | 9 |
| 1.8 | Preliminary reporting of NOx emissions savings in the 2008 Integrated Savings report to the TCEQ | 10 |
| 2 | INTRODUCTION | 25 |
| 2.1 | Statement of Work for Calculations of Emissions from Wind and Other Renewables | 25 |
| 2.2 | Summary of Progress | 25 |
| 3 | ANALYSIS ON POWER PRODUCTION FROM WIND FARMS USING 2007 DATA | 27 |
| 3.1 | Introduction | 27 |
| 3.2 | Analysis of the Sweetwater-III Wind Farm Using OSP and NON-OSP Methods | 29 |
| 3.2.1 | Weather Data, Abilene NOAA Site..... | 29 |
| 3.2.2 | Wind Power Data..... | 30 |
| 3.2.3 | Modeling of Turbine Power vs. Wind Speed..... | 32 |
| 3.2.4 | Testing of the OSP and NON-OSP Models..... | 34 |
| 3.2.5 | Prediction of Wind Power in Base Year 1999 | 35 |
| 3.3 | Capacity Factor Analysis..... | 35 |
| 3.4 | Summary of Wind Power Production for All Wind Farms in the Texas ERCOT Region | 38 |
| 3.5 | Comparison of 1999 Estimated Wind Power in 2007 & 2008 Report and This Report | 42 |
| 3.6 | Uncertainty Analysis on the 2007 Daily Regression Models | 47 |
| 4 | DEGRADATION ANALYSIS FOR WIND FARMS | 50 |
| 5 | CALCULATING NOX EMISSIONS REDUCTION FROM WIND POWER | 60 |
| 5.1 | Calculation of NOx Emissions from Wind Power Using 2007 eGRID..... | 60 |
| 5.2 | Updated Version of eGRID | 61 |
| 6 | OTHER RENEWABLE SOURCES | 72 |
| 6.1 | Implementation..... | 72 |
| 6.2 | Renewable Energy Projects..... | 72 |
| 6.2.1 | Solar Photovoltaic..... | 72 |
| 6.2.2 | Solar Thermal | 73 |
| 6.2.3 | Hydroelectric | 73 |
| 6.2.4 | Geothermal | 73 |
| 6.2.5 | Landfill Gas-Fired Power Plants..... | 73 |

| | | |
|--------|---|-----|
| 6.3 | Results | 74 |
| 6.4 | References | 74 |
| 7 | REVIEW OF ERCOT'S RENEWABLE ENERGY CREDIT PROGRAM INFORMATION | 107 |
| 7.1 | Introduction | 107 |
| 7.2 | Summary of Renewable Projects in Texas | 107 |
| 8 | COMBINED HEAT AND POWER PROJECTS IN TEXAS | 117 |
| 9 | REPORTING OF NOX EMISSIONS CREDITS TO THE TCEQ (PRELIMINARY)..... | 123 |
| 9.1 | Introduction | 123 |
| 9.2 | Legislative Background..... | 124 |
| 9.3 | Calculation of Integrated NOx Emissions Reductions from Multiple State Agencies Participating in the Texas Emissions Reduction Plan (TERP) | 124 |
| 9.4 | Description of the Analysis Method..... | 125 |
| 9.5 | Calculation Procedure | 126 |
| 9.6 | Results | 129 |
| 9.7 | Summary | 130 |
| 10 | APPENDIX A | 139 |
| 10.1 | Presentation in March 2008..... | 139 |
| 10.2 | Presentation in May 2008..... | 150 |
| 10.3 | Presentation on May 22, 2008 | 152 |
| 10.4 | Presentation on September 17, 2008 | 154 |
| 10.5 | Presentation on September 25, 2008 | 166 |
| 10.6 | Presentation on September 30, 2008 | 173 |
| 11 | APPENDIX B | 175 |
| 11.1 | Brazos Wind Ranch..... | 176 |
| 11.1.1 | Brazos Wind Ranch – BRAZ_WND_WND1 | 176 |
| 11.1.2 | Brazos Wind Ranch – BRAZ_WND_WND2 | 179 |
| 11.2 | Buffalo Gap 1- BUFF_GAP_UNIT1 120 MW)..... | 182 |
| 11.2.1 | Buffalo Gap 1 – BUFF_GAP_UNIT1 120 MW)..... | 182 |
| 11.3 | Callahan Divide Wind Energy Center | 185 |
| 11.3.1 | Callahan Divide – CALLAHAN_WND1 | 185 |
| 11.4 | Horse Hollow 1 | 188 |
| 11.4.1 | Horse Hollow 1 – H_HOLLOW_WND1 | 188 |
| 11.5 | Horse Hollow 2 | 191 |
| 11.5.1 | Horse Hollow 2 – H_HOLLOW2_WIND1 | 191 |
| 11.6 | Horse Hollow 3 | 194 |
| 11.6.1 | Horse Hollow 3 – H_HOLLOW3_WIND1 | 194 |
| 11.7 | Horse Hollow 4 | 197 |
| 11.7.1 | Horse Hollow 4 – H_HOLLOW4_WIND1 | 197 |
| 11.8 | Desert Sky | 200 |
| 11.8.1 | Desert Sky – INDNENR_INDNENR | 200 |

| | | |
|---------|--|-----|
| 11.8.2 | Desert Sky – INDNENR_INDNENR_2 | 203 |
| 11.9 | King Mountain Wind Ranch (KING_NE)..... | 206 |
| 11.9.1 | King Mountain – KING_NE_KINGNE..... | 206 |
| 11.10 | King Mountain Wind Ranch (KING_NW) | 209 |
| 11.10.1 | King Mountain – KING_NW_KINGNW | 209 |
| 11.11 | King Mountain Wind Ranch (KING_SE) | 212 |
| 11.11.1 | King Mountain – KING_SE_KINGSE | 212 |
| 11.12 | King Mountain Wind Ranch (KING_SW) | 215 |
| 11.12.1 | King Mountain – KING_SW_KINGSW | 215 |
| 11.13 | Red Canyon | 218 |
| 11.13.1 | Red Canyon 1 – RDCANYON_RDCNY1 | 218 |
| 11.14 | Sweetwater Wind 2 | 221 |
| 11.14.1 | Sweetwater Wind 2 – SWEETWN2_WND2..... | 221 |
| 11.15 | Sweetwater Wind 3 | 224 |
| 11.15.1 | Sweetwater Wind 3 – SWEETWN3_WND3..... | 224 |
| 11.16 | Sweetwater Wind 1 | 227 |
| 11.16.1 | Sweetwater Wind 1 – SWEETWND_WND1 | 227 |
| 11.17 | Trent Mesa..... | 230 |
| 11.17.1 | Trent Mesa – TRENT_TRENT..... | 230 |
| 11.18 | Delaware Mountain Wind Farm..... | 233 |
| 11.18.1 | Delaware Mountain – DELAWARE_WIND_NWP..... | 233 |
| 11.19 | Indian Mesa | 236 |
| 11.19.1 | Indian Mesa – INDNNWP_INDNNWP | 236 |
| 11.20 | Texas Wind Power Project | 239 |
| 11.20.1 | Texas Wind Power Project – KUNITZ_WIND_LGE | 239 |
| | Figure 11-85: KUNITZ_WIND_LGE – Hourly Wind Power vs. NOAA Wind Speed (2007) | 239 |
| 11.21 | Big Spring Wind Power..... | 242 |
| 11.21.1 | Big Spring Wind Power – SGMTN_SIGNALMT..... | 242 |
| 11.22 | Southwest Mesa Wind Project..... | 245 |
| 11.22.1 | Southwest Mesa Wind Project – SW_MESA_SW_MESA | 245 |
| 11.23 | Woodward Mountain Ranch (WOODWRD1) | 248 |
| 11.23.1 | Woodward Mountain Ranch (WOODWRD1_WOODWRD1) | 248 |
| 11.24 | Woodward Mountain Ranch (WOODWRD2) | 251 |
| 11.24.1 | Woodward Mountain Ranch (WOODWRD2_WOODWRD2) | 251 |
| 11.25 | Buffalo Gap2 (BUFF_GAP_UNIT2) | 254 |
| 11.26 | Buffalo Gap2 (BUFF_GAP_UNIT2) | 254 |
| 11.27 | Capricorn Ridge Wind (CAPRIDGE_CR1)..... | 257 |
| 11.27.1 | Capricorn Ridge Wind (CAPRIDGE_CR1) | 257 |
| 11.28 | Capricorn Ridge Wind (CAPRIDGE_CR2)..... | 260 |
| 11.28.1 | Capricorn Ridge Wind (CAPRIDGE_CR2) | 260 |
| 11.29 | Camp Springs Wind Energy Center (CSEC_CSECG1) | 263 |
| 11.29.1 | Camp Springs Wind Energy Center (CSEC_CSECG1) | 263 |
| 11.30 | Lone Star – Mesquite Wind (LNCRK_G83)..... | 266 |
| 11.30.1 | Lone Star – Mesquite Wind (LNCRK_G83) | 266 |

| | | |
|---------|---|-----|
| 11.31 | Forest Creek Wind Farm (MCDLD_FCW1)..... | 269 |
| 11.31.1 | Forest Creek Wind Farm (MCDLD_FCW1) | 269 |
| 11.32 | Sand Bluff Wind Farm (MCDLD_SBW1)..... | 272 |
| 11.32.1 | Sand Bluff Wind Farm (MCDLD_SBW1) | 272 |
| 11.33 | Sweetwater (SWEETWN2_WND24 18 MW) | 275 |
| 11.33.1 | Sweetwater (SWEETWN2_WND24)..... | 275 |
| 11.34 | Sweetwater (SWEETWN4_WIND4A)..... | 278 |
| 11.34.1 | Sweetwater (SWEETWN4_WIND4A)..... | 278 |
| 11.35 | Sweetwater (SWEETWN4_WIND4B) | 281 |
| 11.35.1 | Sweetwater (SWEETWN4_WIND4B)..... | 281 |
| 12 | APPENDIX C | 284 |
| 12.1 | Data Files for Wind Energy Production and Weather Files for the Modeling..... | 284 |
| 12.2 | Papers Presented..... | 284 |

LIST OF FIGURES

| | |
|---|----|
| Figure 1-1: Comparison of 2007 Measured and 1999 Estimated Power Production for Each Wind Farm | 5 |
| Figure 1-2: Comparison of 2007 OSD Measured and 1999 OSD Estimated Power Production for Each Wind Farm | 5 |
| Figure 1-3: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map | 6 |
| Figure 1-4: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map | 7 |
| Figure 1-5: Electricity Generation by Renewable Resources (2001 to 2008) | 9 |
| Figure 1-6: Cumulative OSD NOx Emissions Reduction Projections through 2020 | 10 |
| Figure 3-1: Installed Wind Power Capacity and Power Generation in the ERCOT region from 2001 to December 2008 | 27 |
| Figure 3-2: Completed and Announced Wind Projects in Texas by April 2009 | 28 |
| Figure 3-3: Hourly NOAA-ABI Wind Speed (1999 and 2007)..... | 29 |
| Figure 3-4: Daily NOAA-ABI Wind Speed (1999 and 2007)..... | 30 |
| Figure 3-5: Measured Hourly Wind Power (2007), Sweetwater III Wind Farm | 30 |
| Figure 3-6: Measured Daily Wind Power (2007), Sweetwater III Wind Farm | 30 |
| Figure 3-7: Hourly Wind Power vs. NOAA-ABI Wind Speed (2007)..... | 31 |
| Figure 3-8: Daily Wind Power vs. NOAA-ABI Wind Speed for the Non-OSD Period..... | 31 |
| Figure 3-9: Daily Wind Power vs. NOAA-ABI Wind Speed (2007) for the OSD Period | 31 |
| Figure 3-10: Predicted Wind Power in OSP Using NOAA-ABI Wind Speed (2007)..... | 33 |
| Figure 3-11: Measured and Predicted Power Production in August 2006 Using the OSP Model..... | 34 |
| Figure 3-12: Measured and Predicted Power Production in January 2006 Using the Non-OSP Model..... | 35 |
| Figure 3-13: Predicted Capacity Factors Using Daily Models (2007)..... | 36 |
| Figure 3-14: Predicted Capacity Factors Using Daily Models (1999-2007) | 36 |
| Figure 3-15: 1999 and 2007 Monthly Average Wind Speed for Four NOAA Weather Stations | 37 |
| Figure 3-16: Comparison of Total 2007 Measured and 1999 Estimated Power Production | 40 |
| Figure 3-17: Comparison of Total 2007 OSD Measured and 1999 OSD Estimated Power Production..... | 40 |
| Figure 3-18: Comparison of 2007 Measured and 1999 Estimated Power Production for Each Wind Farm | 41 |
| Figure 3-19: Comparison of 2007 OSD Measured and 1999 OSD Estimated Power Production for Each Wind Farm | 41 |
| Figure 3-20: Comparison of Measured Wind Power of 2005, 2006 and 2007 (Annual and OSD) | 44 |
| Figure 3-21: Comparison of Estimated Power of 1999 using the 2005, 2006 and 2007 Model (Annual and OSD) | 45 |
| Figure 3-22: Comparison of Difference between 1999 Predicted Power and 2006/2007 Measured Power. | 46 |
| Figure 3-23: Comparison of Difference between 1999 OSD Predicted Power and 2006/2007 OSD Measured Power..... | 46 |
| Figure 3-24: Linear Model Presentation of the Daily Wind Power Generation on the Year 2007 for Callahan Wind Farm | 47 |
| Figure 4-1: Sliding 12-month Hourly Wind Power Generation for Indian Mesa | 51 |
| Figure 4-2: Sliding 12-month Hourly Wind Power Generation for Desert Sky | 51 |
| Figure 4-3: Sliding 12-month Hourly Wind Power Generation for King Mountain – NE | 52 |
| Figure 4-4: Sliding 12-month Hourly Wind Power Generation for King Mountain – NW | 52 |
| Figure 4-5: Sliding 12-month Hourly Wind Power Generation for King Mountain – SE..... | 53 |
| Figure 4-6: Sliding 12-month Hourly Wind Power Generation for King Mountain – SW | 53 |
| Figure 4-7: Sliding 12-month Hourly Wind Power Generation for Kunitz | 54 |
| Figure 4-8: Sliding 12-month Hourly Wind Power Generation for Trent Mesa..... | 54 |
| Figure 4-9: Sliding 12-month Hourly Wind Power Generation for Southwest Mesa..... | 55 |
| Figure 4-10: Sliding 12-month Hourly Wind Power Generation for Woodward | 55 |
| Figure 4-11: Sliding 12-month Hourly Wind Power Generation for Big Spring..... | 56 |
| Figure 4-12: Sliding 12-month Hourly Wind Power Generation for Delaware..... | 56 |
| Figure 4-13: Sliding 12-month Hourly Wind Power Generation for Brazos Wind Ranch..... | 57 |
| Figure 4-14: Sliding 12-month Hourly Wind Power Generation for Sweetwater Wind Farm | 57 |
| Figure 4-15: Design and Measured Maximum Capacity for Nine Wind Farms..... | 59 |

| | |
|--|-----|
| Figure 5-1: NOx Emissions (lbs/MWh) from PCA-AEP West in the 2007 Annual eGRID | 62 |
| Figure 5-2: NOx Emissions (lbs/MWh) from PCA-LCRA in the 2007 Annual eGRID | 62 |
| Figure 5-3: NOx Emissions (lbs/MWh) from PCA-TXU in the 2007 Annual eGRID..... | 63 |
| Figure 5-4: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map | 67 |
| Figure 5-5: 1999 Predicted OSD NOx Reductions from Wind Power in Texas Map | 67 |
| Figure 5-6: 1999 Predicted Annual NOx Reductions from Wind Power | 68 |
| Figure 5-7: 1999 Predicted OSD NOx Reductions from Wind Power | 68 |
| Figure 5-8: Average Modeled Flows on Commercially Significant Constraints for 2006 | 69 |
| Figure 6-1: Solar Photovoltaic Projects throughout Texas..... | 100 |
| Figure 6-2: Solar Thermal Projects throughout Texas..... | 101 |
| Figure 6-3: Hydropower Plants throughout Texas | 101 |
| Figure 6-4: Geothermal Projects Installed throughout Texas | 102 |
| Figure 6-5: Landfill Gas-Fired Power Projects Installed throughout Texas | 102 |
| Figure 6-6: Annual Electric Savings per County from PV Projects | 103 |
| Figure 6-7: Ozone Season Day Electric Savings per County from PV Projects..... | 103 |
| Figure 6-8: NOx Emissions Reductions per County from PV Projects | 104 |
| Figure 6-9: Ozone Season Day NOx Emissions Reductions per County from PV Projects..... | 104 |
| Figure 6-10: Annual Electric Savings per County from Solar Thermal Projects | 105 |
| Figure 6-11: Ozone Season Day Electric Savings per County from Solar Thermal Projects | 105 |
| Figure 6-12: NOx Emissions Reductions per County from Solar Thermal Projects | 106 |
| Figure 6-13: Ozone Season Day NOx Emissions Reduction per County from Solar Thermal Projects.... | 106 |
| Figure 7-1: Electricity Generation by Renewable Sources (ERCOT: 2001 – 2008 Annual)..... | 115 |
| Figure 7-2: Electricity Generation by Renewable Sources Other Than Wind (ERCOT: 2001 – 2008 Annual) | 116 |
| Figure 7-3: Electricity Generation by Renewable Sources from Solar and Biomass (ERCOT: 2001 – 2008 Annual) | 116 |
| Figure 8-1: Map of Existing CHP Installations in Texas..... | 118 |
| Figure 8-3: ESL CHP Survey Form | 119 |
| Figure 9-1: Process Flow Diagram of the NOx Emissions Reduction Calculations..... | 132 |
| Figure 9-2: Cumulative OSD NOx Emissions Reduction Projections through 2020 | 136 |
| Figure 9-3: Cumulative OSD NOx Emissions Reduction Projections through 2020 | 136 |
| Figure 10-1: Slides presented on March 19, 2008 (Part 1)..... | 139 |
| Figure 10-2: Slides presented on March 19, 2008 (Part 2)..... | 140 |
| Figure 10-3: Slides presented on March 19, 2008 (Part 3)..... | 141 |
| Figure 10-4: Slides presented on March 19, 2008 (Part 4)..... | 142 |
| Figure 10-5: Slides presented on March 19, 2008 (Part 5)..... | 143 |
| Figure 10-6: Slides presented on March 19, 2008 (Part 6)..... | 144 |
| Figure 10-7: Slides presented on March 19, 2008 (Part 7) | 145 |
| Figure 10-8: Slides presented on March 19, 2008 (Part 8)..... | 146 |
| Figure 10-9: Slides presented on March 19, 2008 (Part 9)..... | 147 |
| Figure 10-10: Slides presented on March 19, 2008 (Part 10)..... | 148 |
| Figure 10-11: Slides presented on March 19, 2008 (Part 11)..... | 149 |
| Figure 10-12: Slides presented in May, 2008 (Part 1)..... | 150 |
| Figure 10-13: Slides presented in May, 2008 (Part 2)..... | 151 |
| Figure 10-14: Slides presented on May 22, 2008 (Part 1)..... | 152 |
| Figure 10-15: Slides presented on May22, 2008 (Part 2)..... | 153 |
| Figure 10-16: Slides presented on September 17, 2008 (Part 1) | 154 |
| Figure 10-17: Slides presented on September 17, 2008 (Part 2) | 155 |
| Figure 10-18: Slides presented on September 17, 2008 (Part 3) | 156 |
| Figure 10-19: Slides presented on September 17, 2008 (Part 4) | 157 |
| Figure 10-20: Slides presented on September 17, 2008 (Part 5) | 158 |
| Figure 10-21: Slides presented on September 17, 2008 (Part 6) | 159 |
| Figure 10-22: Slides presented on September 17, 2008 (Part 7) | 160 |
| Figure 10-23: Slides presented on September 17, 2008 (Part 8) | 161 |
| Figure 10-24: Slides presented on September 17, 2008 (Part 9) | 162 |
| Figure 10-25: Slides presented on September 17, 2008 (Part 10) | 163 |

| | |
|---|-----|
| Figure 10-26: Slides presented on September 17, 2008 (Part 11) | 164 |
| Figure 10-27: Slides presented on September 17, 2008 (Part 12) | 165 |
| Figure 10-28: Slides presented on September 25, 2008 (Part 1) | 166 |
| Figure 10-29: Slides presented on September 25, 2008 (Part 2) | 167 |
| Figure 10-30: Slides presented on September 25, 2008 (Part 3) | 168 |
| Figure 10-31: Slides presented on September 25, 2008 (Part 4) | 169 |
| Figure 10-32: Slides presented on September 25, 2008 (Part 5) | 170 |
| Figure 10-33: Slides presented on September 25, 2008 (Part 6) | 171 |
| Figure 10-34: Slides presented on September 25, 2008 (Part 7) | 172 |
| Figure 10-35: Slides presented on September 30, 2008 (Part 1) | 173 |
| Figure 10-36: Slides presented on September 25, 2008 (Part 2) | 174 |
| Figure 11-1: BRAZ_WND_WND1 - Hourly Wind Power vs. NOAA Wind Speed (2007) | 176 |
| Figure 11-2: BRAZ_WND_WND1 - Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non OSP Model)..... | 176 |
| Figure 11-3: BRAZ_WND_WND1 - Predicted Wind Power in OSP Using NOAA Wind Speed (2007). 178 | 178 |
| Figure 11-4: BRAZ_WND_WND1 – Predicted Capacity Factors Using Daily Models (2007) | 178 |
| Figure 11-5: BRAZ_WND_WND2 - Hourly Wind Power vs. NOAA Wind Speed (2007) | 179 |
| Figure 11-6: BRAZ_WND_WND2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 179 |
| Figure 11-7: BRAZ_WND_WND2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) 180 | 180 |
| Figure 11-8: BRAZ_WND_WND2 – Predicted Capacity Factors Using Daily Models (2007) | 181 |
| Figure 11-9: BUFF_GAP_UNIT1 - Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 182 |
| Figure 11-10: BUFF_GAP_UNIT1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 182 |
| Figure 11-11: BUFF_GAP_UNIT1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007). 184 | 184 |
| Figure 11-12: BUFF_GAP_UNIT1 – Predicted Capacity Factors Using Daily Models (2007) | 184 |
| Figure 11-13: CALLAHAN_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 185 |
| Figure 11-14: CALLAHAN_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 185 |
| Figure 11-15: CALLAHAN_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)187 | 187 |
| Figure 11-16: CALLAHAN_WND1 – Predicted Capacity Factors Using Daily Models (2007) | 187 |
| Figure 11-17: H_HOLLOW_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 188 |
| Figure 11-18: H_HOLLOW_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 188 |
| Figure 11-19: H_HOLLOW_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)190 | 190 |
| Figure 11-20: H_HOLLOW_WND1 – Predicted Capacity Factors Using Daily Models (2007) | 190 |
| Figure 11-21: H_HOLLOW2_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 191 |
| Figure 11-22: H_HOLLOW2_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 191 |
| Figure 11-23: H_HOLLOW2_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 193 |
| Figure 11-24: H_HOLLOW2_WIND1 – Predicted Capacity Factors Using Daily Models (2007)..... | 193 |
| Figure 11-25: H_HOLLOW3_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 194 |
| Figure 11-26: H_HOLLOW3_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 194 |
| Figure 11-27: H_HOLLOW3_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 196 |
| Figure 11-28: H_HOLLOW3_WIND1 – Predicted Capacity Factors Using Daily Models (2007)..... | 196 |
| Figure 11-29: H_HOLLOW4_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 197 |
| Figure 11-30: H_HOLLOW4_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non- OSP Model) | 197 |
| Figure 11-31: H_HOLLOW4_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 199 |
| Figure 11-32: H_HOLLOW4_WIND1 – Predicted Capacity Factors Using Daily Models (2007)..... | 199 |
| Figure 11-33: INDNENR_INDNENR – Hourly Wind Power vs. NOAA Wind Speed (2007) | 200 |

| | |
|--|-----|
| Figure 11-34: INDNENR_INDNENR – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 200 |
| Figure 11-35: INDNENR_INDNENR – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 202 |
| Figure 11-36: INDNENR_INDNENR – Predicted Capacity Factors Using Daily Models (2007)..... | 202 |
| Figure 11-37: INDNENR_INDNENR_2 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 203 |
| Figure 11-38: INDNENR_INDNENR_2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 203 |
| Figure 11-39: INDNENR_INDNENR_2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 204 |
| Figure 11-40: INDNENR_INDNENR_2 – Predicted Capacity Factors Using Daily Models (2007)..... | 205 |
| Figure 11-41: KING_NE_KINGNE – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 206 |
| Figure 11-42: KING_NE_KINGNE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 206 |
| Figure 11-43: KING_NE_KINGNE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 208 |
| Figure 11-44: KING_NE_KINGNE – Predicted Capacity Factors Using Daily Models (2007) | 208 |
| Figure 11-45: KING_NW_KINGNW – Hourly Wind Power vs. NOAA Wind Speed (2007) | 209 |
| Figure 11-46: KING_NW_KINGNW – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 209 |
| Figure 11-47: KING_NW_KINGNW – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 211 |
| Figure 11-48: KING_NW_KINGNW – Predicted Capacity Factors Using Daily Models (2007)..... | 211 |
| Figure 11-49: KING_SE_KINGSE – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 212 |
| Figure 11-50: KING_SE_KINGSE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 212 |
| Figure 11-51: KING_SE_KINGSE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007). | 214 |
| Figure 11-52: KING_SE_KINGSE – Predicted Capacity Factors Using Daily Models (2007) | 214 |
| Figure 11-53: KING_SW_KINGSW – Hourly Wind Power vs. NOAA Wind Speed (2007) | 215 |
| Figure 11-54: KING_SW_KINGSW – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 215 |
| Figure 11-55: KING_SW_KINGSW – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 217 |
| Figure 11-56: KING_SW_KINGSW - Predicted Capacity Factors Using Daily Models (2007)..... | 217 |
| Figure 11-57: RDCANYON_RDCNY1 – Hourly Wind Power vs. NOAA Wind Speed (2006)..... | 218 |
| Figure 11-58: RDCANYON_RDCNY1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 218 |
| Figure 11-59: RDCANYON_RDCNY1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 220 |
| Figure 11-60: RDCANYON_RDCNY1 – Predicted Capacity Factors Using Daily Models (2007) | 220 |
| Figure 11-61: SWEETWN2_WND2 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 221 |
| Figure 11-62: SWEETWN2_WND2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 221 |
| Figure 11-63: SWEETWN2_WND2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 223 |
| Figure 11-64: SWEETWN2_WND2 – Predicted Capacity Factors Using Daily Models (2007) | 223 |
| Figure 11-65: SWEETWN3_WND3 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 224 |
| Figure 11-66: SWEETWN3_WND3 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 224 |
| Figure 11-67: SWEETWN3_WND3 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 226 |
| Figure 11-68: SWEETWN3_WND3 – Predicted Capacity Factors Using Daily Models (2007) | 226 |
| Figure 11-69: SWEETWND_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 227 |
| Figure 11-70: SWEETWND_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 227 |
| Figure 11-71: SWEETWND_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 229 |
| Figure 11-72: SWEETWND_WND1 – Predicted Capacity Factors Using Daily Models (2007) | 229 |
| Figure 11-73: TRENT_TRENT – Hourly Wind Power vs. NOAA Wind Speed (2007) | 230 |

| | |
|---|-----|
| Figure 11-74: TRENT_TRENT – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 230 |
| Figure 11-75: TRENT_TRENT – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 232 |
| Figure 11-76: TRENT_TRENT – Predicted Capacity Factors Using Daily Models (2007) | 232 |
| Figure 11-77: DELAWARE_WIND_NWP – Hourly Wind Power vs. NOAA Wind Speed (2007) | 233 |
| Figure 11-78: DELAWARE_WIND_NWP – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 233 |
| Figure 11-79: DELAWARE_WIND_NWP – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 235 |
| Figure 11-80: DELAWARE_WIND_NWP – Predicted Capacity Factors Using Daily Models (2007).... | 235 |
| Figure 11-81: INDNNWP_INDNNWP- Hourly Wind Power vs. NOAA Wind Speed (2007) | 236 |
| Figure 11-82: INDNNWP_INDNNWP – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 236 |
| Figure 11-83: INDNNWP_INDNNWP – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 238 |
| Figure 11-84: INDNNWP_INDNNWP – Predicted Capacity Factors Using Daily Models (2007) | 238 |
| Figure 11-85: KUNITZ_WIND_LGE – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 239 |
| Figure 11-86: KUNITZ_WIND_LGE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 239 |
| Figure 11-87: KUNITZ_WIND_LGE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 241 |
| Figure 11-88: KUNITZ_WIND_LGE – Predicted Capacity Factors Using Daily Models (2007) | 241 |
| Figure 11-89: SGMTN_SIGNALMT – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 242 |
| Figure 11-90: SGMTN_SIGNALMT – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 242 |
| Figure 11-91: SGMTN_SIGNALMT – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 244 |
| Figure 11-92: SGMTN_SIGNALMT – Predicted Capacity Factors Using Daily Models (2007) | 244 |
| Figure 11-93: SW_MESA_SW_MESA - Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 245 |
| Figure 11-94: SW_MESA_SW_MESA – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 245 |
| Figure 11-95: SW_MESA_SW_MESA – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 247 |
| Figure 11-96: SW_MESA_SW_MESA – Predicted Capacity Factors Using Daily Models (2007)..... | 247 |
| Figure 11-97: WOODWRD1_WOODWRD1 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 248 |
| Figure 11-98: WOODWRD1_WOODWRD1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 248 |
| Figure 11-99: WOODWRD1_WOODWRD1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 250 |
| Figure 11-100: WOODWRD1_WOODWRD1 – Predicted Capacity Factors Using Daily Models (2007)..... | 250 |
| Figure 11-101: WOODWRD2_WOODWRD2 – Hourly Wind Power vs. NOAA Wind Speed (2007).... | 251 |
| Figure 11-102: WOODWRD2_WOODWRD2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 251 |
| Figure 11-103: WOODWRD2_WOODWRD2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 253 |
| Figure 11-104: WOODWRD2_WOODWRD2 – Predicted Capacity Factors Using Daily Models (2007)..... | 253 |
| Figure 11-105: BUFF_GAP_UNIT2 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 254 |
| Figure 11-106: BUFF_GAP_UNIT2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 254 |
| Figure 11-107: BUFF_GAP_UNIT2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 256 |
| Figure 11-108: BUFF_GAP_UNIT2 – Predicted Capacity Factors Using Daily Models (2007) | 256 |
| Figure 11-109: CAPRIDGE_CR1 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 257 |
| Figure 11-110: CAPRIDGE_CR1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 257 |
| Figure 11-111: CAPRIDGE_CR1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)... | 259 |
| Figure 11-112: CAPRIDGE_CR1 – Predicted Capacity Factors Using Daily Models (2007)..... | 259 |

| | |
|---|-----|
| Figure 11-113: CAPRIDGE_CR2 – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 260 |
| Figure 11-114: CAPRIDGE_CR2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 260 |
| Figure 11-115: CAPRIDGE_CR2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)... | 262 |
| Figure 11-116: CAPRIDGE_CR2 – Predicted Capacity Factors Using Daily Models (2007)..... | 262 |
| Figure 11-117: CSEC_CSECG1– Hourly Wind Power vs. NOAA Wind Speed (2007) | 263 |
| Figure 11-118: CSEC_CSECG1– Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 263 |
| Figure 11-119: CSEC_CSECG1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 265 |
| Figure 11-120: CSEC_CSECG1 – Predicted Capacity Factors Using Daily Models (2007)..... | 265 |
| Figure 11-121: LNCRK_G83– Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 266 |
| Figure 11-122: LNCRK_G83– Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 266 |
| Figure 11-123: LNCRK_G83 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)..... | 268 |
| Figure 11-124: LNCRK_G83 – Predicted Capacity Factors Using Daily Models (2007) | 268 |
| Figure 11-125: MCDLD_FCW1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 269 |
| Figure 11-126: MCDLD_FCW1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 269 |
| Figure 11-127: MCDLD_FCW1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007).... | 271 |
| Figure 11-128: MCDLD_FCW1 – Predicted Capacity Factors Using Daily Models (2007)..... | 271 |
| Figure 11-129: MCDLD_SBW1 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 272 |
| Figure 11-130: MCDLD_SBW1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)..... | 272 |
| Figure 11-131: MCDLD_SBW1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007).... | 274 |
| Figure 11-132: MCDLD_SBW1 – Predicted Capacity Factors Using Daily Models (2007)..... | 274 |
| Figure 11-133: SWEETWN2_WND24 – Hourly Wind Power vs. NOAA Wind Speed (2007) | 275 |
| Figure 11-134: SWEETWN2_WND24 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 275 |
| Figure 11-135: SWEETWN2_WND24 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 277 |
| Figure 11-136: SWEETWN2_WND24 – Predicted Capacity Factors Using Daily Models (2007) | 277 |
| Figure 11-137: SWEETWN4_WIND4A – Hourly Wind Power vs. NOAA Wind Speed (2007)..... | 278 |
| Figure 11-138: SWEETWN4_WIND4A – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 278 |
| Figure 11-139: SWEETWN4_WIND4A – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 280 |
| Figure 11-140: SWEETWN4_WIND4A – Predicted Capacity Factors Using Daily Models (2007) | 280 |
| Figure 11-141: SWEETWN4_WIND4B – Hourly Wind Power vs. NOAA Wind Speed (2007) | 281 |
| Figure 11-142: SWEETWN4_WIND4B – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model) | 281 |
| Figure 11-143: SWEETWN4_WIND4B – Predicted Wind Power in OSP Using NOAA Wind Speed (2007) | 283 |
| Figure 11-144: SWEETWN4_WIND4B – Predicted Capacity Factors Using Daily Models (2007) | 283 |

LIST OF TABLES

| | |
|--|-----|
| Table 1-1: Installed/Announced Wind Power Capacity and The Statutory Mandates | 3 |
| Table 1-2: Summary of 90 th Percentile Hourly Wind Power Analysis for Nine Wind Farms (14 Sites) in Texas..... | 8 |
| Table 1-3: New Projects Added in This Report..... | 8 |
| Table 1-4: Electricity Generation by Renewable Resources (2001 to 2008)..... | 9 |
| Table 3-1: Non-OSP Model Coefficients | 32 |
| Table 3-2: OSP Model Coefficients | 32 |
| Table 3-3: Predicted Wind Power Using OSP and NON-OSP Daily Models | 33 |
| Table 3-4: Predicted vs. Measured Wind Power in 2006 | 34 |
| Table 3-5: Predicted Power Production in 1999 | 35 |
| Table 3-6: Summary of Predicted Capacity Factors (1999-2007) | 37 |
| Table 3-7: Summary of Power Production for All Wind Farms..... | 39 |
| Table 3-8: Summary of 1999 and 2007 Monthly Average Wind Speed for Four NOAA Weather Stations | 39 |
| Table 3-9: Summary of Predicted Wind Power in Base Years (1999, 2000 and 2002) for All Wind Farms in the ERCOT Region | 42 |
| Table 3-10: Comparison of Wind Speed of 2005, 2006 and 2007 | 43 |
| Table 3-11: Statistical Parameters of the Determined 2007 Daily Power Production Linear Models..... | 49 |
| Table 3-12: 1999 Uncertainty of the Power Generation Prediction using the Linear Daily Models | 49 |
| Table 4-1: Summary of 90 th Percentile Hourly Wind Power Analysis for Nine Wind Farms in Texas | 58 |
| Table 4-2: Summary of Maximum Hourly Wind Power Analysis for Nine Wind Farms in Texas | 58 |
| Table 5-1: Wind Power Production Assigned to Each PCA in the ERCOT Region | 63 |
| Table 5-2: Wind Farm Information from the PUCT – 2005..... | 63 |
| Table 5-3: Wind Farm Information from the PUCT – 2007..... | 64 |
| Table 5-4: Annual NOx Reductions Using the 1999 Base Year and the 2007 eGrid (25%) | 65 |
| Table 5-5: OSD NOx Reductions using the 1999 Base Year and the 2007 eGrid (25%)..... | 66 |
| Table 5-6: Distribution of the Emission Reductions per CM Zone for each County (Year 2010) | 70 |
| Table 5-7: Distribution of the Emission Reductions per CM Zone for each County (Year 2015) | 71 |
| Table 6-1: New Projects Added in This Report..... | 74 |
| Table 6-2: Solar Photovoltaic Cell Projects: Data and Information | 75 |
| Table 6-3: Solar Photovoltaic Cell Projects: Energy and NOx Reductions..... | 85 |
| Table 6-4: Solar Thermal Projects..... | 88 |
| Table 6-5: Solar Thermal Projects Emissions Reductions..... | 89 |
| Table 6-6: Solar Thermal Special Project..... | 89 |
| Table 6-7: Hydropower Plant Information | 90 |
| Table 6-8: Geothermal Heat Pump Energy Projects | 91 |
| Table 6-9: Landfill Gas-Fired Power Plants: Operational | 96 |
| Table 6-10: Landfill Gas-Fired Power Plants: Candidates | 98 |
| Table 6-11: Landfill Gas-Fired Power Plants: Potential..... | 99 |
| Table 7-1: ERCOT REC Generator List – Biomass | 108 |
| Table 7-2: ERCOT REC Generator List – Hydro..... | 108 |
| Table 7-3: ERCOT REC Generator List – Solar | 109 |
| Table 7-4: ERCOT REC Generator List – Landfill Gas..... | 109 |
| Table 7-5: ERCOT REC Generator List – Wind..... | 110 |
| Table 7-6: Electricity Generation by Renewable Sources (MWh, ERCOT: 2001 – 2008 by Quarter) | 113 |
| Table 7-7: Electricity Generation by Renewable Sources (MWh, ERCOT: 2001 – 2008 by Quarter) | 115 |
| Table 8-1: CHP units located in Texas as of 2007 | 120 |
| Table 9-1: Final Adjustment Factors used for the Calculation of the Annual and OSD NOx Savings for the Different Programs..... | 132 |
| Table 9-2: Example of NOx Emissions Reduction Calculations using eGRID | 133 |
| Table 9-3: Annual and OSD Electricity Savings for the Different Programs | 134 |
| Table 9-4: Annual and OSD NOx Emissions Reduction Values for the Different Programs..... | 135 |
| Table 11-1: Listing of Wind Farms Analyzed for Base-year Calculations..... | 175 |
| Table 11-2: Site Information for Brazos Wind Ranch..... | 176 |

| | |
|--|-----|
| Table 11-3: BRAZ_WND_WND1 – Model Coefficients | 177 |
| Table 11-4: BRAZ_WND_WND1 – Comparison of Predicted Power vs. Measured Power..... | 177 |
| Table 11-5: BRAZ_WND_WND1 – Predicted Power Production in 1999 | 178 |
| Table 11-6: BRAZ_WND_WND2 – Model Coefficients | 179 |
| Table 11-7: BRAZ_WND_WND2 – Comparison of Predicted Power vs. Measured Power..... | 180 |
| Table 11-8: BRAZ_WND_WND2 – Predicted Power Production in 1999 | 181 |
| Table 11-9: Site Information for Buffalo Gap 1 | 182 |
| Table 11-10: BUFF_GAP_UNIT1 – Model Coefficients | 183 |
| Table 11-11: BUFF_GAP_UNIT1 – Comparison of Predicted Power vs. Measured Power | 183 |
| Table 11-12: BUFF_GAP_UNIT1 – Predicted Power Production in 1999..... | 184 |
| Table 11-13: Site Information for Callahan Divide Wind Energy Center..... | 185 |
| Table 11-14: CALLAHAN_WND1 – Model Coefficients | 186 |
| Table 11-15: CALLAHAN_WND1 – Comparison of Predicted Power vs. Measured Power | 186 |
| Table 11-16: CALLAHAN_WND1 – Predicted Power Production in 1999..... | 187 |
| Table 11-17: Site Information for Horse Hollow 1 | 188 |
| Table 11-18: H_HOLLOW_WND1 – Model Coefficients | 189 |
| Table 11-19: H_HOLLOW_WND1 – Comparison of Predicted Power vs. Measured Power..... | 189 |
| Table 11-20: H_HOLLOW_WND1 – Predicted Power Production in 1999 | 190 |
| Table 11-21: Site Information for Horse Hollow 2 | 191 |
| Table 11-22: H_HOLLOW2_WIND1 – Model Coefficients | 192 |
| Table 11-23: H_HOLLOW2_WIND1 – Comparison of Predicted Power vs. Measured Power..... | 192 |
| Table 11-24: H_HOLLOW2_WIND1 – Predicted Power Production in 1999 | 193 |
| Table 11-25: Site Information for Horse Hollow 3 | 194 |
| Table 11-26: H_HOLLOW3_WIND1 – Model Coefficients | 195 |
| Table 11-27: H_HOLLOW3_WIND1 – Comparison of Predicted Power vs. Measured Power..... | 195 |
| Table 11-28: H_HOLLOW3_WIND1 – Predicted Power Production in 1999 | 196 |
| Table 11-29: Site Information for Horse Hollow 4 | 197 |
| Table 11-30: H_HOLLOW4_WIND1 – Model Coefficients | 198 |
| Table 11-31: H_HOLLOW4_WIND1 – Comparison of Predicted Power vs. Measured Power..... | 198 |
| Table 11-32: H_HOLLOW4_WIND1 – Predicted Power Production in 1999 | 199 |
| Table 11-33: Site Information for Desert Sky | 200 |
| Table 11-34: INDNENR_INDNENR – Model Coefficients | 201 |
| Table 11-35: INDNENR_INDNENR – Comparison of Predicted Power vs. Measured Power..... | 201 |
| Table 11-36: INDNENR_INDNENR – Predicted Power Production in 1999 | 202 |
| Table 11-37: INDNENR_INDNENR_2 – Model Coefficients | 203 |
| Table 11-38: INDNENR_INDNENR_2 – Comparison of Predicted Power vs. Measured Power..... | 204 |
| Table 11-39: INDNENR_INDNENR_2 – Predicted Power Production in 1999 | 205 |
| Table 11-40: Site Information for King Mountain Wind Ranch (KING_NE)..... | 206 |
| Table 11-41: KING_NE_KINGNE – Model Coefficients | 207 |
| Table 11-42: KING_NE_KINGNE – Comparison of Predicted Power vs. Measured Power | 207 |
| Table 11-43: KING_NE_KINGNE – Predicted Power Production in 1999..... | 208 |
| Table 11-44: Site Information for King Mountain Wind Ranch (KING_NW) | 209 |
| Table 11-45: KING_NW_KINGNW – Model Coefficients..... | 210 |
| Table 11-46: KING_NW_KINGNW – Comparison of Predicted Power vs. Measured Power | 210 |
| Table 11-47: KING_NW_KINGNW – Predicted Power Production in 1999 | 211 |
| Table 11-48: Site Information for King Mountain Wind Ranch (KING_SE) | 212 |
| Table 11-49: KING_SE_KINGSE – Model Coefficients..... | 213 |
| Table 11-50: King Mountain – KING_SE – Comparison of Predicted Power vs. Measured Power..... | 213 |
| Table 11-51: KING_SE_KINGSE - Predicted Power Production in 1999 | 214 |
| Table 11-52: Site Information for King Mountain Wind Ranch (KING_SW) | 215 |
| Table 11-53: KING_SW_KINGSW – Model Coefficients | 216 |
| Table 11-54: KING_SW_KINGSW – Comparison of Predicted Power vs. Measured Power..... | 216 |
| Table 11-55: KING_SW_KINGSW – Predicted Power Production in 1999 | 217 |
| Table 11-56: Site Information for Red Canyon 1 | 218 |
| Table 11-57: RDCANYON_RDCNY1 – Model Coefficients | 219 |
| Table 11-58: RDCANYON_RDCNY1 – Comparison of Predicted Power vs. Measured Power | 219 |

| | |
|--|-----|
| Table 11-59: RDCANYON_RDCNY1 – Predicted Power Production in 1999..... | 220 |
| Table 11-60: Site Information for Sweetwater Wind 2 | 221 |
| Table 11-61: SWEETWN2_WND2 – Model Coefficients | 222 |
| Table 11-62: SWEETWN2_WND2 – Comparison of Predicted Power vs. Measured Power | 222 |
| Table 11-63: SWEETWN2_WND2 – Predicted Power Production in 1999..... | 223 |
| Table 11-64: Site Information for Sweetwater Wind 3 | 224 |
| Table 11-65: SWEETWN3_WND3 – Model Coefficients | 225 |
| Table 11-66: SWEETWN3_WND3 – Comparison of Predicted Power vs. Measured Power | 225 |
| Table 11-67: SWEETWN3_WND3 – Predicted Power Production in 1999..... | 226 |
| Table 11-68: Site Information for Sweetwater Wind 1 | 227 |
| Table 11-69: SWEETWND_WND1 – Model Coefficients..... | 227 |
| Table 11-70: SWEETWND_WND1 – Comparison of Predicted Power vs. Measured Power | 228 |
| Table 11-71: SWEETWND_WND1 – Predicted Power Production in 1999..... | 229 |
| Table 11-72: Site Information for Trent Mesa..... | 230 |
| Table 11-73: TRENT_TRENT – Model Coefficients | 231 |
| Table 11-74: TRENT_TRENT – Comparison of Predicted Power vs. Measured Power..... | 231 |
| Table 11-75: TRENT_TRENT – Predicted Power Production in 1999 | 232 |
| Table 11-76: Site Information for Delaware Mountain Wind Farm..... | 233 |
| Table 11-77: DELAWARE_WIND_NWP – Model Coefficients..... | 234 |
| Table 11-78: DELAWARE_WIND_NWP – Comparison of Predicted Power vs. Measured Power..... | 234 |
| Table 11-79: DELAWARE_WIND_NWP – Predicted Power Production in 1999 | 235 |
| Table 11-80: Site Information for Indian Mesa..... | 236 |
| Table 11-81: INDNNWP_INDNNWP – Model Coefficients | 237 |
| Table 11-82: INDNNWP_INDNNWP – Comparison of Predicted Power vs. Measured Power..... | 237 |
| Table 11-83: INDNNWP_INDNNWP – Predicted Power Production in 1999 | 238 |
| Table 11-84: Site Information for Texas Wind Power Project | 239 |
| Table 11-85: KUNITZ_WIND_LGE – Model Coefficients | 240 |
| Table 11-86: KUNITZ_WIND_LGE – Comparison of Predicted Power vs. Measured Power..... | 240 |
| Table 11-87: KUNITZ_WIND_LGE – Predicted Power Production in 1999..... | 241 |
| Table 11-88: Site Information for Big Spring Wind Power | 242 |
| Table 11-89: SGMTN_SIGNALMT – Model Coefficients | 243 |
| Table 11-90: SGMTN_SIGNALMT – Comparison of Predicted Power vs. Measured Power | 243 |
| Table 11-91: SGMTN_SIGNALMT – Predicted Power Production in 1999..... | 244 |
| Table 11-92: Site Information for Southwest Mesa..... | 245 |
| Table 11-93: SW_MESA_SW_MESA – Model Coefficients..... | 246 |
| Table 11-94: SW_MESA_SW_MESA – Comparison of Predicted Power vs. Measured Power | 246 |
| Table 11-95: SW_MESA_SW_MESA – Predicted Power Production in 1999 | 247 |
| Table 11-96: Site Information for Woodward Mountain Ranch (WOODWRD1) | 248 |
| Table 11-97: WOODWRD1_WOODWRD1 – Model Coefficients..... | 249 |
| Table 11-98: WOODWRD1_WOODWRD1 – Comparison of Predicted Power vs. Measured Power | 249 |
| Table 11-99: WOODWRD1_WOODWRD1 – Predicted Power Production in 1999 | 250 |
| Table 11-100: Site Information for Woodward Mountain Ranch (WOODWRD2) | 251 |
| Table 11-101: WOODWRD2_WOODWRD2 – Model Coefficients..... | 252 |
| Table 11-102: WOODWRD2_WOODWRD2 – Comparison of Predicted Power vs. Measured Power ... | 252 |
| Table 11-103: WOODWRD2_WOODWRD2 – Predicted Power Production in 1999 | 253 |
| Table 11-104: Site Information for Buffalo Gap (BUFF_GAP_UNIT2) | 254 |
| Table 11-105: BUFF_GAP_UNIT2 – Model Coefficients | 255 |
| Table 11-106: BUFF_GAP_UNIT2 – Comparison of Predicted Power vs. Measured Power | 255 |
| Table 11-107: BUFF_GAP_UNIT2 – Predicted Power Production in 1999..... | 256 |
| Table 11-108: Site Information for Capricorn Ridge Wind (CAPRIDGE_CR1)..... | 257 |
| Table 11-109: CAPRIDGE_CR1 – Model Coefficients..... | 258 |
| Table 11-110: CAPRIDGE_CR1 – Comparison of Predicted Power vs. Measured Power | 258 |
| Table 11-111: CAPRIDGE_CR1 – Predicted Power Production in 1999..... | 259 |
| Table 11-112: Site Information for Capricorn Ridge Wind (CAPRIDGE_CR2)..... | 260 |
| Table 11-113: CAPRIDGE_CR2 – Model Coefficients..... | 261 |
| Table 11-114: CAPRIDGE_CR2 – Comparison of Predicted Power vs. Measured Power | 261 |

| | |
|--|-----|
| Table 11-115: CAPRIDGE_CR2 – Predicted Power Production in 1999 | 262 |
| Table 11-116: Site Information for Camp Springs Wind Energy Center (CSEC_CSECG1)..... | 263 |
| Table 11-117: CSEC_CSECG1 – Model Coefficients | 264 |
| Table 11-118: CSEC_CSECG1 – Comparison of Predicted Power vs. Measured Power..... | 264 |
| Table 11-119: CSEC_CSECG1 – Predicted Power Production in 1999 | 265 |
| Table 11-120: Site Information for Lone Star – Mesquite Wind (LNCRK_G83)..... | 266 |
| Table 11-121: LNCRK_G83 – Model Coefficients | 267 |
| Table 11-122: LNCRK_G83 – Comparison of Predicted Power vs. Measured Power | 267 |
| Table 11-123: LNCRK_G83 – Predicted Power Production in 1999..... | 268 |
| Table 11-124: Site Information for Forest Creek Wind Farm (MCDLD_FCW1)..... | 269 |
| Table 11-125: MCDLD_FCW1 – Model Coefficients | 270 |
| Table 11-126: MCDLD_FCW1 – Comparison of Predicted Power vs. Measured Power | 270 |
| Table 11-127: MCDLD_FCW1 – Predicted Power Production in 1999 | 271 |
| Table 11-128: Site Information for Sand Bluff Wind Farm (MCDLD_SBW1)..... | 272 |
| Table 11-129: MCDLD_SBW1 – Model Coefficients | 273 |
| Table 11-130: MCDLD_SBW1 – Comparison of Predicted Power vs. Measured Power | 273 |
| Table 11-131: MCDLD_SBW1 – Predicted Power Production in 1999 | 274 |
| Table 11-132: Site Information for Sweetwater (SWEETWN2_WND24) | 275 |
| Table 11-133: SWEETWN2_WND24 – Model Coefficients | 276 |
| Table 11-134: SWEETWN2_WND24 – Comparison of Predicted Power vs. Measured Power | 276 |
| Table 11-135: SWEETWN2_WND24 – Predicted Power Production in 1999..... | 277 |
| Table 11-136: Site Information for Sweetwater (SWEETWN4_WIND4A) | 278 |
| Table 11-137: SWEETWN4_WIND4A – Model Coefficients | 279 |
| Table 11-138: SWEETWN4_WIND4A – Comparison of Predicted Power vs. Measured Power | 279 |
| Table 11-139: SWEETWN4_WIND4A – Predicted Power Production in 1999..... | 280 |
| Table 11-140: Site Information for Sweetwater (SWEETWN4_WIND4B) | 281 |
| Table 11-141: SWEETWN4_WIND4B – Model Coefficients | 282 |
| Table 11-142: SWEETWN4_WIND4B – Comparison of Predicted Power vs. Measured Power | 282 |
| Table 11-143: SWEETWN4_WIND4B – Predicted Power Production in 1999..... | 283 |

2 INTRODUCTION

2.1 Statement of Work for Calculations of Emissions from Wind and Other Renewables

This summary report covers the Energy Systems Laboratory's work from September 2008 through August 2009. This work is intended to cover the basic work outline included below:

Task 1: Obtain input from public/private stakeholders.

Task 2: Develop a methodology in cooperation with the Texas Commission on Environmental Quality (TCEQ) and the U.S. Environmental Protection Agency (USEPA) for calculating emissions reductions obtained through wind and other renewable energy resources in Texas.

Task 3: Calculate annual, creditable emissions reductions for wind and other renewable energy resources for inclusion in the State SIP.

Task 4: Include emissions reductions by county from wind and renewable energy resources in the ESL's annual report to the TCEQ.

Task 5: Incorporate wind and renewable energy emissions reductions as a component of the ESL's annual *Clean Air Through Energy Efficiency Conference (CATEE)* to facilitate technical transfer.

2.2 Summary of Progress

The progress toward completing each task is provided in the following section and throughout this report.

Task 1: Obtain input from public/private stakeholders.

Legislation passed during the regular session of the 79th Legislature directed the Energy Systems Laboratory to work with the TCEQ to develop a methodology for computing emissions reductions attributable to renewable energy and for the ESL to quantify the emissions reductions attributable to renewables for inclusion in the State Implementation Plan annually. HB 2921 directed the Texas Environmental Research Consortium (TERC) to engage the Texas Engineering Experiment Station for the development of this methodology.

During the period from September 2008 to August 2009, several presentations were done to report the analysis methodology and the results with TCEQ, EPA, TCEQ, and other interested parties. Appendix A shows the slides that were presented in those meetings.

- March 19, 2008 – Presentation to the TCEQ about calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas
- May 2008 – Presentation to the Texas Clean Air Working Group about calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas
- May 22, 2008 – Presentation to the EPA Technical Forum about calculation of NOx emissions reductions from energy efficiency and renewable energy, conference call.
- September 17, 2008 – Presentation to the University of Texas Department of Architecture about calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas

- September 25, 2008 – Presentation to the EPA Blue Skyways conference about calculation of NOx emissions reductions from energy efficiency and renewable energy, Kansas City, MO
- September 30, 2008 – Presentation to the Texas Senate Natural Resources Committee about the calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas

Task 2: Develop a methodology in cooperation with the Texas Commission on Environmental Quality and the U.S. Environmental Protection Agency for calculating emissions reductions obtained through wind and other renewable energy resources in Texas.

This task is composed of the following subtasks:

- Review existing methodologies for calculating emissions reductions from wind energy and other renewable energy systems with USEPA, TCEQ and stakeholders. Develop acceptable methodologies for wind and renewables.
- Determine how to implement methodologies for Texas, including accounting of current installations, future sites, degradation, discounting/uncertainty, grid constraints, etc.
- Review methodologies for verifying wind energy production and renewable energy installations with TCEQ, USEPA and stakeholders. Develop acceptable methodologies for verifying installations, including documentation, EPA QAPP, etc.
- Develop draft State Guidelines for the TCEQ for EE/RE SIP credits.

Task 3: Calculate annual, creditable emissions reductions for wind and other renewable energy resources for inclusion in the State SIP.

This task is composed of the following subtasks:

- Calculate annual emissions from wind and other renewable energy projects.
- Verify annual installations of wind and renewable energy systems in Texas.
- Verify ERCOT historical data for wind production and other renewables.

Task 4: Include emissions reductions by county from wind and renewable energy resources in the ESL's annual report to the TCEQ.

This task is composed of the following subtasks:

- Report annual emissions from wind and other renewable energy projects.
- Report on verification of installations of wind and renewable energy systems in Texas.
- Develop documentation for all methods developed.

Task 5: Incorporate wind and renewable energy emissions reductions as a component of the ESL's annual Clean Air Through Energy Efficiency Conference (CATEE) to facilitate technical transfer.

Additional information regarding the ESL's efforts on Tasks 2, 3, 4 and 5 are listed below and presented in detail in the following sections. This work was performed during the period September 2008 through August 2009.

- Analysis of wind farms using 2007 data;
- Analysis of emissions reduction from wind farms;
- Updates of the degradation analysis to include more wind farms;
- Analysis of other renewables;
- Review of electricity savings and transmission planning study reported by ERCOT;
- Combined Heat and Power projects in Texas; and
- Preliminary reporting of NOx emissions savings in the 2008 Integrated Savings report to the TCEQ.

3 ANALYSIS ON POWER PRODUCTION FROM WIND FARMS USING 2007 DATA

3.1 Introduction

Texas can now take its place as the largest producer of wind energy in the United States. As of April 2009², the capacity of installed wind turbines totals was 8403 MW with another 330 MW under construction. The capacity announced for new projects is 7,631 MW by 2011. Figure 3-1 shows the total installed wind power capacity in Texas and power generation in the ERCOT region from 2001 to December 2008. Figure 3-2 shows the location of the wind farms completed, under construction and announced based on the information from the PUCT.

In this section, an analysis of 2007 data for Sweetwater III wind farm in Nolan County, Texas is provided—including the processing of weather and power generation data, modeling of daily power generation versus daily wind speed for Ozone³ and Non-Ozone season period using the ASHRAE Inverse Model Toolkit (IMT) (Haberl et al. 2003; Kissack et al. 2003), prediction of 1999 wind power generation using developed coefficients from 2007 OSP and Non-OSP models, and the analysis on monthly capacity factors generated using the model.

Following the analysis, a summary of total predicted wind power production in the base year (1999) for all wind farms in the ERCOT region is presented. Then a comparison between the estimated wind power in 1999 and the 1999 Ozone Season Period from the 2007 and 2008 reports and the results from this year's modeling are also included in this section to show the performance the modeling procedure.

An uncertainty analysis was also performed on all the daily regression models and included in this report to show the accuracy of applying the OSP and Non-OSP linear regression models to predict the wind power generation that the wind farms would have had in the base year of 1999. The detailed analysis for each wind farm is provided in the Appendix to this report. The original data used in the analysis is included in the accompanying CD-ROM with this report.




Figure 3-1: Installed Wind Power Capacity and Power Generation in the ERCOT region from 2001 to December 2008

² Wind project information obtained from the Public Utility Commission of Texas (www.puc.state.tx.us) as of 4/23/2009 and the Electric Reliability Council of Texas (ERCOT) as of December 2008.

³ Ozone Season Days are from July 15 to September 15 in this report according to the information from TCEQ.




Figure 3-2: Completed and Announced Wind Projects in Texas by April 2009

3.2 Analysis of the Sweetwater-III Wind Farm Using OSP and NON-OSP Methods

In this section, the Sweetwater III wind farm was used as an example to analyze the applicability of the procedure of modeling wind power production using the 2007 measured wind power data and NOAA wind data, and predicting the electricity power to the selected base year, 1999. Sweetwater III was completed and commenced operation in late December of 2005. It is a 135-megawatt project using 90, 1.5MW GE Wind turbines located in Nolan County, Texas.

3.2.1 Weather Data, Abilene NOAA Site

In Figure 3-3, the hourly wind speed data is shown from NOAA – Abilene Regional Airport (ABI)⁴ for the years 1999 and 2007. Figure 3-4 shows the daily wind speed data from NOAA - ABI for the same two years. The annual average daily wind speed of 1999 and 2007 are 11.3 mph and 10.1 mph, respectively. To differentiate the data used for the OSP and NON-OSP models, two different colors were used in these plots.





Figure 3-3: Hourly NOAA-ABI Wind Speed (1999 and 2007)



⁴ NOAA wind measurements were taken at a height of 33 ft.




Figure 3-4: Daily NOAA-ABI Wind Speed (1999 and 2007)

3.2.2 Wind Power Data

In Figure 3-5, the hourly electricity produced and measured by ERCOT in the Ozone Season Days and the rest of the year from this wind farm is shown in the time series for 2007. Figure 3-6 shows the daily turbine power generation summed from the hourly data. In Figure 3-7, the hourly wind power data was plotted against hourly NOAA wind measurements. The data show scatter and discretization (i.e., patterning) due to the precision of the measurements. In Figure 3-8, the hourly electricity produced by the wind farm except for Ozone Season Days was summed to daily totals and plotted against the daily average wind speed. Figure 3-9 shows the daily electricity produced by the wind farm plotted against the daily average wind speed only for the Ozone Season Days. These figures also show that daily wind power data is suitable for modeling purposes.




Figure 3-5: Measured Hourly Wind Power (2007), Sweetwater III Wind Farm




Figure 3-6: Measured Daily Wind Power (2007), Sweetwater III Wind Farm




Figure 3-7: Hourly Wind Power vs. NOAA-ABI Wind Speed (2007)




Figure 3-8: Daily Wind Power vs. NOAA-ABI Wind Speed for the Non-OSD Period




Figure 3-9: Daily Wind Power vs. NOAA-ABI Wind Speed (2007) for the OSD Period

3.2.3 Modeling of Turbine Power vs. Wind Speed

As shown in the previous sections, daily wind power and daily NOAA wind data are more appropriate for modeling base-year power production than hourly values. Figure 3-8 and Figure 3-9 show the application of a three-parameter change-point linear regression to the average daily wind power output versus average daily NOAA wind speeds for Non-OSD and OSD periods. The summary of the regression model coefficients from the NON-OSP and OSP daily models is listed in Table 3-1 and Table 3-2. These coefficients show that these two daily models are well described with a root-mean-squared error (RMSE) of 316.18 MWh/day (Non-OSP Model) and 257.29 MWh/day (OSP model) for the 2007 data.

In Table 3-3 the predicted monthly electricity production using the 3-parameter, change-point linear daily NON-OSP and OSP models for 2007 is shown to compare against the measured monthly electricity for the same period. The biggest discrepancy of -14.33% between the measured and predicted value happened in July. Figure 3-10 shows the predicted electricity production from the wind farm as a time-series trace for the Ozone Season Period (July 15 to September 15), using the OSP daily model. For most of the days, the predicted power production matches very well the measured values, demonstrating the good performance of this OSP model.

Table 3-1: Non-OSP Model Coefficients

| IMT Coefficients | NOAA NON-OSP Daily Model |
|--------------------------|---------------------------------|
| Ycp (MWh/day) | -537.6169 |
| Left Slope (MWh/mph-day) | 158.6613 |
| RMSE (MWh/day) | 316.1784 |
| R2 | 0.8062 |
| CV-RMSE | 27.8% |

Table 3-2: OSP Model Coefficients

| IMT Coefficients | NOAA OSP Daily Model |
|--------------------------|-----------------------------|
| Ycp (MWh/day) | -547.0923 |
| Left Slope (MWh/mph-day) | 159.6473 |
| RMSE (MWh/day) | 257.28614 |
| R2 | 0.8247 |
| CV-RMSE | 33.7% |

Table 3-3: Predicted Wind Power Using OSP and NON-OSP Daily Models

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | CV-RMSE |
|----------------------------|-------------|--|---|--|-------------------|---------|
| Jan-07 | 23 | 8.97 | 21,625 | 20,367 | 5.81% | 44.43% |
| Feb-07 | 27 | 12.16 | 35,491 | 37,585 | -5.90% | 32.96% |
| Mar-07 | 31 | 11.82 | 39,630 | 41,450 | -4.59% | 23.08% |
| Apr-07 | 30 | 12.85 | 43,693 | 45,049 | -3.10% | 24.27% |
| May-07 | 31 | 9.32 | 28,565 | 29,169 | -2.12% | 26.38% |
| Jun-07 | 30 | 9.53 | 26,009 | 29,209 | -12.30% | 28.42% |
| Jul-07 | 31 | 6.95 | 15,527 | 17,752 | -14.33% | 42.29% |
| Aug-07 | 31 | 9.10 | 30,236 | 28,144 | 6.92% | 28.67% |
| Sep-07 | 30 | 9.04 | 25,849 | 26,906 | -4.09% | 20.26% |
| Oct-07 | 31 | 11.05 | 40,896 | 37,682 | 7.86% | 23.03% |
| Nov-07 | 30 | 10.37 | 34,766 | 33,217 | 4.46% | 20.33% |
| Dec-07 | 31 | 10.51 | 38,877 | 35,011 | 9.94% | 33.97% |
| Total | 356 | 10.14 | 381,164 | 381,540 | -0.10% | 28.39% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 48,038 | 48,397 | -0.75% | 32.07% |




Figure 3-10: Predicted Wind Power in OSP Using NOAA-ABI Wind Speed (2007)

3.2.4 Testing of the OSP and NON-OSP Models

To test the performance of the OSP and NON-OSP daily models, the model coefficients were applied to the 2006 NOAA daily wind speed to predict the daily wind power that would have been generated in 2006. The predicted daily wind power was then summed to monthly to compare against the monthly measurements from ERCOT, as shown in Table 3-4. The test results show that both the OSP and NON-OSP models are sufficiently robust to allow for its use in projecting wind production into other weather base years with the largest observed error of -36.2% in August 2006 for using the OSD model (Figure 3-11) and the largest error of -19.9% in January 2006 for using the Non-OSP model (Figure 3-12). Due to lack of operation information from this wind farm in those periods, specific reasons for the over-prediction of the wind power production in these two months was not provided in this analysis.

Table 3-4: Predicted vs. Measured Wind Power in 2006

| Month | 2006 Predicted MWh/mo Daily Model | 2006 Measured-ERCOT MWh/mo | 2006 Diff. Daily Model |
|-------|-----------------------------------|----------------------------|------------------------|
| Jan | 41,769 | 34,836 | -19.9% |
| Feb | 34,431 | 33,273 | -3.5% |
| Mar | 45,307 | 40,682 | -11.4% |
| Apr | 42,278 | 39,921 | -5.9% |
| May | 43,921 | 44,001 | 0.2% |
| Jun | 28,592 | 26,630 | -7.4% |
| Jul | 33,243 | 28,497 | -16.7% |
| Aug | 26,397 | 19,383 | -36.2% |
| Sep | 28,917 | 29,729 | 2.7% |
| Oct | 35,888 | 38,728 | 7.3% |
| Nov | 34,776 | 42,613 | 18.4% |
| Dec | 33,126 | 37,359 | 11.3% |
| OSD | 55,710 | 46,015 | -21.1% |
| Total | 484,355 | 415,652 | -16.5% |




Figure 3-11: Measured and Predicted Power Production in August 2006 Using the OSP Model




Figure 3-12: Measured and Predicted Power Production in January 2006 Using the Non-OSP Model

3.2.5 Prediction of Wind Power in Base Year 1999

The resultant coefficients (Table 3-1 and Table 3-2) from the 3-parameter models were next applied to the 1999 average daily NOAA-ABI wind speed to predict the electricity the wind farm would have produced in 1999 (Table 3-5). In Table 3-5, the estimated annual and Ozone Season Day (OSD) values are compared against the measured 2007 values to illustrate the error that would result if one were to simply use the 2007 values without normalization. Table 3-5 shows that the estimated annual power production increased 12.4% when compared against 2007. The average daily power production during the Ozone Season Period increased 31.5% as well. This may be because 1999 (an annual average of 11.3 mph) was windier than 2007 (an annual average of 10.1 mph).

Table 3-5: Predicted Power Production in 1999

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|--|--------------------------------------|
| 439,358 | 390,800 |
| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 1,003 | 763 |

3.3 Capacity Factor Analysis

The predicted monthly capacity factors for 2007, using the daily model and the measured monthly capacity factors for the same period, are shown in Figure 3-13. Figure 3-14 shows the predicted capacity factors using the NOAA model from January to December for the periods 1999 through 2007, as well as the measured monthly capacity factor in 2007 and the average monthly capacity factors for these nine years, using the daily NOAA model. In Figure 3-13, the model shows good agreement tracking the measured capacity factor. In comparison, in Figure 3-14, it can be seen that there is more variation in the year to year wind speeds than the uncertainty from the model. Figure 3-15 shows a close up of the wind speeds for 1999 and 2007 for four Texas weather stations.

As seen in Table 3-6, if predicted with the daily model, the annual capacity factors for these years vary from 33.1% to 39.6% with an average of 36.4%. In the Ozone Season Period, the capacity factors are relatively lower than the annual capacity factors. Analysis also shows that the highest electricity production occurs in the spring months (Figure 3-14). It is interesting to note that the variation across the same month of these years can be more than 20% due to the significantly different wind conditions, e.g. March, May and July.




Figure 3-13: Predicted Capacity Factors Using Daily Models (2007)




Figure 3-14: Predicted Capacity Factors Using Daily Models (1999-2007)




Figure 3-15: 1999 and 2007 Monthly Average Wind Speed for Four NOAA Weather Stations

Table 3-6: Summary of Predicted Capacity Factors (1999-2007)

| | NOAA Annual Average Wind Speed (MPH) | Predicted Annual Capacity Factor | Predicted Capacity Factor in Ozone Season Period |
|----------------------------|--------------------------------------|----------------------------------|--|
| 1999 | 11.3 | 38.8% | 31.0% |
| 2000 | 11.5 | 39.6% | 31.6% |
| 2001 | 10.8 | 36.4% | 30.9% |
| 2002 | 11.0 | 37.3% | 33.0% |
| 2003 | 10.8 | 36.3% | 28.0% |
| 2004 | 10.7 | 35.7% | 25.8% |
| 2005 | 10.3 | 33.9% | 27.4% |
| 2006 | 11.0 | 37.1% | 28.7% |
| 2007 | 10.1 | 33.1% | 23.7% |
| Average (1999-2007) | 10.8 | 36.4% | 28.9% |

3.4 Summary of Wind Power Production for All Wind Farms in the Texas ERCOT Region

Table 3-7 shows the summary of the 2007 measured power production for the wind farms that were operating in 2007 in the Texas ERCOT region and the estimated 1999 power production using daily regression models (Appendix B). Table 3-8 shows the monthly average wind speed across four weather stations used in the modeling. As shown in Figure 3-16 and Figure 3-17, the estimated power production in 1999 (10,226,399 MWh/yr) increased about 17% when compared to what was measured in 2007 (8,752,498 MWh/yr). For the Ozone Season Period, the estimated average daily power production in 1999 is 25,151 MWh/day, a 25% increase from that measured in 2007 (20,094 MWh/day). This is because for all the four NOAA weather stations involved in the modeling, 1999 is windier than 2007 (Table 3-8 and Figure 3-15).

Figure 3-18 presents the comparison of the 2007 measured annual power production against the 1999 estimated annual power production for each wind farm. Figure 3-19 shows the difference between the 2007 measured average daily power production and the 1999 estimated average daily power production during the Ozone Season Period for each wind farm. For the wind farms Buffalo Gap 2, Capricorn Ridge Wind 1 & 2, Camp Springs 1, Lone Star Mesquite wind and Sweetwater Wind 4, which started operation halfway through 2006, the power production during the testing period was low and was excluded in the analysis. Therefore, only certain months of data were used in the modeling.

From this analysis it can be concluded that the use of weather normalization procedure for predicting 1999 base year production based on 2007 measured power production is more accurate than simply using the measured 2007 power production as the base year power production. Therefore, it is recommended to the TCEQ that the current discount factor be reduced to take the more accurate modeling into account.

Table 3-9 shows the summary of predicted wind power production in other years (i.e., 2000 and 2002) for all the wind farms in the ERCOT region, using the coefficients from the daily models developed using 2007 measured wind power data and NOAA wind speed data in 2000 and 2002.

Table 3-7: Summary of Power Production for All Wind Farms

| Wind Unit Name | County | NOAA Weather Station | PCA | Capacity (MW) | 2007 Measured (MWh/yr) (ERCOT Original Data) | 1999 Estimated Using Daily Model (MWh/yr) | 2007 OSP Measured (MWh/day) | 1999 OSP Estimated (MWh/day) |
|--------------------|-------------|----------------------|----------|---------------|--|---|-----------------------------|------------------------------|
| BRAZ_WND_WND1 | SCURRY | ABI | AEP-West | 99 | 294,050 | 349,118 | 666 | 869 |
| BRAZ_WND_WND2 | SCURRY | ABI | AEP-West | 61 | 175,598 | 208,329 | 401 | 516 |
| BUFFALO_GAP_1 | TAYLOR | ABI | AEP-West | 120 | 337,836 | 410,441 | 701 | 968 |
| BUFFALO_GAP_2** | TAYLOR | ABI | AEP-West | 233 | 337,056 | 451,147 | 1,194 | 1,665 |
| CALLAHAN_WND1 | TAYLOR | ABI | AEP-West | 114 | 371,710 | 441,790 | 772 | 1,037 |
| CAPRIDGE_CR1** | STERLING | ABI | LCRA | 214.5 | 162,091 | 150,290 | 0 | 0 |
| CAPRIDGE_CR2** | STERLING | ABI | LCRA | 149.5 | 131,787 | 120,091 | 0 | 0 |
| CSEC_CSECG1** | SCURRY | LBB | AEP-West | 135 | 223,456 | 236,787 | 805 | 868 |
| DELAWARE_WIND_NWP* | CULBERSON | GDP | TXU | 30 | 56,977 | 62,053 | 103 | 90 |
| H_HOLLOW_WND1 | TAYLOR | ABI | AEP-West | 213 | 596,024 | 713,071 | 1,143 | 1,573 |
| HHOLLOW2_WND1 | TAYLOR | ABI | AEP-West | 224 | 503,371 | 617,443 | 986 | 1,360 |
| HHOLLOW3_WND_1 | TAYLOR | ABI | AEP-West | 299 | 605,475 | 735,630 | 1,240 | 1,683 |
| HHOLLOW4_WND_1 | TAYLOR | ABI | AEP-West | 115 | 322,912 | 383,301 | 633 | 866 |
| INDNENR_INDNENR | PECOS | FST | AEP-West | 80 | 253,564 | 274,334 | 640 | 638 |
| INDNENR_INDNENR_2 | PECOS | FST | AEP-West | 80 | 230,462 | 260,431 | 586 | 587 |
| INDNNWP_INDNNWP* | PECOS | FST | AEP-West | 82.5 | 219,786 | 246,998 | 575 | 576 |
| KING_NE_KINGNE | UPTON | MAF | AEP-West | 79.3 | 171,480 | 203,501 | 406 | 456 |
| KING_NW_KINGNW | UPTON | MAF | AEP-West | 79.3 | 216,133 | 248,975 | 548 | 605 |
| KING_SE_KINGSE | UPTON | MAF | AEP-West | 40.3 | 85,497 | 101,648 | 208 | 234 |
| KING_SW_KINGSW | UPTON | MAF | AEP-West | 79.3 | 179,261 | 223,819 | 496 | 548 |
| KUNITZ_WIND_LGE* | CULBERSON | GDP | LCRA | 35 | 33,225 | 40,305 | 43 | 38 |
| LNCRK_G83 | SHACKLEFORD | ABI | AEP-West | 200 | 219,275 | 208,662 | 599 | 785 |
| MCDLD_FCW1 | STERLING | SJT | TXU | 125 | 370,842 | 435,455 | 818 | 1,074 |
| MCDLD_SBW1 | STERLING | SJT | TXU | 90 | 139,221 | 149,417 | 354 | 452 |
| RDCANYON_RDCNY1 | BORDEN | ABI | AEP-West | 124 | 286,816 | 334,823 | 665 | 836 |
| SGMTN_SIGNALMT* | HOWARD | MAF | TXU | 41 | 86,343 | 101,909 | 186 | 208 |
| SW_MESA_SW_MESA* | UPTON | MAF | AEP-West | 75 | 203,388 | 232,435 | 539 | 596 |
| SWEETWN2_WND2 | NOLAN | ABI | LCRA | 92 | 296,341 | 357,326 | 644 | 860 |
| SWEETWN2_WND24** | NOLAN | ABI | LCRA | 16 | 20,956 | 30,361 | 87 | 121 |
| SWEETWN3_WND3 | NOLAN | ABI | LCRA | 135 | 381,117 | 457,851 | 763 | 1,003 |
| SWEETWN4_WND4A** | NOLAN | ABI | LCRA | 119 | 180,454 | 199,353 | 628 | 792 |
| SWEETWN4_WND4B** | NOLAN | ABI | LCRA | 105 | 173,772 | 189,153 | 601 | 786 |
| SWEETWN_WND1 | NOLAN | ABI | LCRA | 37.5 | 109,611 | 135,245 | 221 | 299 |
| TRENT_TRENT | NOLAN | ABI | TXU | 150 | 434,417 | 522,564 | 898 | 1,216 |
| WOODWRD1_WOODWRD1* | PECOS | FST | AEP-West | 80 | 176,771 | 202,553 | 487 | 488 |
| WOODWRD2_WOODWRD2* | PECOS | FST | AEP-West | 80 | 165,424 | 189,790 | 458 | 458 |
| TOTAL | | | | 4,032 | 8,752,498 | 10,226,399 | 20,094 | 25,151 |

* Wind farms in *Italic* were built before 9/2001.

** Only certain months of data available for modeling

Table 3-8: Summary of 1999 and 2007 Monthly Average Wind Speed for Four NOAA Weather Stations

| Month | Wind Speed ABI (mph) | | Wind Speed MAF (mph) | | Wind Speed FST (mph) | | Wind Speed GDP (mph) | |
|----------------|----------------------|------|----------------------|------|----------------------|------|----------------------|------|
| | 1999 | 2007 | 1999 | 2007 | 1999 | 2007 | 1999 | 2007 |
| Jan | 11.8 | 9.5 | 10.9 | 9.6 | 12.0 | 9.0 | 21.2 | 22.7 |
| Feb | 12.2 | 12.0 | 11.2 | 11.2 | 11.4 | 11.2 | 22.4 | 23.8 |
| Mar | 12.1 | 11.8 | 11.8 | 10.3 | 11.8 | 11.8 | 21.5 | 16.8 |
| Apr | 13.6 | 12.9 | 13.5 | 12.3 | 13.1 | 13.0 | 20.9 | 22.1 |
| May | 12.4 | 9.3 | 12.8 | 9.7 | 12.6 | 10.0 | 19.9 | 18.6 |
| Jun | 12.7 | 9.5 | 12.8 | 10.0 | 12.0 | 10.2 | 16.3 | 17.1 |
| Jul | 11.7 | 7.0 | 12.3 | 8.0 | 12.3 | 9.3 | 14.8 | 15.1 |
| Aug | 8.4 | 9.1 | 8.0 | 10.0 | 8.8 | 10.5 | 13.5 | 14.2 |
| Sep | 10.4 | 9.0 | 10.1 | 8.9 | 9.9 | 9.8 | 16.8 | 13.8 |
| Oct | 10 | 11.0 | 9.1 | 10.2 | 10.4 | 10.3 | 14.2 | 17.6 |
| Nov | 9.7 | 10.4 | 8.3 | 8.9 | 9.5 | 8.4 | 18.2 | 19.2 |
| Dec | 10.7 | 10.6 | 10.0 | 8.8 | 10.6 | 9.7 | 20.6 | 22.0 |
| Annual Average | 11.3 | 10.2 | 10.9 | 9.8 | 11.2 | 10.3 | 18.3 | 18.6 |
| OSP Average | 9.7 | 8.2 | 9.5 | 9.0 | 10.0 | 10.0 | 13.9 | 14.8 |




Figure 3-16: Comparison of Total 2007 Measured and 1999 Estimated Power Production




Figure 3-17: Comparison of Total 2007 OSD Measured and 1999 OSD Estimated Power Production




Figure 3-18: Comparison of 2007 Measured and 1999 Estimated Power Production for Each Wind Farm




Figure 3-19: Comparison of 2007 OSD Measured and 1999 OSD Estimated Power Production for Each Wind Farm

Table 3-9: Summary of Predicted Wind Power in Base Years (1999, 2000 and 2002) for All Wind Farms in the ERCOT Region

| Wind Unit Name | County | NOAA Weather Station | Capacity (MW) | PCA | Predicted Wind Power in 1999 | | Predicted Wind Power in 2000 | | Predicted Wind Power in 2002 | |
|-------------------|-------------|----------------------|---------------|----------|------------------------------|---------------|------------------------------|---------------|------------------------------|---------------|
| | | | | | Annual (MWh/yr) | OSD (MWh/day) | Annual (MWh/yr) | OSD (MWh/day) | Annual (MWh/yr) | OSD (MWh/day) |
| BRAZ_WND_WND1 | SCURRY | ABI | 99 | AEP-West | 349,118 | 869 | 358,509 | 893 | 336,388 | 925 |
| BRAZ_WND_WND2 | SCURRY | ABI | 61 | AEP-West | 208,329 | 516 | 213,920 | 529 | 200,533 | 548 |
| BUFF_GAP_UNIT1 | TAYLOR | ABI | 120 | AEP-West | 410,441 | 968 | 421,838 | 1,000 | 395,636 | 1,042 |
| BUFF_GAP_UNIT2* | TAYLOR | ABI | 233 | AEP-West | 451,147 | 1,665 | 469,526 | 1,721 | 427,512 | 1,795 |
| CALLAHAN_WND1 | TAYLOR | ABI | 114 | AEP-West | 441,790 | 1,037 | 453,675 | 1,068 | 425,979 | 1,110 |
| CAPRIDGE_CR1* | STERLING | ABI | 215 | LCRA | 150,290 | 0 | 154,281 | 0 | 139,486 | 0 |
| CAPRIDGE_CR2* | STERLING | ABI | 150 | LCRA | 120,091 | 0 | 123,736 | 0 | 110,133 | 0 |
| CSEC_CSEC61* | SCURRY | LBB | 135 | AEP-West | 236,787 | 868 | 240,151 | 858 | 247,761 | 890 |
| DELAWARE_WIND_NWP | CULBERSON | GDP | 30 | TXU | 62,053 | 90 | 62,783 | 86 | 63,677 | 97 |
| H_HOLLOW_WND1 | TAYLOR | ABI | 213 | AEP-West | 713,071 | 1,573 | 732,137 | 1,625 | 687,985 | 1,693 |
| HHOLLOW2_WIND1 | TAYLOR | ABI | 224 | AEP-West | 617,443 | 1,360 | 633,340 | 1,405 | 592,837 | 1,464 |
| HHOLLOW3_WND_1 | TAYLOR | ABI | 299 | AEP-West | 735,630 | 1,683 | 753,803 | 1,735 | 708,251 | 1,805 |
| HHOLLOW4_WND_1 | TAYLOR | ABI | 115 | AEP-West | 383,301 | 866 | 392,408 | 894 | 370,043 | 931 |
| INDNENR_INDNENR | PECOS | FST | 80 | AEP-West | 274,334 | 638 | 282,482 | 772 | 279,722 | 766 |
| INDNENR_INDNENR_2 | PECOS | FST | 80 | AEP-West | 260,431 | 587 | 268,030 | 713 | 265,301 | 707 |
| INDNNWP_INDNNWP | PECOS | FST | 82.5 | AEP-West | 246,998 | 576 | 253,948 | 692 | 251,366 | 687 |
| KING_NE_KINGNE | UPTON | MAF | 79.3 | AEP-West | 203,501 | 456 | 210,175 | 493 | 208,059 | 617 |
| KING_NW_KINGNW | UPTON | MAF | 79.3 | AEP-West | 248,975 | 605 | 256,202 | 647 | 255,188 | 790 |
| KING_SE_KINGSE | UPTON | MAF | 40.3 | AEP-West | 101,648 | 234 | 105,053 | 254 | 104,104 | 318 |
| KING_SW_KINGSW | UPTON | MAF | 79.3 | AEP-West | 223,819 | 548 | 230,546 | 586 | 229,167 | 715 |
| KUNITZ_WIND_LGE | CULBERSON | GDP | 35 | LCRA | 40,305 | 38 | 40,932 | 35 | 41,700 | 41 |
| LNCRK_G83* | SHACKLEFORD | ABI | 200 | AEP-West | 208,662 | 785 | 249,977 | 807 | 220,998 | 836 |
| MCDLD_FCW1 | STERLING | SJT | 125 | TXU | 435,455 | 1,074 | 446,794 | 1,104 | 420,607 | 1,145 |
| MCDLD_SBW1 | STERLING | SJT | 90 | TXU | 149,471 | 452 | 153,788 | 463 | 146,464 | 477 |
| RDCANYON_RDCNY1 | BORDEN | ABI | 124 | AEP-West | 334,823 | 836 | 342,131 | 856 | 323,770 | 883 |
| SGMTN_SIGNALMT | HOWARD | MAF | 41 | TXU | 101,909 | 208 | 104,961 | 225 | 104,039 | 281 |
| SW_MESA_SW_MESA | UPTON | MAF | 75 | AEP-West | 232,435 | 596 | 239,297 | 639 | 239,102 | 782 |
| SWEETWN2_WND2 | NOLAN | ABI | 92 | LCRA | 357,326 | 860 | 366,978 | 886 | 344,509 | 920 |
| SWEETWN2_WND24* | NOLAN | ABI | 16 | LCRA | 30,361 | 121 | 30,273 | 125 | 27,690 | 130 |
| SWEETWN3_WND3 | NOLAN | ABI | 135 | LCRA | 457,851 | 1,003 | 470,039 | 1,032 | 440,571 | 1,069 |
| SWEETWN4_WND4A* | NOLAN | ABI | 119 | LCRA | 199,353 | 792 | 198,978 | 815 | 183,899 | 846 |
| SWEETWN4_WND4B* | NOLAN | ABI | 105 | LCRA | 189,153 | 786 | 188,841 | 808 | 174,855 | 837 |
| SWEETWN_WND1 | NOLAN | ABI | 37.5 | LCRA | 135,245 | 299 | 139,048 | 308 | 129,870 | 320 |
| TRENT_TRENT | NOLAN | ABI | 150 | TXU | 522,564 | 1,216 | 537,474 | 1,254 | 501,788 | 1,304 |
| WOODWRD1_WOODWRD1 | PECOS | FST | 80 | AEP-West | 202,553 | 488 | 208,913 | 597 | 206,618 | 592 |
| WOODWRD2_WOODWRD2 | PECOS | FST | 80 | AEP-West | 189,790 | 458 | 195,671 | 560 | 193,518 | 555 |
| TOTAL | | | 4,032 | | 10,226,401 | 25,153 | 10,530,641 | 26,485 | 9,999,127 | 27,918 |

3.5 Comparison of 1999 Estimated Wind Power in 2007 & 2008 Report and This Report

Compared to what was reported in the 2008 annual report, an increase of 48% on predicted annual wind power in 1999 was observed, from 6,919,353 MWh/yr to 10,226,399 MWh/yr. The average daily wind power in the 1999 OSD period showed a higher increase of 63%, from 15,468 MWh/day to 25,151 MWh/day. The total wind power capacity included in this year's analysis increased from 2,645 MW to 4,032 MWh (a 52% increase), which includes 233 MW from Buffalo Gap 2, 364 MW from Capricorn Ridge Wind, 135 MW from Camp Springs Wind, 200 MW from Lone Star Mesquite Wind, 125 MW from Forest Creek Wind, 90 MW from Sand Bluff Wind, 16 MW from Sweetwater 24, and 224 MW from Sweet Water 4.

Figure 3-20 (a) shows the annual comparison of measured wind power of 2005, 2006 and 2007 for all the wind farms. Table 3-10 shows the average monthly wind speed for the main four weather stations used in the analysis. In general, most of the wind farms operated at the similar output level for these three years. The total annual wind power production in 2006 for most wind farms was a little higher than in 2005 and 2007. This is consistent with the fact that the average annual wind speed from all four NOAA weather stations in 2006 is a little higher than 2005 and 2007 (Table 3-10). The ones showing a big difference were due to fewer operating months in 2005 and 2006, e.g. Callahan, Sweetwater 2, and Horse Hollow 1, which started operations in 2005, and the wind farms which started operation in 2006, e.g. Buffalo Gap 1, Horse Hollow 2, 3 & 4 and Sweetwater 3. Brazos Wind Ranch 1 & 2, due to the metering problem in 2006, showed a significant difference in measured power when compared with the 2005 and 2007 measurements.

Figure 3-20 (b) shows the comparison of measured power of 2005, 2006 and 2007 for the Ozone Season Period. It is noted that for most of the wind farms, the measured average daily wind power in 2006 OSD is lower than that of 2005 and 2007, which is different than the annual trend. As shown in Table 3-12, this

may be due to the opposite wind condition in the OSD period. In 2006, in four NOAA weather stations, three of them were less windy than the 2005 and 2007 in the OSD period. Since the Capricorn Ridge wind farm started operation only after the Ozone season period in 2007, it shows no value in the chart.

Figure 3-20 (a) shows the annual comparison of the estimated power in 1999 using the annual model of 2005 and the OSP and Non-OSP models of 2006 and 2007. Except for the wind farms that have different operation months, e.g. Horse Hollow 1, 2, 3 and 4, and Red Canyon, the predicted wind power in 1999 using the 2005 and 2006 data and model coefficients, is very close to what is predicted using the 2007 models for the majority of the wind farms—which indicates a steady operation of those wind farms. Figure 3-21 (b) shows the comparison of the estimated power in 1999 using the 2005, 2006 and 2007 models for the Ozone Season Period.

Figure 3-22 and Figure 3-23 show that, in general, the variation in the 1999 predicted wind power caused by using measured data from different years is much smaller than the difference between the 2006 and 2007 measured wind power for most of the wind farms with steady operation. This observation confirms the robust performance and importance of the weather normalization procedure. Due to the absence of detailed information on curtailment, maintenance, or other factors, the explanation on the difference in trend among individual wind farms is not included in this work.

Table 3-10: Comparison of Wind Speed of 2005, 2006 and 2007

| Month | Wind Speed ABI (mph) | | | Wind Speed MAF (mph) | | | Wind Speed FST (mph) | | | Wind Speed GDP (mph) | | |
|----------------|----------------------|------|------|----------------------|------|------|----------------------|------|------|----------------------|------|------|
| | 2005 | 2006 | 2007 | 2005 | 2006 | 2007 | 2005 | 2006 | 2007 | 2005 | 2006 | 2007 |
| Jan | 10.3 | 11.9 | 9.5 | 9.7 | 10.6 | 9.6 | 10.2 | 11.1 | 9.0 | 19.1 | 22.4 | 22.7 |
| Feb | 8.9 | 11.1 | 12.0 | 8.9 | 9.9 | 11.2 | 9.2 | 10.2 | 11.2 | 21.5 | 21.2 | 23.8 |
| Mar | 11.5 | 12.6 | 11.8 | 11.1 | 11.9 | 10.3 | 11.1 | 11.7 | 11.8 | 22.3 | 23.7 | 16.8 |
| Apr | 13 | 12.3 | 12.9 | 12.1 | 12.2 | 12.3 | 12.5 | 12.1 | 13.0 | 19.9 | 22.2 | 22.1 |
| May | 11 | 12.3 | 9.3 | 10.8 | 10.8 | 9.7 | 11.7 | 12.3 | 10.0 | 17.3 | 17.1 | 18.6 |
| Jun | 11.9 | 9.8 | 9.5 | 12.1 | 12.1 | 10.0 | 12.4 | 10.9 | 10.2 | 15.7 | 14.8 | 17.1 |
| Jul | 9.9 | 10.1 | 7.0 | 10.4 | 10.4 | 8.0 | 10.6 | 10.6 | 9.3 | 16.0 | 14.1 | 15.1 |
| Aug | 8.3 | 9.2 | 9.1 | 9.2 | 9.2 | 10.0 | 8.5 | 8.9 | 10.5 | 12.9 | 13.6 | 14.2 |
| Sep | 9.3 | 9.5 | 9.0 | 9.7 | 9.7 | 8.9 | 9.2 | 9.5 | 9.8 | 14.5 | 15.5 | 13.8 |
| Oct | 9.3 | 10.7 | 11.0 | 9.3 | 9.3 | 10.2 | 9.7 | 10.5 | 10.3 | 16.8 | 17.1 | 17.6 |
| Nov | 10.3 | 10.9 | 10.4 | 9.4 | 9.4 | 8.9 | 10.3 | 11.0 | 8.4 | 19.8 | 19.7 | 19.2 |
| Dec | 10 | 10.8 | 10.6 | 9.5 | 9.5 | 8.8 | 8.6 | 10.4 | 9.7 | 19.5 | 20.8 | 22.0 |
| Annual Average | 10.3 | 10.9 | 10.2 | 10.2 | 10.2 | 9.8 | 10.3 | 10.8 | 10.3 | 18.0 | 18.5 | 18.6 |
| OSP Average | 9.0 | 9.2 | 8.2 | 9.7 | 8.9 | 9.0 | 9.3 | 9.2 | 10.0 | 14.5 | 14.2 | 15.8 |




Figure 3-20: Comparison of Measured Wind Power of 2005, 2006 and 2007 (Annual and OSD)




Figure 3-21: Comparison of Estimated Power of 1999 using the 2005, 2006 and 2007 Model (Annual and OSD)




Figure 3-22: Comparison of Difference between 1999 Predicted Power and 2006/2007 Measured Power




Figure 3-23: Comparison of Difference between 1999 OSD Predicted Power and 2006/2007 OSD Measured Power

3.6 Uncertainty Analysis on the 2007 Daily Regression Models

One of the advantages of using regression models is that they allow for an uncertainty analysis to be calculated, which can be used to assess the accuracy of the model. This section of the report presents an updated uncertainty analysis for the daily regressions that were applied to the 2007 data.

Assuming that the daily energy production of wind farm data can be related linearly with the daily average wind speed (see Figure 3-24) and expressed as

$$\hat{E}_i = c_o + c_1 V_i \quad (1)$$

Where V is the daily average wind speed, \hat{E} is the daily total energy production, and c_o and c_1 are the resultant coefficients of a linear regression. The subscript i presents any day over the modeling period.




Figure 3-24: Linear Model Presentation of the Daily Wind Power Generation on the Year 2007 for Callahan Wind Farm

The primary purpose of modeling in this analysis is to back-cast the wind power production, or predict the power production in another year that would have occurred if the turbines had been installed and operating. This allows for the evaluation of the NOx reductions during the base-year weather conditions. Unfortunately, any prediction intrinsically contains an uncertainty, which is related to the prediction variance. Thus, the prediction uncertainty, $\sigma^2(\hat{E}_{pred,j})$, assuming no autocorrelation effects in the data used to generate the linear model, can be presented for a particular observation, j , during any time a particular condition is presented as follows:

$$\sigma^2(\hat{E}_{pred,j}) = MSE(\hat{E}_i) \cdot \left[1 + \frac{1}{n} + \frac{(V_j - \bar{V}_n)^2}{\sum_{i=1}^n (V_i - \bar{V}_n)^2} \right] \quad (2)$$

The mean square error, $MSE(\hat{E}_i)$, during the period of the development of the linear model can be computed by:

$$MSE(\hat{E}_i) = \left[\frac{1}{n-(k+1)} \right] \sum_{i=1}^n (E_i - \hat{E}_i)^2 \quad (3)$$

Where n is the number of days in the period used for the developed model, k is the number of regressor variables in the linear model, and \bar{V}_n is the mean value of the velocity on the modeling period.

The last term in the brackets of the equation 2 accounts for the increase in the variance of the energy prediction for any particular observation, j , which is different from the centroid of the modeling data. On the other hand, the second term accounts for the variance in predicting the mean energy predicted for the observation, j .

The total uncertainty for a period of interest, of m days, is then the sum of all the wind energy predicted $\hat{E}_{pred,j}$ in each individual observation.

Assuming that

$$\sum_{j=1}^m \sigma^2(\hat{E}_{pred,j}) = \sigma^2\left(\sum_{j=1}^m (\hat{E}_{pred,j})\right) = \sigma^2(\hat{E}_{pred,total}) \quad (4)$$

And the total prediction variance or uncertainty is obtained through

$$\sigma^2(\hat{E}_{pred,total}) = MSE(\hat{E}_i) \cdot m \cdot \left[1 + \frac{1}{n} + \frac{\sum_{j=1}^m (V_j - \bar{V}_n)^2}{m \sum_{i=1}^n (V_i - \bar{V}_n)^2} \right] \quad (5)$$

Thus, it is observable that the last equation is affected by the number of days that the wind energy will be predicted, the number of days used for the modeling development and the uncertainty due to the distances between the data predicted and the centroid of the modeling data. Therefore, increasing n and m yields an effective relative decrease in the uncertainty—which is expected.

Table 3-11 presents all the statistics parameters for the daily linear models of all the wind farms in the ERCOT region. Table 3-12 shows the uncertainty of applying the linear models to predict the energy generation that they would have had in the year 1999, ranging from 2% to 4.3%. The results indicate that the daily models are reasonably reliable for predicting the performance of the wind farm in the base year within the same range of wind conditions.

Also, the same table includes the uncertainty related to the predicted wind generated for the same wind farms in the 1999 Ozone Season Period using the OSP model, which consider the period of July 15 though Sep 15 – about 63 days. The uncertainty of using OSP models for predicting wind power in the 1999 OSD varies from 1.2% to 13.6% for all the wind farms.

4 DEGRADATION ANALYSIS FOR WIND FARMS

The analysis contained in this section is an update of the work reported in the 2008 annual report in response to a request by the TCEQ to determine what amounts of degradation could be observed in the measured power from Texas wind farms. Currently, the TCEQ uses a very conservative 5% degradation per year for the power output from a wind farm when making future projections from existing wind farms. Accordingly, the TCEQ asked the ESL to evaluate any observed degradation from the measured data for Texas wind farms. To accomplish this, nine wind farms (12 sites) from 2002 to 2007 and two wind farms (Brazos wind ranch and Sweetwater) from 2004 to 2007 were evaluated. In these, nine wind farms were built before January 2002 with a total capacity of 1,010.5 MW and two wind farms started operation from January 2004 with a total capacity of 197.5MW.

In this analysis, a sliding statistical index was established for each site that uses 10th, 25th, 50th, 75th, 90th, and 99th percentiles of the hourly power generation over a 12-month sliding period⁵, as well as mean, minimum and maximum hourly power generation of the same 12-month period. These indices are then displayed using one data symbol for each 12-month slide, beginning from the first 12-month period until the last 12-month period for each of the wind farms, as shown from Figure 4-1 and Figure 4-14. The 90th percentile values were chosen to present the degradation for each wind farm⁶. In addition, our analysis revealed that the maximum hourly power generation over a 12-month period was also a useful index to watch, since this facilitated a way to see if there was major operation change (i.e., shut down of wind turbines) during the studied time period.

Table 4-1 presents the summary of the degradation analysis for the eleven wind farms (14 sites). Of the 14 sites analyzed, ten sites showed an increase when one compares the 90th percentile of whole period to the 90th percentile of the first 12-month period, ranging from 3.5% to 23.7%. The remaining four sites showed a decrease from -3.2% to -18.1%. The weighted average of this increase across all wind farms studied is 8.7% (positive), which indicates that no degradation was observed from the aggregate energy production from these wind farms over the studied operation period.

Table 4-2 and Figure 4-15 show the design capacity, the maximum and minimum of the observed maximum hourly wind power over the sliding 12-month period, and the observed maximum hourly wind power for the last 12-month period for the studied wind farms. It is interesting to note that the observed maximum hourly wind power generation is slightly lower than the design/announced capacity for the majority of the sites. In total, the maximum hourly wind power output during the time period is 1167 MW for eleven wind farms—40.9 MW (3.5%) lower than the design capacity. It also shows that, for some sites, the maximum hourly wind power over the last 12-month period is lower than the maximum hourly wind power measured during the time period. The total decrease from all wind farms is 44.1 MW, which is about 3.8% of total design capacity. Additional operation information will be needed from the owners of the wind farms or ERCOT to explain this observation, such as maintenance records, curtailment, etc.

⁵ To calculate this, the hourly data for the 12-month period is converted into quartiles, and those quartiles are recorded in a table. Then, the oldest month is dropped from the dataset and a new month is added, and the quartiles recalculated and recorded, etc.

⁶ The choice of the 90th percentile is consistent with the recommendation by Abushakra, B., Haberl, J., Claridge, D. 2004. "Overview of Literature on Diversity Factors and Schedules for Energy and Cooling Load Calculations (1093-RP)," *ASHRAE Transactions-Research*, Vol. 110, Pt. 1 (February), pp. 164-176; and in Claridge, D., Abushakra, B., Haberl, J. 2003. "Electricity Diversity Profiles for Energy Simulation of Office Buildings (1093-RP)," *ASHRAE Transactions-Research*, Vol. 110, Pt. 1 (February), pp. 365-377.




Figure 4-1: Sliding 12-month Hourly Wind Power Generation for Indian Mesa




Figure 4-2: Sliding 12-month Hourly Wind Power Generation for Desert Sky




Figure 4-3: Sliding 12-month Hourly Wind Power Generation for King Mountain – NE




Figure 4-4: Sliding 12-month Hourly Wind Power Generation for King Mountain – NW




Figure 4-5: Sliding 12-month Hourly Wind Power Generation for King Mountain – SE.




Figure 4-6: Sliding 12-month Hourly Wind Power Generation for King Mountain – SW




Figure 4-7: Sliding 12-month Hourly Wind Power Generation for Kunitz.




Figure 4-8: Sliding 12-month Hourly Wind Power Generation for Trent Mesa.




Figure 4-9: Sliding 12-month Hourly Wind Power Generation for Southwest Mesa




Figure 4-10: Sliding 12-month Hourly Wind Power Generation for Woodward




Figure 4-11: Sliding 12-month Hourly Wind Power Generation for Big Spring




Figure 4-12: Sliding 12-month Hourly Wind Power Generation for Delaware




Figure 4-13: Sliding 12-month Hourly Wind Power Generation for Brazos Wind Ranch




Figure 4-14: Sliding 12-month Hourly Wind Power Generation for Sweetwater Wind Farm

Table 4-1: Summary of 90th Percentile Hourly Wind Power Analysis for Nine Wind Farms in Texas

| Wind Farm | First 12-mo 90th Percentile Hourly Wind Power | | Average of the Sliding 12-mo 90th Percentile Hourly Wind Power | | Minimum of the Sliding 12-mo 90th Percentile Hourly Wind Power | | Maximum of the Sliding 12-mo 90th Percentile Hourly Wind Power | | No. of Month of Data | Capacity (MW) |
|--------------------------|---|-------|--|-------------------------|--|-------------------------|--|-------------------------|----------------------|---------------|
| | First 12-mo Ending Mo. | MW | MW | % Diff. vs. First 12-mo | MW | % Diff. vs. First 12-mo | MW | % Diff. vs. First 12-mo | | |
| Brazos Wind Ranch | Dec-04 | 127.5 | 131.9 | 3.5% | 125.1 | -1.9% | 137.2 | 7.6% | 48 | 160 |
| Indian Mesa | Dec-02 | 48.0 | 55.2 | 15.1% | 42.1 | -12.2% | 66.0 | 37.5% | 72 | 82.5 |
| Delaware | Dec-02 | 18.6 | 19.2 | 3.5% | 15.6 | -15.8% | 21.5 | 15.7% | 72 | 30 |
| Desert Sky | Dec-02 | 89.0 | 110.1 | 23.7% | 83.1 | -6.7% | 134.4 | 50.9% | 72 | 160 |
| King Mountain-NE | Dec-02 | 41.8 | 45.0 | 7.7% | 36.3 | -13.2% | 52.5 | 25.5% | 72 | 79 |
| King Mountain-NW | Dec-02 | 44.7 | 51.8 | 16.0% | 40.2 | -10.1% | 63.8 | 42.7% | 72 | 79 |
| King Mountain-SE | Dec-02 | 21.6 | 22.5 | 4.1% | 18.4 | -15.0% | 25.8 | 19.1% | 72 | 40 |
| King Mountain-SW | Dec-02 | 41.6 | 46.4 | 11.7% | 38.4 | -7.6% | 53.4 | 28.5% | 72 | 79 |
| Sweetwater Wind 1 | Dec-04 | 34.1 | 33.0 | -3.2% | 32.3 | -5.0% | 34.2 | 0.4% | 48 | 37.5 |
| Trent | Dec-02 | 108.8 | 125.4 | 15.2% | 108.2 | -0.6% | 132.8 | 22.0% | 72 | 150 |
| Woodward | Dec-02 | 85.3 | 90.6 | 6.3% | 80.4 | -5.7% | 100.3 | 17.6% | 72 | 160 |
| Kunitz | Dec-02 | 25.2 | 20.6 | -18.1% | 11.6 | -54.0% | 25.2 | 0.0% | 72 | 35 |
| Big Spring | Dec-02 | 27.2 | 25.6 | -6.1% | 23.9 | -12.0% | 27.2 | 0.0% | 72 | 41 |
| Southwest Mesa | Dec-02 | 51.1 | 48.0 | -5.9% | 38.5 | -24.6% | 55.3 | 8.2% | 72 | 75 |
| Weighted Average: | | | 8.7% | | -9.4% | | 23.2% | | Total: | 1208 |

Table 4-2: Summary of Maximum Hourly Wind Power Analysis for Nine Wind Farms in Texas

| Wind Farm | Design Capacity (A) | Maximum of the Sliding 12-mo Maximum MW-Measured (B) | Minimum of the Sliding 12-mo Maximum MW - Measured (C) | Maximum MW in Last 12-mo - Measured (D) | Difference (A-B) | Difference (B-D) |
|-------------------|---------------------|--|--|---|------------------|------------------|
| Brazos Wind Ranch | 160 | 160.0 | 152.5 | 156.4 | 0.0 | 3.5 |
| Indian Mesa | 82.5 | 78.5 | 63.9 | 71.1 | 4.1 | 7.4 |
| Delaware | 30 | 28.9 | 24.8 | 26.3 | 1.1 | 2.6 |
| Desert Sky | 160 | 159.6 | 105.8 | 159.6 | 0.4 | 0.0 |
| King Mountain-NE | 79 | 76.2 | 49.8 | 75.3 | 2.8 | 0.9 |
| King Mountain-NW | 79 | 77.6 | 56.2 | 77.6 | 1.4 | 0.0 |
| King Mountain-SE | 40 | 40.0 | 27.8 | 40.0 | 0.0 | 0.0 |
| King Mountain-SW | 79 | 75.9 | 51.2 | 71.1 | 3.1 | 4.8 |
| Sweetwater Wind 1 | 37.5 | 37.5 | 37.5 | 37.5 | 0.0 | 0.0 |
| Trent | 150 | 147.6 | 138.8 | 145.1 | 2.4 | 2.5 |
| Woodward | 160 | 142.3 | 104.1 | 138.2 | 17.7 | 4.1 |
| Kunitz | 35 | 35.0 | 23.5 | 23.5 | 0.0 | 11.5 |
| Big Spring | 41 | 37.0 | 30.9 | 30.9 | 4.0 | 6.1 |
| South Mesa | 75 | 71.2 | 53.8 | 70.4 | 3.8 | 0.8 |
| Total: | 1208.0 | 1167.1 | 920.5 | 1123.0 | 40.9 | 44.1 |




Figure 4-15: Design and Measured Maximum Capacity for Nine Wind Farms

5 CALCULATING NOX EMISSIONS REDUCTION FROM WIND POWER

5.1 Calculation of NOx Emissions from Wind Power Using 2007 eGRID

The Energy Systems Laboratory has worked closely with the TCEQ and EPA to develop creditable procedures for calculating NO_x reductions from electricity savings using the EPA's Emissions and Generation Resource Integrated Database (eGRID). Calculating NO_x emissions from wind power to counties within the ERCOT region encounters some major complications. First, electricity can be generated from different primary energy sources which results in very different NO_x emissions. Second, the combination of generation resources used to meet loads may vary during each day or different seasons. Third, electricity is transported over long distances by complex, interconnected transmission and distribution systems. Therefore, the generation source related to electricity usage can be difficult to trace and may occur far from the jurisdiction in which that energy is consumed. Due to the limited availability of public data and the fact that the eGRID database aggregates the emissions on the basis of PCAs⁷, the decision was made by the TCEQ and EPA to calculate and assign emissions, according to the PCA where it was generated. A similar decision has been used in California (Marnay et al. 2002). This assumption does not address the deregulation of generation, but provides a good estimation of the emissions reduction from wind power electric production for the base year of 1999, which is currently in use by the TCEQ using the EPA's eGRID.

The procedure presented in this section calculates annual and peak-day, county-wide NO_x reductions from electricity savings from wind projects implemented in the Power Control Areas in ERCOT listed in the EPA's eGRID. For this purpose, a special version of eGRID⁸ was developed by the EPA for the TCEQ that reflects the 2007 electricity and pollution from electric utilities in ERCOT. The NO_x production for each power plant is provided from the 2007 eGRID database for ten electric utility suppliers. This eGRID matrix was utilized to assign the power plant used by the utility provider, once the utility provider had been chosen for a given county. Figure 5-1 shows a snapshot of the NO_x emission distribution among Texas counties from generating one mega-watt-hour of electricity in the power control area of AEP-West, which was derived from the 2007 Annual eGRID table. For example, the counties marked in red show higher NO_x emissions of above 0.08 lbs/MWh. The counties marked in green were least impacted by the NO_x emissions (less than 0.0005 lbs/MWh) from the power plants assigned to AEP-West. Figure 5-2 and Figure 5-3 show the same county-wide NO_x emissions distribution from TXU and LCRA.

To calculate the NO_x emissions reduction from the wind projects within the ERCOT region, the total MWh wind power for each Power Control Area are summarized in Table 5-1. The assignment of PCA to each wind farm was based on the information provided by the PUCT to ESL in 2005 and 2007 as shown in Table 5-2 and Table 5-3, respectively. The total MWh production in each PCA was input in the corresponding cells in the eGRID table to calculate the total annual and OSD emissions reduction for the entire ERCOT region (Table 5-4 and Table 5-5).

According to the developed models, the total MWh savings in the base year 1999 for the wind farms within the ERCOT region is 10,226,401 MWh and 25,152 MWh/day in the Ozone Season Period. The total NO_x emissions reductions across all the counties amount to 6,051 tons/yr and 15 tons/day for the Ozone Season Period. The distribution of the NO_x emissions reduction in the counties within the ERCOT region is shown in Figure 5-4, Figure 5-5, Figure 5-6, and Figure 5-7. Based on the 2007 eGRID, it is shown that the counties in the gulf coast area will get emissions benefit from the wind farms located in the west. Figure 5-8 shows the average modeled power flows during 2006 for each of the Commercially Significant Constraints from ERCOT⁹. Based on modeled flows, Houston is a significant importer from the 'North Zone' and the 'South Zone,' while the 'South Zone' and the 'Northeast Zone' export significant amounts of power. So, any modifications on the generation patterns in the north area could affect the generation on the

⁷ A Power Control Area (PCA) is defined as one grid region for which one utility controls the dispatch of electricity. Some smaller utilities are embedded in the power control areas of larger utilities. The corresponding PCA for wind farms was obtained from PUCT.

⁸ This 2007 eGRID table for Texas was provided by Art Diem of the USEPA and includes emissions values for AEP, Austin Energy, Brownsville Public Utility, LCRA, Reliant, San Antonio Public Service, South Texas Coop, TMPP, TNMP, and TXU.

⁹ ERCOT, "2006 State of the Market Report for the ERCOT Wholesale Electricity Markets" Available at: http://www.puc.state.tx.us/WMO/documents/annual_reports/2006annualreport.pdf

South area (Gulf coast) which has a larger emissions rate than the northern counterpart, thus giving a major emissions reduction impact. Therefore, we believe the distribution of electricity is adequately reflected in the current choice of the PCAs continued in the 2007 eGRID.

5.2 Updated Version of eGRID

The ESL has been working with the EPA and the TCEQ on a new version of eGRID for all ERCOT counties in Texas. This new version of eGRID was developed based on the ERCOT congestion management zones (Figure 5-8).¹⁰ It uses a simplified dispatch approach of the ERCOT grid to estimate NOx emission reductions across the ERCOT region in Texas. The simplified dispatch method reduces the generation from plants that are expected to be operating in future years and reduces NOx emissions at these plants by the expected reduction in output emission rate of these plants. This method does not use an electric system planning model, or an electric system dispatch model, which could more fully reflect some of the dynamics of the electricity system than is presented here.

Based on the reduction targets identified by the legislature for investor owned utilities, this study assigns the electric generation reductions at specific fossil fuel fired plants that currently exist and to plants that are scheduled to be online in the years examined in this analysis, 2010 and 2015. This method assigns the potential energy savings targets of each affected investor owned utility in ERCOT, which are then applied to the respective congestion management (CM) zones based on the proportion of the utility's load in each CM zone. Then it applies the energy savings to generation from each CM zone based on year 2007 generation and power flows across these zones. Next, it applies the CM zone specific reductions in generation to each plant within the CM zone based on the amount of the plant's generation that could be affected by energy efficiency measures, which is derived from a function of the plant's capacity factor. Then a plant specific output NOx emission rate is applied to the expected reduction in electric generation. These emission rates are based on year 2005 EPA's eGRID emission rates and TCEQ's most current baseline emissions inventory for year 2005 and for projected year 2018. Finally the plant specific emission reduction is summed to the county level. The potential emissions reductions are presented for each of the investor owned utilities and in aggregate for all five ERCOT utilities under the year 2010 and 2015 energy savings scenarios (Table 5-6 and Table 5-7).

As the TCEQ moves the base year to more recent years, this updated version of eGRID representing the current Texas market may be used to estimate the emissions reduction from wind power in the next year's report.

¹⁰ Estimation of Annual Reductions of NOx Emissions in ERCOT for the HB3693 Electricity Savings Goal, The United States Environmental Protection Agency and the Energy Systems Lab, December 2008




Figure 5-1: NOx Emissions (lbs/MWh) from PCA-AEP West in the 2007 Annual eGRID




Figure 5-2: NOx Emissions (lbs/MWh) from PCA-LCRA in the 2007 Annual eGRID




Figure 5-3: NOx Emissions (lbs/MWh) from PCA-TXU in the 2007 Annual eGRID

Table 5-1: Wind Power Production Assigned to Each PCA in the ERCOT Region

| PCA | Annual Wind Power (MWh/yr) | OSD Wind Power (MWh/day) |
|----------|----------------------------|--------------------------|
| AEP-WEST | 7,275,027 | 18,213 |
| TXU | 1,271,399 | 3,041 |
| LCRA | 1,679,976 | 3,899 |
| Total | 10,226,401 | 25,153 |

Table 5-2: Wind Farm Information from the PUCT – 2005

Source: <http://www.puc.state.tx.us/electric/maps/qentable.pdf>

| Map No. | Company | Facility | City (County) | Resource | Capacity (MW) | Date in Service | Interconnection | Region | PCA |
|---------|------------------------------------|--------------------------------|---------------------------|----------|---------------|-----------------|-----------------|--------|----------|
| 7 | York Research | Big Spring Wind Power | Big Spring (Howard) | Wind | 34 | Feb-99 | TXU | ERCOT | TXU |
| 8 | FPL Energy | Southwest Mesa Wind Project | McCamey (Upton) | Wind | 75 | Jun-99 | WTU | ERCOT | AEP-West |
| 9 | American National Wind Power | Delaware Mountain Wind Farm | Delaware Mountains (Wind) | Wind | 30 | Jun-99 | TXU | ERCOT | TXU |
| 10 | York Research | Big Spring Wind Power | Big Spring (Howard) | Wind | 6.6 | Jun-99 | TXU | ERCOT | TXU |
| 33 | Orion Energy/American National Win | Indian Mesa I | (Pecos) | Wind | 82.5 | Jun-01 | WTU | ERCOT | AEP-West |
| 35 | FPL/Cielo/TXU | Woodward Mountain Ranch | McCamey (Pecos) | Wind | 160 | Jul-01 | WTU | ERCOT | AEP-West |
| 44 | AEP | Trent Mesa | Trent Mesa (Nolan) | Wind | 150 | Nov-01 | TXU | ERCOT | TXU |
| 45 | AEP | Desert Sky (Indian Mesa II) | Iraan (Pecos) | Wind | 160 | Dec-01 | WTU | ERCOT | AEP-West |
| 46 | FPL/Cielo | King Mountain Wind Ranch | McCamey (Upton) | Wind | 278 | Dec-01 | WTU | ERCOT | AEP-West |
| 65 | Cielo/Orion/Green Mountain | Brazos Wind Ranch | Fluvana (Scurry) | Wind | 160 | Dec-03 | ONCOR | ERCOT | AEP-West |
| 66 | DKR/Babcock&Brown/Catamount | Sweetwater 1 | Sweetwater (Nolan) | Wind | 37.5 | Dec-03 | LCRA | ERCOT | LCRA |
| 75 | FPL Energy | Callahan Divide Wind Energy Cr | Abilene (Taylor) | Wind | 114 | Feb-05 | AEP-TNC | ERCOT | AEP-West |
| Map No. | Company | Facility | City (County) | Resource | Capacity (MW) | Date in Service | Interconnection | Region | PCA |
| 79 | Clipper Windpower Dev. | Silver Star Phase I | (Eastland) | Wind | 60 | 2005 | 5-Jun | ERCOT | TXU |
| 80 | DKRW Development | Sweetwater II | Sweetwater (Nolan) | Wind | 89 | 2005 | 5-Dec | ERCOT | TXU |
| 81 | AES Corporation | Buffalo Gap | Abilene (Taylor) | Wind | 120 | 1Q-05 | 4Q-05 | ERCOT | AEP-West |
| 84 | Orion Energy | | (Culberson) | Wind | 175 | NA | 6-Dec | ERCOT | TXU |

| Capacity (MW) | PCA (1998 Designation) | Percent of Total Capacity |
|---------------|------------------------|---------------------------|
| 1149.5 | AEP-West | 66.38% |
| 37.5 | LCRA | 2.17% |
| 544.6 | TXU | 31.45% |
| 1731.6 | TOTAL | 100.00% |

Table 5-3: Wind Farm Information from the PUCT – 2007

| Company | Facility | City | County | Resource | Capacity (MW) | Status | In Service | Interconnection | Region |
|---|--------------------------------------|------------|-------------|----------|---------------|-----------|------------|-----------------|--------|
| LG&E | Texas Wind Power Project | Culberson | | Wind | 35 | Completed | Oct-95 | TXU, LCRA | ERCOT |
| York Research | Big Spring Wind Power | Big Spring | Howard | Wind | 34 | Completed | Feb-99 | TU | ERCOT |
| York Research | Big Spring Wind Power | Big Spring | Howard | Wind | 7 | Completed | Jun-99 | TXU | ERCOT |
| FPL Energy | Southwest Mesa Wind Project | McCarney | Upton | Wind | 75 | Completed | Jun-99 | WTU | ERCOT |
| American National Wind Power | Delaware Mountain Wind Farm | Culberson | | Wind | 30 | Completed | Jun-99 | TXU | ERCOT |
| Cielo/EI Paso Electric | Hueco Mountain Wind Ranch | Hueco Mtn. | El Paso | Wind | 1 | Completed | Apr-01 | EPE | WSCC |
| Orion Energy/American National Wind Power | Indian Mesa | | Pecos | Wind | 83 | Completed | Jun-01 | WTU | ERCOT |
| FPL/Cielo/TXU | Woodward Mountain Ranch | McCarney | Pecos | Wind | 160 | Completed | Jul-01 | WTU | ERCOT |
| AEP | Trent Mesa | Sweetwater | Nolan | Wind | 150 | Completed | Nov-01 | TXU | ERCOT |
| AEP | Desert Sky (Indian Mesa II) | Iraan | Pecos | Wind | 160 | Completed | Dec-01 | WTU | ERCOT |
| FPL/Cielo | King Mountain Wind Ranch | McCarney | Upton | Wind | 278 | Completed | Dec-01 | WTU | ERCOT |
| Shell Wind Energy | Llano Estacado Wind Ranch | White Deer | Carson | Wind | 79 | Completed | Jan-02 | SPS | SPP |
| Cielo/Orion/Green Mountain | Brazos Wind Ranch | Fluvana | Scurry | Wind | 160 | Completed | Dec-03 | ONCOR | ERCOT |
| DKR Development | Sweetwater Wind 1 | Sweetwater | Nolan | Wind | 38 | Completed | Dec-03 | LCRA | ERCOT |
| Aeolus Wind | | | Hansford | Wind | 3 | Completed | 2003 | SPS | SPP |
| DKRW Development | Sweetwater Wind 2 | Sweetwater | Nolan | Wind | 92 | Completed | Feb-05 | LCRA | ERCOT |
| FPL Energy | Callahan Divide Wind Energy Center | Abilene | Taylor | Wind | 114 | Completed | Feb-05 | AEP/TNC | ERCOT |
| AES Seawest | Buffalo Gap 1 | Abilene | Taylor | Wind | 120 | Completed | Sep-05 | AEP/TNC | ERCOT |
| FPL Energy | Horse Hollow Phase 1 | Abilene | Taylor | Wind | 213 | Completed | Oct-05 | AEP/TNC | ERCOT |
| DKRW Energy | Sweetwater Wind 3 (Cottonwood Creek) | Sweetwater | Nolan | Wind | 135 | Completed | Dec-05 | LCRA | ERCOT |
| FPL Energy | Horse Hollow Phase 2 | Abilene | Taylor | Wind | 224 | Completed | May-06 | AEP/TNC | ERCOT |
| FPL Energy | Red Canyon 1 | | Borden | Wind | 84 | Completed | May-06 | BEPC | ERCOT |
| FPL Energy | Horse Hollow Phase 3 | Abilene | Taylor | Wind | 299 | Completed | Sep-06 | AEP/TNC | ERCOT |
| Airtricity | Forest Creek Wind Farm | | Sterling | Wind | 124 | Completed | Dec-06 | TXU-ED | ERCOT |
| Airtricity | Sand Bluff Wind Farm | | Sterling | Wind | 90 | Completed | Dec-06 | TXU-ED | ERCOT |
| Deere & Company | JD Wind 1, 2, 3, 5 | Gruver | Hansford | Wind | 40 | Completed | Dec-06 | SPS | SPP |
| Edison Mission Group | Wildorado Wind Ranch | Wildorado | Oldham | Wind | 161 | Completed | Apr-07 | SPS | SPP |
| DKRW/BabcockBrown | Sweetwater Wind 4 (Cottonwood Creek) | Sweetwater | Nolan | Wind | 300 | Completed | May-07 | LCRA | ERCOT |
| Invenergy | Camp Springs Wind Energy Center | | Scurry | Wind | 130 | Completed | Jul-07 | Onkor | ERCOT |
| AES | Buffalo Gap 2 (Cirello 1) | Abilene | Taylor | Wind | 233 | Completed | Aug-07 | AEP/TNC | ERCOT |
| FPL Energy | Capricorn Ridge Wind | | Sterling | Wind | 364 | Completed | Sep-07 | LCRA | ERCOT |
| DKRW/BabcockBrown | Sweetwater Wind 5 | Sweetwater | Nolan | Wind | 80 | Completed | Dec-07 | LCRA | ERCOT |
| Renewable Energy Systems | Whirwind | Floydada | Floyd | Wind | 60 | Completed | Dec-07 | AEP | ERCOT |
| Gemesa Energy | Barton Chapel Wind 1 | | Jack | Wind | 120 | Completed | Dec-07 | Onkor | ERCOT |
| Enel North America/WKN USA | Snyder Wind Project | Snyder | Scurry | Wind | 63 | Completed | Dec-07 | BCEC | ERCOT |
| Horizon Wind Energy | Lone Star - Mesquite Wind | | Shackelford | Wind | 200 | Completed | Dec-07 | Onkor | ERCOT |
| Invenergy | Stanton Wind Energy | | Martin | Wind | 101 | Completed | Jan-08 | Onkor | ERCOT |
| Airtricity | Champion Wind Farm | | Scurry | Wind | 126 | Completed | Jan-08 | Onkor | ERCOT |
| Airtricity | Roscoe Wind Farm 1 | | Scurry | Wind | 209 | Completed | Jan-08 | Onkor | ERCOT |
| BP/Clipper Windpower | Silver Star Phase I | | Erath | Wind | 60 | Completed | Mar-08 | Onkor | ERCOT |
| Edison Mission Group | Goat Mountain Wind Ranch | | Sterling | Wind | 70 | Completed | Mar-08 | LCRA | ERCOT |
| AES | Buffalo Gap 3 | | Taylor | Wind | 138 | Completed | Apr-08 | AEP/TNC | ERCOT |
| FPL Energy | Capricorn Ridge Wind exp. | | Sterling | Wind | 298 | Completed | May-08 | LCRA | ERCOT |
| Horizon Wind Energy | Lone Star - Post Oak Wind | | Shackelford | Wind | 200 | Completed | May-08 | Onkor | ERCOT |
| Invenergy | McAdoo Wind Energy | | Dickens | Wind | 150 | Completed | May-08 | AEP | ERCOT |
| Invenergy | Camp Springs Energy expansion | | Scurry | Wind | 120 | Completed | Jun-08 | Onkor | ERCOT |
| Airtricity | Panther Creek | | Howard | Wind | 143 | Completed | Jul-08 | Onkor | ERCOT |
| Duke Energy | Ocotillo Windpower 1 | | Howard | Wind | 59 | Completed | Aug-08 | Onkor | ERCOT |
| BP Alt. Energy - NRG | Sherbino Mesa Wind Farm | | Pecos | Wind | 150 | Completed | Sep-08 | ERCOT | |
| Babcock & Brown | South Trent Wind Farm | | Taylor | Wind | 98 | Completed | Oct-08 | Onkor | ERCOT |
| FPL Energy | Wolf Ridge Windfarm | | Cooke | Wind | 113 | Completed | Oct-08 | ERCOT | |
| Babcock & Brown | Gulf Wind 1 | | Kenedy | Wind | 283 | Completed | Nov-08 | AEP/TCC | ERCOT |
| E.On Climate & Renewables | Inadate | | Nolan | Wind | 197 | Completed | Nov-08 | | ERCOT |
| E.On Climate & Renewables | Panther Creek 2 | | Howard | Wind | 115 | Completed | Nov-08 | | ERCOT |
| E.On Climate & Renewables | Pyron | | Scurry | Wind | 249 | Completed | Nov-08 | | ERCOT |
| Eurus Energy Holdings | Bull Creek Wind Plant | | Borden | Wind | 180 | Completed | Nov-08 | | ERCOT |
| Invenergy | Turkey Track Energy Center | | Nolan | Wind | 170 | Completed | Nov-08 | | ERCOT |
| NRG Padoma Wind | Elbow Creek Wind | | Howard | Wind | 117 | Completed | Nov-08 | Onkor | ERCOT |
| PPM Energy | Penascal Wind Farm | | Kenedy | Wind | 202 | Completed | Nov-08 | | ERCOT |
| Renewable Energy Systems | Hackberry Wind Farm | | Shackelford | Wind | 165 | Completed | Nov-08 | | ERCOT |




Figure 5-4: 1999 Predicted Annual NOx Reductions from Wind Power in Texas Map




Figure 5-5: 1999 Predicted OSD NOx Reductions from Wind Power in Texas Map




Figure 5-6: 1999 Predicted Annual NOx Reductions from Wind Power




Figure 5-7: 1999 Predicted OSD NOx Reductions from Wind Power




Figure 5-8: Average Modeled Flows on Commercially Significant Constraints for 2006

6 OTHER RENEWABLE SOURCES

Renewable energy projects throughout the state of Texas were found to determine NOx emissions reduction. Five specific categories were determined to base the search in—including solar photovoltaic, solar thermal, geothermal, hydroelectric, and landfill gas-fired power plants. The criterion for each project to be included in the data collection was that the installation date was after the year 2000 and the project was installed within the state of Texas. However, projects installed before the year 2000 were also included in order to provide a complete record.

6.1 Implementation

As previously reported, this is an updated version of the earlier report published in July 2007. Many newly-located and renewable-energy projects are included in this section in the five main categories.

The information was collected using the following modes:

- Information from the internet: websites of environmental agencies like ERCOT, EIA, NREL which publish information that is available to the general public;
- Information from the websites of manufacturers, distributors, consultants related with renewable energy products; and
- Some information was collected by personally emailing individuals, who were either manufacturers, distributors, or consultants.

It was essentially the same methodology/protocol followed for data collection used in the previous report. In most cases, the information obtained was very limited. They did not contain some system specification data. Therefore, we contacted manufacturers, consultants, and distributors or officers in environmental agencies to collect more information; their responses are also included. Table 6-1 shows the number of new projects in each category that are added in this report.

6.2 Renewable Energy Projects

6.2.1 Solar Photovoltaic

From the website of “Soltrex” details of about 16 new solar photo voltaic projects were obtained. The website of Soltrex is the main source of information since it provides all detailed specifications of each of the projects monitored. Some other websites like SECO seem to provide system specification data, they turn out to be links to the Soltrex website in the end.

The website of the company “Meridian Solar” reports about 56 new projects. This website provides only information like capacity and location

Apart from these sources another website of a company, ”Standard Renewable Energy” reports about 47 projects installed in the state of Texas with only the important details like capacity and location . The website of “South West Photo-Voltaic” reported one new project

However, the information provided in the website of Soltrex and Standard Renewable energy was limited and insufficient for emission reduction calculations.

The number of projects per county is presented in Figure 6-1. A summary of the different projects and their outputs of ESL’s emissions calculator (*eCALC*) can be found in Table 6-2 and Table 6-3, respectively. The annual and OSD electric savings per county, due to these projects, are presented in Figure 6-6 and Figure 6-7, and the corresponding emissions reductions are shown in Figure 6-8 and Figure 6-9.

6.2.2 Solar Thermal

Apart from the projects reported by Techsun solar, which were included in the previous report, we were able to locate six more projects for this year's report. The source of information is a solar heating equipment manufacturer – “Alternative Power Solutions.” Their website provided some case studies which are included in this information.

The number of projects collected per county is presented in Figure 6-2. A summary of the different projects and their outputs from eCALC can be found in Table 6-4 and Table 6-5, respectively. The annual and OSD electric savings per county, due to these projects, are presented in Figure 6-10 and Figure 6-11, and the respective emission reductions are shown in Figure 6-12 and Figure 6-13. The special projects for parabolic solar concentrators are listed in Table 6-6.

6.2.3 Hydroelectric

Apart from the 45 projects reported in the previous report no new projects were identified as far as Hydro electric power plants are concerned. No new hydro electric projects were installed in the state of Texas after the year 2000.

All of the hydroelectric projects located, and their information, are presented in Table 6-7. A Texas map, which shows the location of the different projects per county, is located in Figure 6-3.

6.2.4 Geothermal

Information provided by “Image Engineering Group,” a consultant group, details about 120 different geothermal heat pump projects installed in the state of Texas in different schools and organizations. They have been listed in Table 6-8. However, in-depth details were not available.

Mr. Don Penn, of Image Engineering Group was contacted via email for additional details, through a reference from Dr. Greg Tinkler, a consulting engineer with RLB Consulting Engineers. Mr. Penn kindly responded to our queries in time and provided us with a detailed spread sheet listing out all the projects done by the company and included details like capacity, location area covered etc. These additional details have been updated for about 75 projects reported in the last report. The spread sheet also listed some 24 new projects and the details which have been included in this updated report.

Also, FHP manufacturing, a geothermal heat pump manufacturer, provides information about some 50 different projects installed in the state of Texas—this information was also included in the report.

The resulting information can be found in Table 6-8 with a corresponding map in Figure 6-4 which shows the number of projects in different counties.

6.2.5 Landfill Gas-Fired Power Plants

The Environmental Protection Agency (EPA) has a project data base for Landfill Methane Outreach Program (LMOP). This formed the main source of information for the previous report. We were unable to locate any new projects for this report.

The implemented, candidate and potential projects are listed in Table 6-9, Table 6-10, and Table 6-11, respectively. Figure 6-5 shows the location of these operational projects implemented throughout Texas.

6.3 Results

We were able to considerably increase the number of renewable energy projects identified in the state of Texas. Some 141 new projects were identified, located, and included in this report (which were not included in the 2008 annual report)—the details are presented in Table 6-1. This report also updates the details of about 75 geothermal projects, which were reported in the previous report. The emission reduction calculations presented in the previous report were also included in this report.

Table 6-1: New Projects Added in This Report

| Renewable Energy Source | No of New Projects identified and reported in May 2009 |
|-------------------------|--|
| Solar Photo-Voltaic | 114 |
| Solar Thermal | 3 |
| Land fill gas | 0 |
| Hydro-Electric | 0 |
| Geothermal | 24 |

6.4 References

Useful information was obtained from the following websites:

- <http://www.soltrex.com/systems.cfm?state=tx>
- http://www.meridiansolar.com/portfolio_commercial/commerical.html
- <http://www.sre3.com/projectGallery.jsp>
- <http://www.sre3.com/index.jsp>
- <http://apowersolutions.com/pdf/Commercial%20Solar%20Pool%20Heating%20Case%20Studies.pdf>
- <http://www.eia.doe.gov/cneaf/electricity/page/eia860.html>
- <http://www.iegltd.com/project.refer.geo.master.pdf>
- <http://www.iegltd.com/html/information.html>
- <http://geoheat.oit.edu/state/tx/tx.htm>
- http://data.memberclicks.com/site/treia/Maria_RichardsSchools.pdf
- <http://www.southwestpv.com/SolarSite/SolarSiteMain.aspx>
- <http://www.fhp-mfg.com/>

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity (kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|--|-----------------|----------|------------------|--------|-----------------------------|---------------|-------------------|-------|---------------------|
| 1 | Giddings Middle School | Giddings, TX | Lee | Bastrop | Jun-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 2 | La Grange Intermediate School | La Grange, TX | Fayette | Bastrop | May-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 3 | Schulenburg Elementary School | Schulenburg, TX | Fayette | Bastrop | Jun-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 4 | Smithville Junior High School | Smithville, TX | Bastrop | Bastrop | Jun-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 5 | Bastrop Intermediate School | Bastrop, TX | Bastrop | Bastrop | May-07 | Sharp Electronics NE-170-U1 | 1.02 | 84 | 35 | 180 |
| 6 | Eagle Pass High School - CC Winn Campus | Eagle Pass, TX | Maverick | Bexar | Feb-02 | Siemens SP 75 | 0.9 | 81.84 | 25 | 180 |
| 7 | East Central ISD | San Antonio, TX | Bexar | Bexar | Nov-03 | Shell SP-140-PC | 1.12 | 113.92 | 60 | 180 |
| 8 | James Madison High School | San Antonio, TX | Bexar | Bexar | Feb-02 | Siemens SP 75 | 0.9 | 81.84 | 25 | 180 |
| 9 | John Jay High School | San Antonio, TX | Bexar | Bexar | Dec-01 | Siemens SP 75 | 0.9 | 81.84 | 60 | 180 |
| 10 | Roosevelt High School | San Antonio, TX | Bexar | Bexar | Mar-04 | Shell SP140PC | 1.12 | 113.92 | 30 | 180 |
| 11 | Utopia ISD | Utopia, TX | Uvalde | Bexar | Jun-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 12 | City Public Services of San Antonio, Northside | San Antonio, TX | Bexar | Bexar | Jul-02 | MSX-120 | 17.28 | 1699.2 | 30* | 180* |
| 13 | Del Rio High School | Del Rio, TX | Kinney | Bexar | Jul-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 25 | 180 |
| 14 | Kendall Elementary School | Boerne, TX | Kendall | Bexar | Apr-07 | Sharp Electronics NE-170-U2 | 1.02 | 84 | 35 | 180 |
| 15 | Uvalde Junior High School | Uvalde, TX | Uvalde | Bexar | Jul-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 25 | 180 |
| 16 | City Public Services Primary Control Center | San Antonio, TX | Bexar | Bexar | Jun-04 | BP MSX-120 | 17.28 | 1699.2 | 30* | N/A |
| 17 | Institute of Texan Cultures | San Antonio, TX | Bexar | Bexar | N/A | N/A | 15 | N/A | N/A | N/A |
| 18 | Ft. Sam Houston Bldg. 1350 | San Antonio, TX | Bexar | Bexar | Apr-06 | N/A | 181 | N/A | N/A | N/A |
| 19 | Bexar County Jail Annex | San Antonio, TX | Bexar | Bexar | N/A | N/A | N/A | N/A | N/A | N/A |
| 20 | Alvin High School | Alvin, TX | Brazoria | Brazoria | Nov-03 | Shell SP-140-PC | 1.12 | 113.92 | 30 | 180 |
| 21 | El Campo Middle School | El Campo, TX | Wharton | Brazoria | Jul-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 25 | 180 |
| 22 | Bluebonnet Elementary School | Lockhart, TX | Caldwell | Caldwell | Jul-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 23 | Flatonia Elementary School | Flatonia, TX | Gonzales | Caldwell | May-07 | Sharp Electronics NE-170-U1 | 1.02 | 84 | 35 | 180 |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity (kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|---|-------------------|------------|------------------|--------|-----------------------------|---------------|-------------------|-------|---------------------|
| 24 | Waelder ISD | Waelder, TX | Gonzales | Caldwell | May-07 | Sharp Electronics NE-170-U5 | 1.02 | 64.08 | 35 | 180 |
| 25 | Blue Ridge ISD | Blue Ridge, TX | Collin | Collin | Oct-03 | Siemens SP 75 | 0.9 | 81.84 | 25 | 180 |
| 26 | McKinney Green Building | McKinney, TX | Collin | Collin | Mar-06 | ASE-300-DG-FT | 45 | 3749.76 | 30* | N/A |
| 27 | Canyon High School | New Braunfels, TX | Comal | Comal | Feb-04 | Shell SP140PC | 1.12 | 113.92 | 20 | 230 |
| 28 | Dallas ISD Environmental Education Center | Seagoville, TX | Dallas | Dallas | Feb-04 | Shell Solar SP140PC | 1.12 | 113.92 | 30 | 180 |
| 29 | The Winston School | Dallas, TX | Dallas | Dallas | N/A | BP XXXXXXXX | 71 | N/A | 0 | N/A |
| 30 | Childress High School | Childress, TX | Childress | Denton | Jul-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 25 | 180 |
| 31 | Cordova Middle School | El Paso, TX | El Paso | El Paso | Jan-03 | Shell SP140PC | 1.12 | 113.92 | 25 | 180 |
| 32 | Gene Roddenberry Planetarium | El Paso, TX | El Paso | El Paso | Jun-02 | 4-kW ASE SunSine AC | 3.42 | 313.44 | 25 | 180 |
| 33 | Monahans High School | Monahans, TX | Ward | El Paso | Dec-01 | Siemens SP 75 | 0.9 | 81.84 | 60 | 180 |
| 34 | Presidio High School | Presidio, TX | Presidio | El Paso | Dec-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 25 | 180 |
| 35 | Weimar High School | Weimar, TX | Colorado | Fort Bend | May-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 36 | University of Texas Medical Branch at Galveston | Galveston, TX | Galveston | Galveston | Mar-02 | Solarex SX-80U | 19.2 | 1892.88 | 30* | 180* |
| 37 | Pine Tree Junior High School | Longview, TX | Gregg | Gregg | Mar-00 | ASE Americas ASE-300-DG/50 | 4.56 | 417.92 | 25 | 180 |
| 38 | Marion Middle School | Marion, TX | Guadalupe | Guadalupe | May-05 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 39 | Seabrook Intermediate School | Seabrook, TX | Harris | Harris | Nov-03 | Shell SP-140-PC | 1.12 | 113.92 | 60 | 180 |
| 40 | NASA Johnson Space Center | Houston, TX | Harris | Harris | Oct-04 | MSX-121 | 9.72 | 955.8 | 30* | 180* |
| 41 | UT Health Science Center | Houston, TX | Harris | Harris | Feb-00 | Solarex SJ-7500 | 1.5 | 271 | 30* | 180* |
| 42 | Aircraft Obstruction Light | Houston, TX | Harris | Harris | N/A | SX65U | N/A | 162.6 | 30* | 180* |
| 43 | Learning Center at Sheldon Lake State Park | Houston, TX | Harris | Harris | N/A | BP Solar | 170 | 108.4 | 40 | 180* |
| 44 | Learning Center at Sheldon Lake State Park | Houston, TX | Harris | Harris | N/A | N/A | N/A | 81.3 | 25 | 180* |
| 45 | Hempstead Middle School | Hempstead, TX | Washington | Harris | Apr-07 | Sharp Electronics NE-170-U1 | 1.02 | 84 | 35 | 180 |
| 46 | Houston Ship Channel | Houston, TX | Harris | Harris | Sep-00 | BP SX65U | 0.78 | 72 | 30* | N/A |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity[kW] | Total Area [sqft] | Slope | Azimuth [South=180] |
|------------|--------------------------------|-----------------|------------|------------------|-----------|----------------------|--------------|-------------------|-------|---------------------|
| 47 | La Grange Intermediate School | La Grange, TX | Fayette | Bastrop | 05/01/05 | GE Energy GEPV-050-M | 1 | 6.07 | 30 | 180 |
| 48 | Weimar High School | Weimar, TX | Colorado | Fort Bend | 5/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 49 | Marion Middle School | Marion, TX | Guadalupe | Guadalupe | 5/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 50 | Giddings Middle School | Giddings, TX | Lee | Bastrop | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 51 | Schulenburg Elementary School | Schulenburg, TX | Fayette | Bastrop | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 52 | Smithville Junior High School | Smithville, TX | Bastrop | Bastrop | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 53 | Utopia ISD | Utopia, TX | Uvalde | Bexar | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 54 | Brenham Middle School | Brenham, TX | Washington | Montgomery | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 55 | Cuero Junior High School | Cuero, TX | DeWitt | Victoria | 6/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 56 | Bluebonnet Elementary School | Lockhart, TX | Caldwell | Caldwell | 7/5/2008 | GE Energy GEPV-050-M | 1 | 121.4 | 30 | 180 |
| 57 | McKinney Green Building | McKinney, TX | Collin | Collin | 3/6/2008 | ASE-300-DG-FT | 45 | 3749.76 | 30* | N/A |
| 58 | Ft. Sam Houston Bldg. 1350 | San Antonio, TX | Bexar | Bexar | 4/6/2008 | N/A | 181 | N/A | N/A | N/A |
| 59 | Bedichek Middle Shool | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 60 | Blanton Elementary School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 61 | Cunningham elementary School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 62 | Garza High School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 63 | Martin Middle School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 64 | Murchison Middle School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 65 | O'Henry Middle School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 66 | Pond Springs Elementary School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 67 | Westwood High School | Austin, TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 225 |
| 68 | Zilker Elementary School | Austin TX | Travis | Travis | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 69 | Davis Elementary School | Round Rock, TX | Williamson | Williamson | 10/6/2008 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity (kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|--------------------------------|----------------|-----------|------------------|--------|-----------------------------|---------------|-------------------|-------|---------------------|
| 70 | Bedichek Middle Shool | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 71 | Blanton Elementary School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 72 | Cunningham elementary School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 73 | Garza High School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 74 | Harper School | Harper, TX | Gillespie | Travis | Mar-07 | Sharp Electronics NE-170-U1 | 1.02 | 84 | 35 | 180 |
| 75 | Llano Junior High School | Llano, TX | Llano | Travis | Apr-07 | Sharp Electronics NE-170-U5 | 1.02 | 84 | 35 | 180 |
| 76 | Martin Middle School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 77 | Murchison Middle School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 78 | O'Henry Middle School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 79 | Pond Springs Elementary School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 80 | San Marcos Electric Utility | San Marcos, TX | Travis | Travis | Apr-07 | Sharp Electronics NE-170-U5 | 1.02 | 64.08 | 35 | 180 |
| 81 | Sonora High School | Sonora, TX | Sutton | Travis | Dec-99 | ASE Americas ASE-300-DG/50 | 4.56 | 418.08 | 15 | 220 |
| 82 | Vliet Residence | Austin, TX | Travis | Travis | Jan-99 | Siemens SP 75 | 1.8 | 163.92 | 20 | 260 |
| 83 | Westwood High School | Austin, TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 225 |
| 84 | Zilker Elementary School | Austin TX | Travis | Travis | Oct-06 | Sharp ND-L3EJEA | 4.059 | 352.44 | 30 | 180 |
| 85 | Courtyard Tennis Club | Austin, TX | Travis | Travis | N/A | N/A | 23 | N/A | N/A | N/A |
| 86 | Escarment Village | Austin, TX | Travis | Travis | N/A | N/A | 7 | N/A | N/A | N/A |
| 87 | IBM | Austin, TX | Travis | Travis | N/A | N/A | 22 | N/A | N/A | N/A |
| 88 | Hines Pool and Spa | Austin, TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 89 | Centex Beverage Inc. | Austin, TX | Travis | Travis | N/A | N/A | 22 | N/A | N/A | N/A |
| 90 | Lake Austin Marina | Austin , TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 91 | Habitat Suites | Austin, TX | Travis | Travis | N/A | N/A | 17 | N/A | N/A | N/A |
| 92 | Palmer events Center | Austin, TX | Travis | Travis | N/A | N/A | 36 | N/A | N/A | N/A |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|---|----------------------|---------|------------------|-----------|-------------------------|--------------|-------------------|-------|---------------------|
| 93 | Hines Pool and Spa | Austin, TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 94 | Centex Beverage Inc. | Austin, TX | Travis | Travis | N/A | N/A | 22 | N/A | N/A | N/A |
| 95 | Lake Austin Marina | Austin , TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 96 | Habitat Suites | Austin, TX | Travis | Travis | N/A | N/A | 17 | N/A | N/A | N/A |
| 97 | Palmer events Center | Austin, TX | Travis | Travis | N/A | N/A | 36 | N/A | N/A | N/A |
| 98 | LCRA Environmental Laboratory | Austin, TX | Travis | Travis | N/A | N/A | 22 | N/A | N/A | N/A |
| 99 | Austin Bergstrom International Airport | Austin, TX | Travis | Travis | N/A | N/A | 32 | N/A | N/A | N/A |
| 100 | Sand Hill power Plant, Control Building | Austin, TX | Travis | Travis | N/A | N/A | 15 | N/A | N/A | N/A |
| 101 | Spring Terrace | Austin, TX | Travis | Travis | N/A | N/A | 18 | N/A | N/A | N/A |
| 102 | American YouthWorks | Austin, TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 103 | Town Lake Trail Foundation | Austin, TX | Travis | Travis | N/A | N/A | 0.5 | N/A | N/A | N/A |
| 104 | Garden Terrace | Austin, TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 105 | Vintage Creek learning Center | Austin, TX | Travis | Travis | N/A | N/A | 11 | N/A | N/A | N/A |
| 106 | Ebeneezer Baptist Church | Austin, TX | Travis | Travis | N/A | N/A | 8.4 | N/A | N/A | N/A |
| 107 | Sierra Ridge | Austin, TX | Travis | Travis | N/A | N/A | 17 | N/A | N/A | N/A |
| 108 | Westcave Preserve | Round Mountain, TX | Llano | Travis | N/A | N/A | 1.7 | N/A | N/A | N/A |
| 109 | St. Andrews Episcopal School | Austin, TX | Travis | Travis | N/A | N/A | 22 | N/A | N/A | N/A |
| 110 | St. Gabriel Catholic Church | Austin, TX | Travis | Travis | N/A | N/A | 21 | N/A | N/A | N/A |
| 111 | Hornsby Bend Birding Shelter | Austin, TX | Travis | Travis | N/A | N/A | 0.3 | N/A | N/A | N/A |
| 112 | Casa Verde | Austin, TX | Travis | Travis | N/A | N/A | 1.5 | N/A | N/A | N/A |
| 113 | Solar Powered Water Purification | Matagorda Island, TX | Calhoun | Victoria | N/A | BP585U | N/A | 111.23 | 30* | 180* |
| 114 | Austin Clint Small middle school | Austin TX | Travis | Travis | 9/12/2008 | Kyocera 6T130 | 3.12 | N/A | 30 | 180 |
| 115 | City Hall, Austin, Texas | Austin, TX | Travis | Travis | xxx-04 | PROSOL (type-austin)*** | 9.74 | 894.3 | 30* | 180* |
| 116 | Austin Dessau Elementary | Austin TX | Travis | Travis | 9/12/2008 | Kyocera 6T130 | 3.12 | N/A | 30 | 180 |
| 117 | Austin Gus Garcia Middle School | Austin TX | Travis | Travis | 9/12/2008 | Kyocera 6T131 | 3.12 | N/A | 30 | 180 |
| 118 | Austin Lake Travis Elementary | Austin TX | Travis | Travis | 9/12/2008 | Kyocera 6T132 | 3.12 | N/A | 30 | 180 |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|---------------------|---|-----------------|----------|------------------|------------|---------------|--------------|-------------------|-------|---------------------|
| 119 | Austin Lake Travis High School | Austin TX | Travis | Travis | 9/12/2008 | Kyocera 6T132 | 3.12 | N/A | 30 | 180 |
| 120 | Greenville ISD Bowie elementary | Greenville, TX | Hunt | | 2/9/2009 | Sharp NE170 | 4.08 | 336 | 32 | 180 |
| 121 | Greenville ISD Carver elementary | Greenville, TX | Hunt | | 2/9/2009 | Sharp NE170 | 4.08 | 336 | 32 | 180 |
| 122 | Greenville ISD Crockett elementary | Greenville, TX | Hunt | | 2/9/2009 | sharp SH170 | 4.08 | 336 | 32 | 180 |
| 123 | Greenville ISD Lamar elementary | Greenville, TX | Hunt | | 2/9/2009 | sharp SH170 | 4.08 | 336 | 32 | 180 |
| 124 | Greenville ISD Middle Sxhool | Greenville, TX | Hunt | | 2/9/2009 | sharp SH170 | 4.08 | 336 | 32 | 180 |
| 125 | Greenville ISD Travis Elementary | Greenville, TX | Hunt | | 2/9/2009 | sharp SH170 | 4.08 | 336 | 32 | 180 |
| 126 | Manor Middle Sxhool | Manor,TX | Travis | Travis | 10/24/2007 | Sharp NE170 | 1.02 | 84 | 35 | 180 |
| 127 | McKinney Roughs Nature Center | Cedar Creek, TX | Henderon | | 3/24/2008 | Sharp NE170 | 1.02 | 84 | 35 | 180 |
| 128 | San Saba Middle School | San Saba, TX | San Saba | | 6/18/2007 | Sharp NE170 | 1.02 | 84 | 35 | 180 |
| Note: (*) = Assumed | | | | | | | | | | |
| 129 | Villas on 6th | Austin, TX | Travis | Travis | N/A | N/A | 9.1 | N/A | N/A | N/A |
| 130 | Installation for a an electronics equipment | Austin, TX | Travis | Travis | N/A | N/A | 9.1 | N/A | N/A | N/A |
| 131 | Solar Decathlon | Austin,TX | Travis | Travis | N/A | N/A | 3.7 | N/A | N/A | N/A |
| 132 | Bracken Cave | Bracken, TX | Comal | | N/A | N/A | 0.5 | N/A | N/A | N/A |
| 133 | Residential project #163 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 134 | Residential project #157 by Meridian Energy | Plano, TX | Collin | Collin | N/A | N/A | 2 | N/A | N/A | N/A |
| 135 | Residential project #126 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 1.9 | N/A | N/A | N/A |
| 136 | Residential project #224 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 1.75 | N/A | 30 | 115 |
| 137 | Residential project #228 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.34 | N/A | 15 | 210 |
| 138 | Residential project #229 by Meridian Energy | Austin, TX | Travis | Travis | N/A | Sharp 167W | 3.34 | N/A | 12 | 175 |
| 139 | Residential project #233 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.34 | N/A | 30 | 185 |
| 140 | Residential project #234 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 6.68 | N/A | 15 | 120 |
| 141 | Residential project #238 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 4 | N/A | 30 | 180 |
| 142 | Residential project #243 by Meridian Energy | Austin, TX | Travis | Travis | N/A | sharp 165W | 3.3 | N/A | 28 | 170 |
| 143 | Residential project #246 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 2.7 | N/A | 28 | 170 |
| 144 | Residential project #247 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | 45 | 210 |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|---|-------------------|-----------|------------------|------|------------|--------------|-------------------|-------|---------------------|
| 145 | Residential project #252 by Meridian Energy | Austin, TX | Travis | Travis | N/A | sharp 170w | 3.1 | N/A | 20 | 200 |
| 146 | Residential project #268 by Meridian Energy | Austin, TX | Travis | Travis | N/A | sanyo 200w | 3.2 | N/A | 25 | 210 |
| 147 | Residential project #272 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.1 | N/A | 20 | 200 |
| 148 | Residential project #219 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 149 | Residential project #221 by Meridian Energy | Del Valle, TX | Travis | Travis | N/A | N/A | 3.1 | N/A | N/A | N/A |
| 150 | Residential project #239 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.1 | N/A | N/A | N/A |
| 151 | Residential project #244 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 152 | Residential project #256 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 153 | Residential project #266 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 154 | Residential project #281 by Meridian Energy | New Braunfels, TX | Guadalupe | Guadalupe | N/A | N/A | 3 | N/A | N/A | N/A |
| 155 | Residential project #289 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 156 | Residential project #214 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 157 | Residential project #212 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 158 | Residential project #210 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 159 | Residential project #208 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 160 | Residential project #207 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 161 | Residential project #206 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 162 | Residential project #205 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 1 | N/A | N/A | N/A |
| 163 | Residential project #204 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 164 | Residential project #200 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 165 | Residential project #195 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 2 | N/A | N/A | N/A |
| 166 | Residential project #194 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 167 | Residential project #192 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 168 | Residential project #190 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 169 | Residential project #188 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 3 | N/A | N/A | N/A |
| 170 | Residential project #187 by Meridian Energy | Austin, TX | Travis | Travis | N/A | N/A | 1.3 | N/A | N/A | N/A |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|--|-------------------|------------|------------------|------|------------|--------------|-------------------|-------|---------------------|
| 171 | Residential project #184 by Meridian Energy | Frisco, TX | collin | collin | N/A | N/A | 6 | N/A | N/A | N/A |
| 172 | Residential project #183 by Meridian Energy | Spicewood, TX | Burnet | | N/A | N/A | 1.8 | N/A | N/A | N/A |
| 173 | Residential project #181 by Meridian Energy | San Antonio, TX | Bexar | Bexar | N/A | N/A | 3 | N/A | N/A | N/A |
| 174 | Residential project #180 by Meridian Energy | Llano, TX | Llano | | N/A | N/A | 3 | N/A | N/A | N/A |
| 175 | Residential project #165 by Meridian Energy | Blanco, TX | Blanco | | N/A | N/A | 1 | N/A | N/A | N/A |
| 176 | Residential project #119 by Meridian Energy | Wimberly, TX | Hays | | N/A | N/A | 1.4 | N/A | N/A | N/A |
| 177 | Residential project #102 by Meridian Energy | Mexia, TX | Limestone | | N/A | N/A | 1.5 | N/A | N/A | N/A |
| 178 | Residential project #279 by Meridian Energy | Fischer, TX | Comal | Comal | N/A | N/A | 6 | N/A | N/A | N/A |
| 179 | Residential project #105 by Meridian Energy | Brenham, TX | Washington | | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 180 | Residential project #127 by Meridian Energy | Jonestown, TX | Travis | Travis | N/A | N/A | 1.08 | N/A | N/A | N/A |
| 181 | Residential project #161 by Meridian Energy | Alpine, TX | Brewster | | N/A | N/A | 3.96 | N/A | N/A | N/A |
| 182 | Residential project #174 by Meridian Energy | Ft.Davis, TX | Jeff Davis | | N/A | N/A | 2.64 | N/A | N/A | N/A |
| 183 | Residential project #162 by Meridian Energy | Spicewood, TX | Burnet | | N/A | N/A | 0.15 | N/A | N/A | N/A |
| 184 | Residential project #160 by Meridian Energy | Elgin, TX | Travis | Travis | N/A | N/A | 0.308 | N/A | N/A | N/A |
| 185 | Tarrant regional water district | Ft Worth, TX | Travis | | N/A | N/A | 238 | N/A | N/A | N/A |
| 186 | City of Austin, Service center# 5 | Austin, TX | Travis | Travis | N/A | N/A | 23.4 | N/A | N/A | N/A |
| 187 | City of Austin, Service center# 6 | Austin, TX | Travis | Travis | N/A | N/A | 55900 | N/A | N/A | N/A |
| 188 | City of Austin, fire station #27 | Austin, TX | Travis | Travis | N/A | N/A | 4.16 | N/A | N/A | N/A |
| 189 | City of Austin, St.John's | Austin, TX | Travis | Travis | N/A | N/A | 4.94 | N/A | N/A | N/A |
| 190 | City of Austin, Far South Austin Public Health | Austin, TX | Travis | Travis | N/A | N/A | 5.72 | N/A | N/A | N/A |
| 191 | waco chamber of commerce building | Austin, TX | Travis | Travis | N/A | N/A | 9.6 | N/A | N/A | N/A |
| 192 | Houston Code Building | Houston, TX | Harris | Harris | N/A | N/A | 6.6 | N/A | N/A | N/A |
| 193 | city of houston annex building | Houston, TX | Harris | Harris | N/A | N/A | 6.6 | N/A | N/A | N/A |
| 194 | Kirby junior high school, Wichita falls | Wichita Falls, TX | Wichita | | N/A | N/A | 1 | N/A | N/A | N/A |
| 195 | Garnell Construction | Wichita Falls, TX | Wichita | | N/A | N/A | 4.2 | N/A | N/A | N/A |
| 196 | Green Builders | Austin, TX | Travis | Travis | N/A | N/A | 2.8 | N/A | N/A | N/A |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|--|------------------|-----------|------------------|------|------------|--------------|-------------------|-------|---------------------|
| 197 | Green Builders | Austin, TX | Travis | Travis | N/A | N/A | 1.6 | N/A | N/A | N/A |
| 198 | Children's museum of Houston | Houston, TX | Harris | Harris | N/A | N/A | 8.8 | N/A | N/A | N/A |
| 199 | Chipotle Mexican Grill | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 200 | Discovery Green | Houston, TX | Harris | Harris | N/A | N/A | 49.9 | N/A | N/A | N/A |
| 201 | Jason's Deli | Austin, TX | Travis | Travis | N/A | N/A | 8.8 | N/A | N/A | N/A |
| 202 | Tejas securities building | Austin, TX | Travis | Travis | N/A | N/A | 22.4 | N/A | N/A | N/A |
| 203 | Jason's Deli | Beaumont, TX | Jefferson | | N/A | N/A | 7.7 | N/A | N/A | N/A |
| 204 | Chipotle Mexican Grill | Austin, TX | Travis | Travis | N/A | N/A | 3.8 | N/A | N/A | N/A |
| 205 | Residential project by Standard Renewable Energy | Dallas, TX | Dallas | Dallas | N/A | N/A | 3.5 | N/A | N/A | N/A |
| 206 | Residential project by Standard Renewable Energy | Carrollton, TX | Denton | | N/A | N/A | 2 | N/A | N/A | N/A |
| 207 | Residential project by Standard Renewable Energy | Galveston, TX | Galveston | | N/A | N/A | 3.8 | N/A | N/A | N/A |
| 208 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.1 | N/A | N/A | N/A |
| 209 | Residential project by Standard Renewable Energy | Bellaire, TX | Harris | | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 210 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.1 | N/A | N/A | N/A |
| 211 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 212 | Residential project by Standard Renewable Energy | Galveston, TX | Galveston | | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 213 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 214 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 215 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 216 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 3.2 | N/A | N/A | N/A |
| 217 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 3.4 | N/A | N/A | N/A |
| 218 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 3.4 | N/A | N/A | N/A |
| 219 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 3.5 | N/A | N/A | N/A |
| 220 | Residential project by Standard Renewable Energy | Dallas, TX | Dallas | Dallas | N/A | N/A | 3.1 | N/A | N/A | N/A |
| 221 | Residential project by Standard Renewable Energy | Shavano Park, TX | Bexar | | N/A | N/A | 4.6 | N/A | N/A | N/A |
| 222 | Residential project by Standard Renewable Energy | Katy, TX | Harris | | N/A | N/A | 4.8 | N/A | N/A | N/A |

Table 6-2: Solar Photovoltaic Cell Projects: Data and Information (cont.)

| Project No | Solar Project | City/Town | County | County for ECALC | Date | PV Modules | Capacity(kW) | Total Area (sqft) | Slope | Azimuth (South=180) |
|------------|--|-----------------|-----------|------------------|------|------------|--------------|-------------------|-------|---------------------|
| 223 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 4.8 | N/A | N/A | N/A |
| 224 | Residential project by Standard Renewable Energy | Dallas, TX | Dallas | Dallas | N/A | N/A | 4.6 | N/A | N/A | N/A |
| 225 | Residential project by Standard Renewable Energy | Wimberly, TX | Hays | | N/A | N/A | 5.1 | N/A | N/A | N/A |
| 226 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 6 | N/A | N/A | N/A |
| 227 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 6.4 | N/A | N/A | N/A |
| 228 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 6.4 | N/A | N/A | N/A |
| 229 | Residential project by Standard Renewable Energy | Austin, TX | Travis | Travis | N/A | N/A | 6.4 | N/A | N/A | N/A |
| 230 | Residential project by Standard Renewable Energy | Houston, TX | Harris | Harris | N/A | N/A | 6.1 | N/A | N/A | N/A |
| 231 | Residential project by Standard Renewable Energy | Texas City, TX | Galveston | | N/A | N/A | 8.5 | N/A | N/A | N/A |
| 232 | Colorado acres | Webb county, Tx | Webb | | N/A | N/A | 7.2 | N/A | N/A | N/A |

Table 6-3: Solar Photovoltaic Cell Projects: Energy and NOx Reductions

| Proj. No | Project | County For Ecalc | Annual Energy Savings (for base year conditions) and Emissions Reduction In lbs/year | | | | | | | Annual Energy Savings (for base year conditions) and Average Emissions Reduction In lbs/day Per Ozone Season | | | | | | |
|-------------|---|---------------------|---|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|---|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | | | Annual Energy Consumptio | 1999 | | | 2007 | | | Annual Energy Consumpti | 1999 | | | 2007 | | |
| | | | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ |
| 1 | Vliet Residence | Travis | 2415 | 9.27 | 5.22 | 3465 | 3.92 | 2.17 | 3109 | 8 | 0.03 | 0.02 | 11 | 0.01 | 0 | 9 |
| 2 | Del Rio High School | Bexar | 6165 | 16.26 | 5.85 | 9155 | 10.17 | 10.1 | 10013 | 19 | 0.05 | 0.02 | 28 | 0.03 | 0.02 | 30 |
| 3 | Uvalde Junior High School | Bexar | 6165 | 16.26 | 5.85 | 9155 | 10.17 | 10.1 | 10013 | 19 | 0.05 | 0.02 | 28 | 0.03 | 0.02 | 30 |
| 4 | El Campo Middle School | Brazoria | 5513 | 13.31 | 11.41 | 8670 | 9.54 | 7.4 | 7790 | 17 | 0.04 | 0.03 | 26 | 0.03 | 0.02 | 23 |
| 5 | Childress High School | Denton | 6284 | 24.12 | 13.98 | 9081 | 10.22 | 5.71 | 8103 | 20 | 0.08 | 0.04 | 28 | 0.03 | 0.01 | 24 |
| 6 | Central High School | Williamson | 6151 | 23.62 | 13.29 | 8824 | 9.99 | 5.53 | 7917 | 19 | 0.07 | 0.04 | 27 | 0.03 | 0.01 | 23 |
| 7 | Abilene School District Planetarium | Hood | 6284 | 24.12 | 19.98 | 9081 | 10.22 | 5.71 | 8103 | 20 | 0.08 | 0.04 | 28 | 0.03 | 0.01 | 24 |
| 9 | Martin High School | Nueces | 5373 | 14.91 | 3.09 | 7478 | 6.45 | 2.15 | 6320 | 18 | 0.05 | 0.01 | 25 | 0.02 | 0 | 20 |
| 11 | Calallen High School | Nueces | 5567 | 15.45 | 3.2 | 7748 | 6.68 | 2.23 | 6549 | 17 | 0.05 | 0.01 | 24 | 0.02 | 0 | 20 |
| 12 | Spring Hill Junior High School | Smith | 5749 | 22.35 | 12.69 | 8258 | 9.4 | 5.26 | 7408 | 18 | 0.07 | 0.04 | 26 | 0.03 | 0.01 | 22 |
| 15 | Sonora High School | Travis | 6131 | 23.54 | 13.25 | 8795 | 9.96 | 5.51 | 7891 | 20 | 0.07 | 0.04 | 28 | 0.03 | 0.01 | 24 |
| 16 | UT Health Science Center | Harris | 3545 | 5.92 | 5.01 | 3835 | 4.26 | 3.33 | 3464 | 11 | 0.02 | 0.01 | 11 | 0.01 | 0.01 | 10 |
| 17 | Mission High School | Nueces | 5565 | 15.45 | 3.2 | 7746 | 6.68 | 2.23 | 6546 | 17 | 0.05 | 0.01 | 24 | 0.02 | 0 | 20 |
| 19 | Rio Hondo High School | Nueces | 5565 | 15.45 | 3.2 | 7746 | 6.68 | 2.23 | 6546 | 17 | 0.05 | 0.01 | 24 | 0.02 | 0 | 20 |
| 20 | Houston Ship Channel | Harris | 942 | 1.57 | 1.33 | 1019 | 1.13 | 0.89 | 920 | 3 | 0 | 0 | 3 | 0 | 0 | 3 |
| 21 | Maplewood Elementary School | Travis | 2408 | 9.25 | 5.2 | 3455 | 3.91 | 2.17 | 3100 | 7 | 0.03 | 0.02 | 11 | 0.01 | 0 | 9 |
| 22 | Brooksmith ISD | Hood | 670 | 2.57 | 1.49 | 969 | 1.09 | 0.61 | 864 | 1 | 0.01 | 0 | 2 | 0 | 0 | 2 |
| 23 | Hamlin ISD | Parker | 1230 | 4.78 | 2.71 | 1766 | 2.01 | 1.13 | 1585 | 4 | 0.01 | 0.01 | 6 | 0.01 | 0 | 5 |
| 24 | Ira ISD | Parker | 1047 | 4.07 | 2.31 | 1504 | 1.71 | 0.96 | 1349 | 3 | 0.01 | 0.01 | 4 | 0 | 0 | 3 |
| 25 | John Jay High School | Bexar | 1013 | 2.67 | 0.96 | 1505 | 1.67 | 1.66 | 1646 | 3 | 0.01 | 0 | 4 | 0 | 0 | 4 |
| 27 | Holliday ISD | Parker | 1047 | 4.07 | 2.31 | 1504 | 1.71 | 0.96 | 1349 | 3 | 0.01 | 0.01 | 4 | 0 | 0 | 3 |
| 28 | River Road ISD | Parker | 1047 | 4.07 | 2.31 | 1504 | 1.71 | 0.96 | 1349 | 3 | 0.01 | 0.01 | 4 | 0 | 0 | 3 |
| 29 | Eagle Pass High School - CC Winn | Bexar | 1207 | 3.18 | 1.15 | 1792 | 1.99 | 1.98 | 1960 | 4 | 0.01 | 0 | 6 | 0.01 | 0 | 6 |
| 30 | James Madison High School | Bexar | 1207 | 3.18 | 1.15 | 1792 | 1.99 | 1.98 | 1960 | 4 | 0.01 | 0 | 6 | 0.01 | 0 | 6 |
| 31 | University of Texas Medical Branch | Galveston | 24763 | 59.8 | 51.24 | 38942 | 42.85 | 33.23 | 34990 | 74 | 0.18 | 0.15 | 116 | 0.12 | 0.08 | 101 |
| 33 | City Public Services of San Antonio, Northside | Bexar | 24895 | 65.67 | 23.63 | 36970 | 41.08 | 40.79 | 40436 | 75 | 0.2 | 0.07 | 112 | 0.12 | 0.08 | 120 |

Table 6-3: Solar Photovoltaic Cell Projects: Energy and NOx Reductions (cont.)

| Proj. No | Project | County For Ecalc | Annual Energy Savings (for base year conditions) and Emissions Reduction In lbs/year | | | | | | Annual Energy Savings (for base year conditions) and Average Emissions Reduction In lbs/day Per Ozone Season | | | | | | | |
|-------------|--------------------------------------|---------------------|---|-----------------|-----------------|-----------------|-----------------|-----------------|---|-------------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | | | Annual Energy Consumptio | 1999 | | | 2007 | | | Annual Energy Consumpti | 1999 | | | 2007 | | |
| | | | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ |
| 35 | Blue Ridge ISD | Collin | 1230 | 4.72 | 2.73 | 1777 | 2 | 1.12 | 1586 | 4 | 0.01 | 0.01 | 6 | 0.01 | 0 | 5 |
| 36 | Bryker Woods Elementary School | Travis | 1404 | 5.39 | 3.03 | 2014 | 2.28 | 1.26 | 1807 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 5 |
| 37 | East Central ISD | Bexar | 1411 | 3.72 | 1.34 | 2096 | 2.33 | 2.31 | 2292 | 4 | 0.01 | 0 | 6 | 0.01 | 0 | 6 |
| 38 | Alvin High School | Brazoria | 1490 | 3.6 | 3.08 | 2344 | 2.58 | 2 | 2106 | 4 | 0.01 | 0.01 | 7 | 0.01 | 0 | 6 |
| 39 | Seabrook Intermediate School | Harris | 1255 | 2.1 | 1.77 | 1358 | 1.51 | 1.18 | 1226 | 3 | 0.01 | 0 | 4 | 0 | 0 | 3 |
| 40 | Kealing Middle School | Travis | 1404 | 5.39 | 3.03 | 2014 | 2.28 | 1.26 | 1807 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 5 |
| 41 | Canyon High School | Comal | 1681 | 4.43 | 1.6 | 2496 | 2.77 | 2.75 | 2730 | 5 | 0.01 | 0.01 | 8 | 0.01 | 0.01 | 8 |
| 42 | Dallas ISD Environmental Education | Dallas | 1704 | 6.62 | 3.76 | 2448 | 2.79 | 1.56 | 2196 | 5 | 0.02 | 0.01 | 7 | 0.01 | 0 | 6 |
| 43 | Junction High School | Travis | 1404 | 5.39 | 3.03 | 2014 | 2.28 | 1.26 | 1807 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 5 |
| 44 | Roosevelt High School | Bexar | 1669 | 4.4 | 1.58 | 2478 | 2.75 | 2.73 | 2711 | 5 | 0.01 | 0 | 7 | 0.01 | 0.01 | 8 |
| 45 | City Public Services Primary Control | Bexar | 24895 | 65.67 | 23.63 | 36970 | 41.08 | 40.79 | 40436 | 75 | 0.2 | 0.07 | 112 | 0.12 | 0.08 | 120 |
| 46 | NASA Johnson Space Center | Harris | 12504 | 20.87 | 17.66 | 13.53 | 15.04 | 11.75 | 12216 | 37 | 0.06 | 0.05 | 40 | 0.04 | 0.03 | 35 |
| 47 | La Grange Intermediate School | Bastrop | 1774 | 6.9 | 3.92 | 2548 | 2.9 | 1.62 | 2286 | 5 | 0.02 | 0.01 | 8 | 0.01 | 0 | 7 |
| 48 | Weimar High School | Fort Bend | 1588 | 3.84 | 3.25 | 2490 | 2.77 | 2.16 | 2249 | 5 | 0.01 | 0.01 | 7 | 0.01 | 0.01 | 7 |
| 49 | Marion Middle School | Guadalupe | 1779 | 4.69 | 1.69 | 2641 | 2.94 | 2.91 | 2889 | 5 | 0.01 | 0.01 | 8 | 0.01 | 0.01 | 9 |
| 50 | Giddings Middle School | Bastrop | 1774 | 6.9 | 3.92 | 2548 | 2.9 | 1.62 | 2286 | 5 | 0.02 | 0.01 | 8 | 0.01 | 0 | 7 |
| 51 | Schulenburg Elementary School | Bastrop | 1774 | 6.9 | 3.92 | 2548 | 2.9 | 1.62 | 2286 | 5 | 0.02 | 0.01 | 8 | 0.01 | 0 | 7 |
| 52 | Smithville Junior High School | Bastrop | 1774 | 6.9 | 3.92 | 2548 | 2.9 | 1.62 | 2286 | 5 | 0.02 | 0.01 | 8 | 0.01 | 0 | 7 |
| 53 | Utopia ISD | Bexar | 1779 | 4.69 | 1.69 | 2641 | 2.94 | 2.91 | 2889 | 5 | 0.01 | 0.01 | 8 | 0.01 | 0.01 | 9 |
| 54 | Brenham Middle School | Montgomery | 1588 | 2.65 | 2.24 | 1718 | 1.91 | 1.49 | 1552 | 5 | 0.01 | 0.01 | 5 | 0.01 | 0 | 4 |
| 55 | Cuero Junior High School | Victoria | 1624 | 4.51 | 0.93 | 2260 | 1.95 | 0.65 | 1910 | 5 | 0.01 | 0 | 7 | 0.01 | 0 | 6 |
| 56 | Bluebonnet Elementary School | Caldwell | 1774 | 4.93 | 1.02 | 2469 | 2.13 | 0.71 | 2087 | 5 | 0.01 | 0 | 7 | 0.01 | 0 | 6 |
| 57 | McKinney Green Building | Collin | 56096 | 215.35 | 124.75 | 81061 | 91.21 | 50.98 | 72330 | 171 | 0.66 | 0.38 | 248 | 0.28 | 0.07 | 213 |
| 59 | Bedichek Middle Shool | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 60 | Blanton Elementary School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 61 | Cunningham elementary School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |

Table 6-3: Solar Photovoltaic Cell Projects: Energy and NOx Reductions (cont.)

| Proj. No | Project | County For Ecalc | Annual Energy Savings (for base year conditions) and Emissions Reduction In lbs/year | | | | | | Annual Energy Savings (for base year conditions) and Average Emissions Reduction In lbs/day Per Ozone Season | | | | | | | |
|-------------|--|---------------------|--|-----------------|-----------------|-----------------|-----------------|-----------------|--|-------------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|------|
| | | | Annual Energy Consumptio | 1999 | | | 2007 | | | Annual Energy Consumpti | 1999 | | | 2007 | | |
| | | | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ | | NO _x | SO _x | CO ₂ | NO _x | SO _x | |
| 62 | Garza High School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 63 | Martin Middle School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 64 | Murchison Middle School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 65 | O'Henry Middle School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 66 | Pond Springs Elementary School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 67 | Westwood High School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 68 | Zilker Elementary School | Travis | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 69 | Davis Elementary School | Williamson | 5150 | 19.78 | 11.13 | 7389 | 8.37 | 4.63 | 6629 | 16 | 0.06 | 0.03 | 22 | 0.03 | 0.01 | 19 |
| 70 | Brenham Jr. High School | Harris | 826 | 1.38 | 1.17 | 893 | 0.99 | 0.78 | 807 | 2 | 0 | 0 | 3 | 0 | 0 | 2 |
| 71 | Harper School | Travis | 1212 | 4.65 | 2.62 | 1739 | 1.97 | 1.09 | 1560 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 4 |
| 72 | Kendall Elementary School | Bexar | 1215 | 3.21 | 1.15 | 1805 | 2.01 | 1.99 | 1974 | 4 | 0.01 | 0 | 5 | 0.01 | 0 | 6 |
| 73 | Leonard Shanklin Elementary School | Caldwell | 1212 | 3.36 | 0.7 | 1687 | 1.46 | 0.49 | 1426 | 4 | 0.01 | 0 | 5 | 0 | 0 | 4 |
| 74 | Hempstead Middle School | Harris | 1083 | 1.81 | 1.53 | 1171 | 1.3 | 1.02 | 1058 | 3 | 0.01 | 0 | 3 | 0 | 0 | 3 |
| 75 | Llano Junior High School | Travis | 1212 | 4.65 | 2.62 | 1739 | 1.97 | 1.09 | 1560 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 4 |
| 76 | San Marcos Electric Utility | Travis | 925 | 3.55 | 2 | 1326 | 1.5 | 0.83 | 1190 | 3 | 0.01 | 0.01 | 4 | 0 | 0 | 3 |
| 77 | Lampasas Middle School | Williamson | 1212 | 4.65 | 2.62 | 1739 | 1.97 | 1.09 | 1560 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 4 |
| 78 | Bastrop Intermediate School | Bastrop | 1212 | 4.71 | 2.67 | 1741 | 1.98 | 1.11 | 1562 | 4 | 0.01 | 0.01 | 5 | 0.01 | 0 | 4 |
| 79 | Flatonia Elementary School | Caldwell | 1212 | 3.36 | 0.7 | 1687 | 1.46 | 0.49 | 1426 | 4 | 0.01 | 0 | 5 | 0 | 0 | 4 |
| 80 | Waelder ISD | Caldwell | 925 | 2.57 | 0.53 | 1287 | 1.11 | 0.37 | 1088 | 3 | 0.01 | 0 | 4 | 0 | 0 | 3 |
| 84 | Aircraft Obstruction Light | Harris | 2127 | 3.65 | 3 | 2301 | 2.56 | 2 | 2078 | 6 | 0.01 | 0.01 | 7 | 0.01 | 0 | 6 |
| 85 | Learning Center at Sheldon Lake State Park | Harris | 1372 | 2.29 | 1.94 | 1484 | 1.65 | 1.29 | 1340 | 4 | 0.01 | 0.01 | 4 | 0 | 0 | 4 |
| 86 | Learning Center at Sheldon Lake State Park | Harris | 1072 | 1.79 | 1.51 | 1160 | 1.29 | 1.01 | 1048 | 3 | 0.01 | 0 | 4 | 0 | 0 | 3 |
| 88 | Solar Powered Water Pumping | Montgomery | 3545 | 5.92 | 5.01 | 3835 | 4.26 | 3.33 | 3464 | 11 | 0.02 | 0.01 | 11 | 0.01 | 0.01 | 10 |
| 89 | Solar Powered Reverse Osmosis in | Nueces | 8187 | 22.73 | 4.7 | 11395 | 9.83 | 3.28 | 9630 | 25 | 0.07 | 0.01 | 35 | 0.03 | 0.01 | 28 |
| 113 | Solar Powered Water Purification | Victoria | 1488 | 4.13 | 0.86 | 2071 | 1.79 | 0.6 | 1750 | 4 | 0.01 | 0 | 6 | 0.01 | 0 | 5 |
| 114 | City Hall, Austin, Texas | Travis | 13069 | 50.19 | 28.24 | 18747 | 21.23 | 11.75 | 16821 | 39 | 0.15 | 0.09 | 57 | 0.06 | 0.02 | 49 |
| | TOTAL | | 362212 | 9074.6 | 594.79 | 465535 | 8558.3 | 360.65 | 449179 | 1101 | 7999.2 | 1.72 | 1446 | 8029.6 | 0.62 | 1310 |

Table 6-4: Solar Thermal Projects

| Project No | City | County | County for eCalc | Project Purpose | Model | Collector Area (sqft) | Number of collectors | Total Area (sqft) | Slope (degree) | Azimuth (i.e. South=0, West (-) and East (+)) | Fluid |
|------------|----------------|------------|------------------|--|---------------------------|-----------------------|----------------------|-------------------|----------------|---|------------|
| 1 | Austin | Travis | Travis | Domestic Hot Water (DHW) | N/A | N/A | 2 | N/A | N/A | 0 | Antifreeze |
| 2 | Austin | Travis | Travis | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 3 | 78.75 | 20 | 0 | Water |
| 3 | Round Rock | Williamson | Williamson | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 2 | 52.5 | 20 | -90 | Water |
| 4 | Springs | Hays | Hays | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 2 | 52.5 | 20 | 20 | Water |
| 5 | San Antonio | Bexar | Bexar | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 2 | 52.5 | 20 | 0 | Water |
| 6 | San Antonio | Bexar | Bexar | Pool Heating System | FS collector | 32 | 8 | 256 | 20 | -45 | Water |
| 7 | N/A | N/A | N/A | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 3 | 78.75 | 20 | -45 | Water |
| 8 | N/A | N/A | N/A | Domestic Hot Water (DHW) | SS HX Drainback | 26.25 | 2 | 52.5 | 20 | -45 | Water |
| 9 | Midland | Midland | N/A | Pool Heating System-city of midland aquatic center | HC 50 collectors-make:APS | 50 | 256 | 12800 | N/A | N/A | Water |
| 10 | Lubbock | Lubbock | N/A | Pool Heating System-Lubbock TX State School | HC 50 collectors-make:APS | 50 | 36 | 1800 | N/A | N/A | Water |
| 11 | Corpus Christi | Nueces | N/A | Pool Heating System-Corpus Christi TX State School | HC 50 collectors-make:APS | 50 | 36 | 1800 | N/A | N/A | Water |
| 12 | Richmond | Fort Bend | N/A | Pool Heating System-Richmond TX State School | HC 50 collectors-make:APS | 50 | 36 | 1800 | N/A | N/A | Water |
| 13 | El Paso | El Paso | N/A | El Paso recreation facility | HC 50 collectors-make:APS | 50 | 120 | 6000 | N/A | N/A | Water |
| 14 | El Paso | El Paso | N/A | El Paso recreation facility | HC 50 collectors-make:APS | 50 | 128 | 6400 | N/A | N/A | Water |
| 15 | edinburg | Hidalgo | N/A | Pool heating system for Gym spa | make : APS | N/A | 34 | 600+ | N/A | N/A | Water |
| 16 | pearland | Brazoria | N/A | Pool heating system-residential | make : APS | N/A | 7 | N/A | N/A | N/A | water |
| 17 | cleveland | Liberty | N/A | Domestic Hot Water (DHW) | make : APS | N/A | N/A | N/A | N/A | N/A | water |

Table 6-5: Solar Thermal Projects Emissions Reductions

| | | Annual Energy Savings (for base year conditions) and Emissions Reduction | | | | | | Average per Ozone Season Day (for base year conditions) and Emissions Reduction | | | | | | | |
|--------------|------------------|--|-----------------|-----------------|-----------------|-----------------|-----------------|---|------------------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | | Annual Energy Consumption (kWh/yr) | 1999 | | | 2007 | | | Annual Energy Consumption (kWh/yr) | 1999 | | | 2007 | | |
| Project | County for ECALC | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ | | NO _x | SO _x | CO ₂ | NO _x | SO _x | CO ₂ |
| 2 | Travis | 4134 | 15.87 | 8.93 | 5930 | 6.71 | 3.72 | 5320 | 14 | 0.05 | 0.03 | 20 | 0.02 | 0.01 | 17 |
| 3 | Williamson | 3211 | 12.33 | 6.94 | 4606 | 5.22 | 2.89 | 4133 | 13 | 0.05 | 0.03 | 18 | 0.02 | 0 | 16 |
| 4 | Hays | 3469 | 9.16 | 2.44 | 4791 | 4.41 | 1.14 | 4234 | 12 | 0.03 | 0.01 | 17 | 0.02 | 0 | 15 |
| 5 | Bexar | 3469 | 9.15 | 3.29 | 5152 | 5.73 | 5.68 | 5635 | 12 | 0.03 | 0.01 | 18 | 0.02 | 0.01 | 19 |
| 6 | Bexar | 26235 | 69.2 | 24.9 | 38960 | 43.3 | 42.98 | 42.612 | 87 | 0.23 | 0.08 | 130 | 0.14 | 0.09 | 140 |
| TOTAL | | 40518 | 115.71 | 46.5 | 59439 | 65.37 | 56.41 | 19364.6 | 138 | 0.39 | 0.16 | 203 | 0.22 | 0.11 | 207 |

Table 6-6: Solar Thermal Special Project

| Special Case | |
|---|----------------------------------|
| Location | Fort Sam Houston, San Antonio TX |
| Date | 3-Jun |
| Collector | Roof Mounted Parabolic Trough |
| Number of collectors | 129 |
| Total Aperture area (sqft) | 4515 |
| Maximum operation temperature (°F) | 400 |
| Annual Energy Consumption (KWh/yr) | 270583 |
| Annual Energy Consumption OSD (KWh/yr) (KWh/yr) | 741.3 |

Table 6-7: Hydropower Plant Information

| No. | Utility Name | Plant Name | County | Initial Year Of Operation | Capacity in MW | STATUS |
|-----|--|---------------------|------------|---------------------------|----------------|-------------|
| 1 | Guadalupe Blanco River Auth | Abbott TP 3 | Victoria | 1927 | 1.4 | operational |
| 2 | Guadalupe Blanco River Auth | Abbott TP 3 | Victoria | 1927 | 1.4 | operational |
| 3 | Guadalupe Blanco River Auth | Dunlap TP 1 | Guadalupe | 1927 | 1.8 | operational |
| 4 | Guadalupe Blanco River Auth | Dunlap TP 1 | Guadalupe | 1927 | 1.8 | operational |
| 5 | Guadalupe Blanco River Auth | Nolte | Williamson | 1927 | 1.2 | operational |
| 6 | Guadalupe Blanco River Auth | Nolte | Williamson | 1927 | 1.2 | operational |
| 7 | Guadalupe Blanco River Auth | H 4 | Guadalupe | 1931 | 2.4 | operational |
| 8 | Guadalupe Blanco River Auth | H 5 | Guadalupe | 1931 | 2.4 | operational |
| 9 | Guadalupe Blanco River Auth | TP 4 | Guadalupe | 1932 | 2.4 | operational |
| 10 | Maverick Cty Water Control & Improvement | Eagle Pass | Maverick | 1932 | 3.2 | operational |
| 11 | Maverick Cty Water Control & Improvement | Eagle Pass | Maverick | 1932 | 3.2 | operational |
| 12 | Maverick Cty Water Control & Improvement | Eagle Pass | Maverick | 1932 | 3.2 | operational |
| 13 | Lower Colorado River Authority | Buchanan | Burnet | 1938 | 18.3 | operational |
| 14 | Lower Colorado River Authority | Buchanan | Burnet | 1938 | 18.3 | operational |
| 15 | Lower Colorado River Authority | Buchanan | Burnet | 1938 | 11.2 | operational |
| 16 | Lower Colorado River Authority | Inks | Burnet | 1938 | 15 | operational |
| 17 | Lower Colorado River Authority | Austin | Lampasas | 1941 | 8 | operational |
| 18 | Lower Colorado River Authority | Austin | Lampasas | 1941 | 8 | operational |
| 19 | Lower Colorado River Authority | Marshall Ford | Travis | 1941 | 34 | operational |
| 20 | Lower Colorado River Authority | Marshall Ford | Travis | 1941 | 34.5 | operational |
| 21 | Lower Colorado River Authority | Marshall Ford | Travis | 1941 | 34 | operational |
| 22 | Brazos River Authority | Morris Sheppard | Palo Pinto | 1942 | 12.5 | operational |
| 23 | Brazos River Authority | Morris Sheppard | Palo Pinto | 1942 | 12.5 | operational |
| 24 | USCE-Tulsa District | Denison | Grayson | 1945 | 35 | operational |
| 25 | USCE-Tulsa District | Denison | Grayson | 1949 | 35 | operational |
| 26 | Lower Colorado River Authority | Granite Shoals | Burnet | 1951 | 30 | operational |
| 27 | Lower Colorado River Authority | Granite Shoals | Burnet | 1951 | 30 | operational |
| 28 | Lower Colorado River Authority | Marble Falls | Burnet | 1951 | 15 | operational |
| 29 | Lower Colorado River Authority | Marble Falls | Burnet | 1951 | 15 | operational |
| 30 | USCE-Fort Worth District | Whitney | Bosque | 1953 | 15 | operational |
| 31 | USCE-Fort Worth District | Whitney | Bosque | 1953 | 15 | operational |
| 32 | International Bound & Wtr Comm | Falcon Dam & Power | Zapata | 1954 | 10.5 | operational |
| 33 | International Bound & Wtr Comm | Falcon Dam & Power | Zapata | 1954 | 10.5 | operational |
| 34 | International Bound & Wtr Comm | Falcon Dam & Power | Zapata | 1954 | 10.5 | operational |
| 35 | USCE-Fort Worth District | Sam Rayburn | Jasper | 1965 | 26 | operational |
| 36 | USCE-Fort Worth District | Sam Rayburn | Jasper | 1965 | 26 | operational |
| 37 | Entergy Gulf States Inc | Toledo Bend | Newton | 1969 | 40.5 | operational |
| 38 | Entergy Gulf States Inc | Toledo Bend | Newton | 1969 | 40.5 | operational |
| 39 | International Bound & Wtr Comm | Amistad Dam & Power | Valverde | 1983 | 33 | operational |
| 40 | International Bound & Wtr Comm | Amistad Dam & Power | Valverde | 1983 | 33 | Operational |
| 41 | Guadalupe Blanco River Auth | Canyon | Randall | 1989 | 3 | Operational |
| 42 | Guadalupe Blanco River Auth | Canyon | Randall | 1989 | 3 | Operational |
| 43 | USCE-Fort Worth District | Robert D Willis | Harris | 1989 | 4 | Operational |
| 44 | USCE-Fort Worth District | Robert D Willis | Harris | 1989 | 4 | Operational |
| 45 | City of Garland | Lewisville | Denton | 1992 | 2.8 | Operational |
| | | | | Total | 669.2 | |

Table 6-8: Geothermal Heat Pump Energy Projects

| No | Project | County | Implementation Date | Capacity (ton) | Area (sqft) |
|----|--|----------|---------------------|----------------|-------------|
| 1 | Birdville High School Campus | Denton | 2001 | N/A | N/A |
| 2 | Texas Motor Speedway | Denton | 1998 | N/A | N/A |
| 3 | George W. Bush's ranch | McLennan | 2001 | 14 | N/A |
| 4 | Esperanza del Sol, Dallas (Hope of the Sun) | Dallas | 1994 | 18 | 15,276 |
| 5 | Hillside Oaks, East Dallas | Dallas | 1997 | 366 | 276,120 |
| 6 | Pease Elementary School, Austin | Travis | 1997 | 90 | 39,162 |
| 7 | Brooke Elementary School | Travis | 1997 | 150 | 51,605 |
| 8 | Govalle Elementary School | Travis | 1997 | 230 | 89,319 |
| 9 | Bailey Middle School, Austin | Travis | 1997 | 512 | 200,000 |
| 10 | Home in Iowa Park | Wichita | 1997 | 1 | 1,668 |
| 11 | The Home of the Future | Dallas | 1997 | 13 | 4,573 |
| 12 | Birdville Athletic Complex / Stadium | Tarrant | post 1992 | N/A | 60,000 |
| 13 | Frisco ISD Administration Building and Network Operations Center | Collin | post 1992 | N/A | 20,000+ |
| 14 | Aubrey Athletic Complex / Stadium | Denton | post 2002 | 64 | 25,807 |
| 15 | Lake Dallas Athletic Complex / Stadium | Denton | post 2001 | 63 | 43,500 |
| 16 | Wakeland High School | Collin | post 1992 | 1010.25 | 335,932 |
| 17 | Lovejoy High School | Collin | post 2004 | 792.5 | 216,290 |
| 18 | Grand Prairie High Ninth Grade Center | Dallas | post 2000 | 598 | 150,000+ |
| 19 | South Grand Prairie High Ninth Grade Center | Dallas | post 2001 | atleast 133 | 100,000+ |
| 20 | Renovations to HVAC System at South Grand Prairie High School | Dallas | post 2001 | 69 | 12,500 |
| 21 | Renovations to HVAC System at South Grand Prairie High School | Dallas | post 2002 | 64 | 49,000 |
| 22 | David Daniels Elementary | Dallas | post 1992 | N/A | 70,000+ |
| 23 | Edelweiss Daniels Elementary | Dallas | post 2000 | 305 | 72,872 |
| 24 | Crockett Elementary | Dallas | post 2000 | 305 | 72,872 |
| 25 | Kirby Elementary | Dallas | post 2000 | 305 | 72,872 |
| 26 | Renovations to HVAC System at Lee Middle School | Dallas | post 1992 | 214 | 136,600 + |
| 27 | Rebuild of Lee Middle School (Fire Damage) | Dallas | post 2000 | 64 | 2,800 |
| 28 | Renovations/Additions to Adams Middle School | Dallas | post 1992 | N/A | N/A |
| 29 | Renovations/Additions to North Oaks Middle School | Tarrant | post 1992 | N/A | 71,000+ |
| 30 | Renovations/Additions to North Richland Middle School | Tarrant | post 1992 | 273 | 80,000+ |
| 31 | Watauga Middle School | Tarrant | post 2000 | N/A | 80,000+ |
| 32 | HVAC Renovation for Watauga Middle School | Tarrant | post 1992 | 23 | 1987 added |
| 33 | Renovations to HVAC System at Eisenhower Elementary | Dallas | post 1992 | N/A | N/A |
| 34 | Renovations/Additions to Rayburn Elementary | Dallas | post 1992 | N/A | 38,000+ |
| 35 | Renovations/Additions to Watauga Elementary School | Tarrant | post 1992 | N/A | 56,000+ |
| 36 | Renovations/Additions to Smithfield Elementary School | Tarrant | post 1992 | N/A | 56,000+ |
| 37 | Renovations to David E. Smith Elementary School | Tarrant | 2003 | 30 | 45,000+ |
| 38 | Renovations/Additions to Green Valley Elementary School | Tarrant | post 2000 | 8 | 50,000+ |
| 39 | Renovations/Additions to Richland Elementary School | Tarrant | post 1992 | 221 | 38,000+ |
| 40 | Renovations/Additions to Birdville Elementary School | Tarrant | post 1992 | N/A | 32,000+ |
| 41 | Renovations/Additions to Grace Hardeman Elementary | Tarrant | post 2000 | 12 | N/A |
| 42 | W.A. Porter Elementary School | Tarrant | post 2000 | N/A | 48,000+ |
| 43 | Renovations/Additions to W.A. Porter Elementary School | Tarrant | post 2000 | 12 | 1963 added |
| 44 | Haltom Middle School | Tarrant | post 1992 | N/A | 109,000 |
| 45 | HVAC Renovation for Haltom Middle School | Tarrant | post 2000 | 22 | 6730 added |
| 46 | HVAC Renovation for Richland Middle School' | Tarrant | post 1992 | N/A | 91,000 |
| 47 | HVAC Renovation for North Oaks Middle School | Tarrant | post 1992 | N/A | 70,000 |
| 48 | HVAC Renovation for North Richland Middle School | Tarrant | post 1992 | N/A | 75,000 |
| 49 | Holiday Heights Elementary | Tarrant | post 2000 | N/A | 40,000 |
| 50 | HVAC Renovation for Holiday Heights Elementary | Tarrant | post 2000 | 12 | 2923 added |

Table 6-8: Geothermal Heat Pump Energy Projects (cont.)

| No | Project | County | Implementation Date | Capacity (ton) | Area (sqft) |
|-----|---|---------|---------------------|----------------|-------------|
| 51 | HVAC Renovation for Watuaga Elementary | Tarrant | post 1992 | N/A | 40,000 |
| 52 | HVAC Renovation for David E. Smith Elementary | Tarrant | post 1992 | N/A | 35,000 |
| 53 | HVAC Renovation for West Birdville Elementary | Tarrant | post 1992 | N/A | 42,000 |
| 54 | HVAC Renovation for Glenview Elementary | Tarrant | post 1992 | N/A | 40,000 |
| 55 | HVAC Renovation for South Birdville Elementary | Tarrant | post 1992 | 149 | 38,000 |
| 56 | HVAC Renovation for WT Francisco Elementary | Tarrant | post 2000 | 26 | 31,000 |
| 57 | HVAC Renovation for Foster Village Elementary | Tarrant | post 2000 | 12 | 66,000 |
| 58 | Snow Heights Elementary | Tarrant | post 2000 | 124 | 33,000 |
| 59 | Renovations/Additions to Snow Heights Elementary School | Tarrant | post 2000 | 8 | 1963 added |
| 60 | HVAC Renovation for OH Stowe Elementary | Tarrant | post 1992 | N/A | 40,000 |
| 61 | Jackson Middle School | Dallas | post 2000 | 365 | 100,000+ |
| 62 | Renovations to HVAC System at Jackson Middle School | Dallas | post 2000 | N/A | N/A |
| 63 | Renovations/Additions to Richland Elementary School | Tarrant | post 1992 | N/A | 38,000+ |
| 64 | Renovations/Additions to Birdville Elementary School | Tarrant | post 1992 | N/A | 32,000+ |
| 65 | HVAC Renovation for Rayburn Elementary School | Dallas | post 1992 | N/A | N/A |
| 66 | HVAC Renovation for North Oaks Middle School | Tarrant | post 1992 | 204 | 70,000 |
| 67 | HVAC Renovation for Watuaga Elementary | Tarrant | post 2000 | 26 | 40,000 |
| 68 | Anchor Church | Tarrant | post 1992 | N/A | 40,000+ |
| 69 | Little Elm Elementary | Denton | post 2001 | 218 | 70,000+ |
| 70 | Griffen Parc Middle School | Collin | 2004 | 383 | 151,566 |
| 71 | Riddle Elementary | Collin | 2003 | 238 | 70,000+ |
| 72 | Boals Elementary | Collin | 2003 | 238 | 74,300 |
| 73 | Lake Dallas Middle School | Denton | post 2003 | 537.5 | 250,000+ |
| 74 | North Elementary | Tarrant | post 1992 | N/A | 110,000+ |
| 75 | Isbell Elementary | Collin | 2004 | 279 | 75,904 |
| 76 | Bledsoe Elementary | Collin | 2005 | 279 | 75,904 |
| 77 | Roach Middle School | Collin | post 1992 | N/A | 120,000+ |
| 78 | Fowler Middle School | Collin | 2006 | 488 | 138,651 |
| 79 | North Star Elementary | Tarrant | post 1992 | N/A | 70,000+ |
| 80 | Hometown Elementary School | Tarrant | post 1992 | N/A | 70,000+ |
| 81 | Liberty High School | Collin | 2007 | 1051 | 306,179 |
| 82 | Ashley Elementary | Collin | 2005 | 279 | 75,325 |
| 83 | Ogle Elementary | Collin | 2006 | 279 | 75,904 |
| 84 | Sem Elementary | Collin | post 1992 | N/A | 70,000+ |
| 85 | Corbell Elementary | Collin | 2005 | 279 | 76,814 |
| 86 | Taylor Elementary | Collin | post 1992 | N/A | 70,000+ |
| 87 | Middle School #5 | Tarrant | post 1992 | N/A | 1,40,000+ |
| 88 | Intermediate School #5 | Tarrant | post 1992 | N/A | 1,20,000+ |
| 89 | Liberty Elementary | Tarrant | post 1992 | N/A | 70,000+ |
| 90 | Stafford Middle School | Collin | 2008 | 509 | 142,108 |
| 91 | Scoggins Middle School | Collin | 2008 | 512 | 124,108 |
| 92 | Elementary #10 | Tarrant | post 1992 | N/A | 70,000+ |
| 93 | Elementary #11 | Tarrant | post 1992 | N/A | 70,000+ |
| 94 | Elementary #12 | Tarrant | post 1992 | N/A | 70,000+ |
| 95 | Elementary #13 | Tarrant | post 1992 | N/A | 70,000+ |
| 96 | Middle School #4 | Tarrant | 2006 | 624 | 151,417 |
| 97 | Robertson Elementary | Collin | 2007 | 291 | 75,902 |
| 98 | Mooneyham Elementary | Collin | 2007 | 291 | 75,902 |
| 99 | Carrol Elementary | Collin | 2007 | 291.5 | 75,902 |
| 100 | Brookstone Elementary | Collin | 2008 | 291.5 | 75,902 |

Table 6-8: Geothermal Heat Pump Energy Projects (cont.)

| No | Project | County | Implementation Date | Capacity (ton) | Area (sqft) |
|-----|---|------------|---------------------|----------------|-------------|
| 101 | Tadlock Elementary | Collin | 2008 | 306.5 | 77,184 |
| 102 | Aubrey Intermediate/Middle School | Denton | post 2004 | 209.5 | 80,000+ |
| 103 | Florence Hill Elementary | Dallas | post 2003 | 160 | 70,000+ |
| 104 | Garner Elementary | Dallas | post 2004 | 160 | 70,000+ |
| 105 | Bowie Elementary | Dallas | post 2004 | 44 | 25,000+ |
| 106 | High School #5 | Collin | post 1992 | N/A | 300,000+ |
| 107 | High School #6 | Collin | post 1992 | N/A | 300,000+ |
| 108 | Memorial Stadium Field House | Collin | 2004 | 27 | 10,000+ |
| 109 | Rogers Elementary | Collin | post 2006 | 221 | 63,000+ |
| 110 | Camp Wisdom Elementary | Dallas | post 1992 | N/A | 70,000+ |
| 111 | Additions to Anderson Elementary | Collin | 2003 | 30 | 9,000+ |
| 112 | Additions to Borchardt Elementary | Collin | post 1992 | N/A | 9,000+ |
| 113 | Bright Elementary | Collin | 2004 | 30 | 9,000+ |
| 114 | Additions to Christi Elementary | Collin | 2004 | 29.5 | 9,000+ |
| 115 | Additions to Curtsinger Elementary | Collin | post 1992 | N/A | 9,000+ |
| 116 | Additions to Fisher Elementary | Collin | 2003 | 30 | 9,000+ |
| 117 | Additions to Shawnee Trail Elementary | Collin | post 1992 | N/A | 9000 + |
| 118 | CATE Center (Career and Technology) | Collin | 2008 | 401.5 | 100,000+ |
| 119 | CTE at Centennial High School (Career and Technology) | Collin | 2007 | 16 | 9000+ |
| 120 | Staley Middle School Field House | Collin | 2004 | 12 | 6000+ |
| 121 | West Transportation Facility | Collin | 2008 | 80 | 26,148 |
| 122 | McKinney Lofts | Dallas | N/A | N/A | N/A |
| 123 | Havana Club Apartments | Bexar | N/A | N/A | N/A |
| 124 | Hogg Palace Lofts | Harris | N/A | N/A | N/A |
| 125 | South Main Baptist Church | Harris | N/A | N/A | N/A |
| 126 | The Tower | Tarrant | N/A | N/A | N/A |
| 127 | Edgemere | Dallas | N/A | N/A | N/A |
| 128 | Radisson Carlson Park | Bexar | N/A | N/A | N/A |
| 129 | Biggs Field Project | El Paso | N/A | N/A | N/A |
| 130 | Denison Housing Authority | Grayson | N/A | N/A | N/A |
| 131 | Fort Sam Houston Barracks | Bexar | N/A | N/A | N/A |
| 132 | Fort Sam Houston Building 905/906 | Bexar | N/A | N/A | N/A |
| 133 | Fort Walters | Palo pinto | N/A | N/A | N/A |
| 134 | Drury Inn & Suites | Bexar | N/A | N/A | N/A |
| 135 | Lexington Hotel Suites | Tarrant | N/A | N/A | N/A |
| 136 | Arnold Middle School | Dallas | N/A | N/A | N/A |
| 137 | Shaner Hotel | Bexar | N/A | N/A | N/A |
| 138 | Holiday Inn Northwest | Bexar | N/A | N/A | N/A |
| 139 | 2ND Home Suites | Dallas | N/A | N/A | N/A |
| 140 | Homewood Suites | Bexar | N/A | N/A | N/A |
| 141 | Air Dynamics | Dallas | N/A | N/A | N/A |
| 142 | Radiatas | Webb | N/A | N/A | N/A |
| 143 | Hensley Field Operations Center | Dallas | N/A | N/A | N/A |
| 144 | Southwest Plaza Base Bldg | Dallas | N/A | N/A | N/A |
| 145 | Air Performance | Dallas | N/A | N/A | N/A |
| 146 | Meadwest VA Co. | Harris | N/A | N/A | N/A |
| 147 | Gap #1550 Mockingbird Station | Dallas | N/A | N/A | N/A |
| 148 | Kirby Building | Dallas | N/A | N/A | N/A |
| 149 | USSA Towers | Bexar | N/A | N/A | N/A |
| 150 | Trinity Towers | Nueces | N/A | N/A | N/A |

Table 6-8: Geothermal Heat Pump Energy Projects (cont.)

| No | Project | County | Implementation Date | Capacity (ton) | Area (sqft) |
|-----|--|-------------|---------------------|----------------|----------------|
| 151 | Sonny Bryans BBQ | Dallas | N/A | N/A | N/A |
| 152 | L'Etoile Restaurant | Bexar | N/A | N/A | N/A |
| 153 | Sweeny Ind.Sch. Dist.Warehouse | Brazoria | N/A | N/A | N/A |
| 154 | Freylands Elementary | Chambers | N/A | N/A | N/A |
| 155 | Mustang Mech. Montwood High | El Paso | N/A | N/A | N/A |
| 156 | Boerne Elementary School | Kendall | N/A | N/A | N/A |
| 157 | City View Schools | Wichita | N/A | N/A | N/A |
| 158 | Montwood High School Addition | El Paso | N/A | N/A | N/A |
| 159 | Montwood High School Auditorium | El Paso | N/A | N/A | N/A |
| 160 | The Island on Lake Travis | Travis | N/A | N/A | N/A |
| 161 | Allen Campus | Brazos | N/A | N/A | N/A |
| 162 | Judson Lofts | Bexar | N/A | N/A | N/A |
| 163 | pink elementary school | collin | 2005 | 286 | 75,904 |
| 164 | Griffin middle school | collin | 2002 | N/A | N/A |
| 165 | Joslin Elementary | Travis | 1991 | N/A | N/A |
| 166 | Brent wood Elementary | Travis | 1991 | N/A | N/A |
| 167 | Walnut Creek Elementary | Travis | 1991 | N/A | N/A |
| 168 | Sims Elementary | Travis | 1991 | N/A | N/A |
| 169 | F R Rice Elementary | Travis | 1991 | N/A | N/A |
| 170 | T A Brown Elementary | Travis | 1991 | N/A | N/A |
| 171 | Canyon Ridge Middle School | William son | 2004 | N/A | N/A |
| 172 | Vista Ridge High School | William son | 2004 | N/A | N/A |
| 173 | Pleasant Hill Elemtary | William son | 2005 | N/A | N/A |
| 174 | Good Night Middle school | Hays | 1985 | N/A | N/A |
| 175 | Santa Teresa Elementary | Hays | N/A | 125 | N/A |
| 176 | Santa Teresa Middle School | Hays | N/A | 200 | N/A |
| 177 | Esconreras primary kindergarten | Hays | N/A | 105 | N/A |
| 178 | Mullendore Elementary | Tarrant | post 1995 | N/A | N/A |
| 179 | O.H. Stowe Elementary | Tarrant | post 1995 | N/A | N/A |
| 180 | Austin Elementary School GPISD | Dallas | post 2000 | 91 | atleast 21,100 |
| 181 | Fannin Elementary School GPISD | Dallas | 2004 | 220.5 | N/A |
| 182 | Peaster Elementary | Parker | post 1995 | N/A | N/A |
| 183 | Frisco Elementary School #15 | collin | post 1995 | N/A | N/A |
| 184 | Lone Star Elementary - Frisco ISD | collin | post 1995 | N/A | N/A |
| 185 | Woodland Springs Elementary - Keller ISD | Tarrant | post 1995 | N/A | N/A |
| 186 | Bette Perot Elementary - Keller ISD | Tarrant | post 1995 | N/A | N/A |
| 187 | Granbury Middle School East Site | Hood | post 1995 | N/A | N/A |
| 188 | Frisco Elementary #18 - Shaddock | collin | post 2007 | N/A | N/A |
| 189 | Shiver Road Elementary #18 Keller ISD | Tarrant | post 2007 | N/A | N/A |
| 190 | Woodland Springs Elementary #17 Keller ISD | Tarrant | post 2007 | N/A | N/A |
| 191 | McDonwell Elementary (Keller ISD) | Tarrant | post 2007 | N/A | N/A |
| 192 | Keller Intermediate School #5 Keller ISD | Tarrant | post 2007 | N/A | N/A |
| 193 | Shady Shores Elementary | Denton | post 2007 | 392.75 | 75,904 |
| 194 | Alta Vista Middle School #5 Keller ISD | Tarrant | post 2007 | N/A | N/A |
| 195 | Brewer High School (White Settlement ISD) | Tarrant | post 2007 | N/A | N/A |
| 196 | Leaky High school | Gillespie | N/A | 120 | N/A |
| 197 | Canutillo High School | El Paso | N/A | 1200 | N/A |
| 198 | Lubbock Christian University | Lubbock | N/A | N/A | N/A |
| 199 | Rice University | Harris | N/A | N/A | N/A |
| 200 | brown building lofts | Travis | N/A | N/A | N/A |

Table 6-8: Geothermal Heat Pump Energy Projects (cont.)

| No | Project | County | Implementation Date | Capacity (ton) | Area (sqft) |
|-----|---|---------|---------------------|----------------|-------------|
| 201 | Wheeler county Court House | wheeler | N/A | N/A | N/A |
| 202 | Ballinger housing authority | runnels | N/A | N/A | N/A |
| 203 | Project under category miscellaneous cited by FHP manufacturing | Travis | N/A | N/A | N/A |
| 204 | Foreman independent school district | Bowie | N/A | N/A | N/A |
| 205 | Timber Creek High School #4 | Tarrant | post '2008 | 116.5 | 361,141 |
| 206 | Ed Wilkie Middle School #5: Geothermal Design Services | Travis | post '2008 | 643 | |
| 207 | William & Abbie Allen Elementary School | Collin | post '2008 | 339 | 83,960 |
| 208 | Career & Technology Education Center | N/A | post '2008 | 799 | 247,880 |
| 209 | Early Childhood School | Collin | post '2008 | 385 | 54,861 |
| 210 | Burleson Elementary School #11 | N/A | post '2008 | 283.5 | |
| 211 | Killeen Police Headquarters: Geothermal Design | Bell | post '2008 | 208 | 88,663 |
| 212 | Burleson High School #2 | Tarrant | post '2008 | 2126 | 490,447 |
| 213 | Secondary Instructional Facility | Travis | post '2008 | 745 | 184,824 |
| 214 | Lamar & Norma Hunt Middle School #10 | Collin | post '2008 | 512 | 147,096 |
| 215 | Elizabeth Cash Maus Middle School #11 | Collin | post '2008 | 512 | 147,096 |
| 216 | Robert Cobb Middle School #12 | Collin | post '2008 | 512 | 147,096 |
| 217 | ES | Collin | post '2008 | 310 | 77,184 |
| 218 | Aubrey High School | Denton | post '2008 | 225 | N/A |
| 219 | DFW Airport: EAD Annex | Travis | post 2009 | 18 | N/A |
| 220 | 2009 Capital Improvements @ Various Campuses | Travis | post 2009 | 147.5 | N/A |
| 221 | Pre-Kindergarten School | Denton | post 2009 | 164 | 60,391 |
| 222 | George & Debra Purefoy Elementary School #30 | N/A | post 2009 | 304 | N/A |
| 223 | Elementary School #14: Geothermal Design Services | N/A | post 2009 | Y | N/A |
| 224 | Patricia Dean Boswell McCall Elementary School | Parker | 2007 | 367 | 89,642 |
| 225 | Aubrey Intermediate: Add/Reno | Denton | 2007 | 234 | 69,519 |
| 226 | Sam Carter Service Center | Collin | 2007 | 116 | 49,377 |
| 227 | Dr. Monaco Elementary School | Denton | 2007 | 263 | 74,544 |
| 228 | Caprock Elementary School #20 | Tarrant | 2007 | 303.5 | 92,768 |
| 229 | Trinity Springs Middle School: Add. | Tarrant | 2007 | 120.5 | 36,136 |
| 230 | Milam Elementary School: 2007 Bond HVAC Replacement | Dallas | 2008 | 131 | N/A |
| 231 | Truman Middle School: HVAC Retrofit Phase 2 | Dallas | under progress | 146 | N/A |
| 232 | Alta Vista Elementary School | Tarrant | under progress | 572.5 | N/A |
| 233 | Sandshell Elementary School #21 | Travis | under progress | 278 | N/A |
| 234 | Corinth Primary | Denton | under progress | 238 | N/A |
| 235 | All Saints Episcopal School | Travis | under progress | 337 | N/A |
| 236 | Alliance for Children | Travis | under progress | 33 | N/A |
| 237 | Faithbridge Presbyterian Church | Collin | under progress | 165 | N/A |
| 238 | Heritage High School | Collin | 2007 | 1041.5 | 325,693 |

Table 6-9: Landfill Gas-Fired Power Plants: Operational

| Project No | Landfill Name | City | County | Waste In Place (tons) | Landfill Owner Organization | Project Status | Project Start Date | MW Capacity | LFG Flow to Project (SCFD) | Emission Reductions (MTCO2) |
|------------|------------------------------------|-------------|------------|-----------------------|-----------------------------|----------------|--------------------|-------------|----------------------------|-----------------------------|
| 1 | McCarty Road LF | Houston | Harris | 28,918,718 | Allied Waste Services | Operational | 1/1/1986 | N/A | N/A | 0.797 |
| 2 | DFW Gas Recovery | Lewisville | Denton | N/A | WM Renewable Energy LLC | Operational | May-88 | 3 | N/A | N/A |
| 3 | DFW Gas Recovery | Lewisville | Denton | N/A | WM Renewable Energy LLC | Operational | May-88 | 3 | N/A | N/A |
| 4 | Dallas-Fort Worth LF | Dallas | Denton | 18,388,100 | Waste Management, Inc. | Operational | 1/1/1992 | 6.6 | N/A | 0.286 |
| 5 | Sunset Farms | Austin | Travis | N/A | Gas Recovery Systems Inc | Operational | Dec-96 | 1 | N/A | N/A |
| 6 | Sunset Farms | Austin | Travis | N/A | Gas Recovery Systems Inc | Operational | Dec-96 | 1 | N/A | N/A |
| 7 | Sunset Farms | Austin | Travis | N/A | Gas Recovery Systems Inc | Operational | Dec-96 | 1 | N/A | N/A |
| 8 | Sunset Farms | Austin | Travis | 9,600,000 | Allied Waste Services | Operational | 12/1/1996 | 3 | 1.5 | 0.13 |
| 9 | Austin Community LF | Austin | Travis | 10,380,188 | Waste Management, Inc. | Shutdown | 1/1/1998 | N/A | N/A | N/A |
| 10 | City of Brownwood Landfill | Brownwood | Brown | 1,300,100 | City of Brownwood | Operational | 1/1/1998 | N/A | N/A | 0.035 |
| 11 | McCommas Bluff LF/City of Dallas | Dallas | Dallas | 26,470,000 | City of Dallas, TX | Operational | 1/1/2000 | N/A | N/A | 0.772 |
| 12 | Rosenberg Landfill | Rosenberg | Fort Bend | 2,649,100 | Fort Bend County, TX | Operational | 1/1/2000 | N/A | 1 | 0.082 |
| 13 | Castle Road Landfill | Garland | Dallas | 4,012,500 | City of Garland | Operational | 5/1/2000 | N/A | N/A | 0.089 |
| 14 | Arlington LF | Arlington | Tarrant | 13,981,144 | City of Arlington | Operational | 6/1/2001 | 5 | 1.584 | 0.217 |
| 15 | BFI - Tessman Road Landfill | San Antonio | Bexar | 11,300,000 | Allied Waste Services | Operational | 10/10/2002 | 5.4 | 2.9 | 0.234 |
| 16 | Coastal Plains LF | Alvin | Galveston | 6,546,410 | Waste Management, Inc. | Operational | 1/10/2003 | 6.7 | N/A | 0.289 |
| 17 | Sanifill Of Texas-Baytown LF | Baytown | Chambers | 6,290,000 | Waste Management, Inc. | Operational | 1/24/2003 | 3.9 | 1.73 | 0.169 |
| 18 | Blue Bonnet LF | Houston | Harris | 2,526,000 | Waste Management, Inc. | Operational | 3/1/2003 | 1.9 | 0.928 | 0.084 |
| 19 | City of Conroe LF | Conroe | Montgomery | 3,146,000 | City of Conroe | Operational | 3/1/2003 | 2.9 | N/A | 0.126 |
| 20 | Atascosita | Atascosita | Harris | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 21 | Atascosita | Atascosita | Harris | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 23 | Atascosita | Atascosita | Harris | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 24 | Atascosita | Atascosita | Harris | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 25 | Coastal Plains | Alvin | Galveston | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 26 | Coastal Plains | Alvin | Galveston | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 27 | Coastal Plains | Alvin | Galveston | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 28 | Coastal Plains | Alvin | Galveston | N/A | Viridis Energy | Operational | 3-Mar | 1.3 | N/A | N/A |
| 29 | BFI - Tessman Road Landfill | San Antonio | Bexar | 11,300,000 | Allied Waste Services | Operational | 5/1/2003 | 2.7 | 1.45 | 0.117 |
| 30 | Security Recycling and Disposal LF | Cleveland | Montgomery | 4,014,800 | Waste Management, Inc. | Operational | 5/1/2003 | 5 | N/A | 0.217 |

Table 6-9: Landfill Gas-Fired Power Plants: Operational (cont.)


| Project No | Landfill Name | City | County | Waste In Place (tons) | Landfill Owner Organization | Project Status | Project Start Date | MW Capacity | LFG Flow to Project (SCFD) | Emission Reductions (MTCO2) |
|------------|----------------------------------|-------------|------------|-----------------------|-----------------------------|----------------|--------------------|-------------|----------------------------|-----------------------------|
| 31 | BFI Tessman Rd Landfill | San Antonio | Bexar | N/A | Energy Developments Inc | Operational | 3-May | 1.4 | N/A | N/A |
| 32 | WMI/Atascocita LF | Humble | Harris | 9,628,700 | Waste Management, Inc. | Operational | 6/1/2003 | 8.5 | 3.09 | 0.368 |
| 33 | Bluebonnet | Houston | Harris | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 34 | Bluebonnet | Houston | Harris | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 35 | Bluebonnet | Houston | Harris | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 36 | Bluebonnet | Houston | Harris | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 37 | Conroe | Conroe | Montgomery | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 38 | Conroe | Conroe | Montgomery | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 39 | Conroe | Conroe | Montgomery | N/A | Viridis Energy | Operational | 3-Aug | 1 | N/A | N/A |
| 40 | Baytown | Baytown | Chambers | N/A | Viridis Energy | Operational | 3-Dec | 1.3 | N/A | N/A |
| 41 | Baytown | Baytown | Chambers | N/A | Viridis Energy | Operational | 3-Dec | 1.3 | N/A | N/A |
| 42 | Security | Houston | Montgomery | N/A | Viridis Energy | Operational | 3-Dec | 1.3 | N/A | N/A |
| 43 | Security | Houston | Montgomery | N/A | Viridis Energy | Operational | 3-Dec | 1.3 | N/A | N/A |
| 45 | Sunset Farms | Austin | Travis | N/A | Gas Recovery Systems Inc | Operational | 4-Jan | 1 | N/A | N/A |
| 46 | WMI/Atascocita LF | Humble | Harris | 9,628,700 | Waste Management, Inc. | Operational | 1/1/2004 | 1.7 | 0.62 | 0.074 |
| 47 | City of Austin LF | Austin | Travis | 4,858,500 | City of Austin, TX | Operational | 2/1/2004 | 0.2 | N/A | 0.009 |
| 48 | City of Waco LF | Woodway | McLennan | 2,225,000 | City of Waco | Operational | 3/1/2004 | 1.5 | 1 | 0.065 |
| 49 | Atascosita | Atascosita | Harris | N/A | Viridis Energy | Operational | 4-Jul | 1.7 | N/A | N/A |
| 50 | Denton Sanitary Landfill | Denton | Denton | 2,266,664 | City of Denton, TX | Operational | 2/1/2005 | N/A | 0.432 | 0.035 |
| 51 | Covel Gardens LF | San Antonio | Bexar | 12,007,000 | Waste Management, Inc. | Operational | 12/1/2005 | 9.6 | N/A | 0.416 |
| 52 | Fort Worth Regional LF | Haltom City | Tarrant | N/A | Allied Waste Services | Construction | 3/15/2006 | 1.6 | 0.72 | 0.069 |
| 53 | McCommas Bluff LF/City of Dallas | Dallas | Dallas | 26,470,000 | City of Dallas, TX | Construction | 7/1/2006 | 22 | N/A | 0.953 |
| 54 | Denton Sanitary Landfill | Denton | Denton | 2,266,664 | City of Denton, TX | Construction | 9/1/2006 | 1.5 | 0.86 | 0.065 |

Table 6-10: Landfill Gas-Fired Power Plants: Candidates

| Proj. No | Landfill Name | County | Waste In Place (tons) | Year Landfill Opened | Landfill Closure Year | Landfill Owner Organization |
|----------|------------------------------------|-------------|-----------------------|----------------------|-----------------------|-----------------------------|
| 1 | Skyline LF | Ellis | 8,191,000 | 1942 | 2040 | Waste Management, Inc. |
| 2 | Trinity Oaks Landfill | Dallas | 6,838,600 | 1969 | 2003 | Allied Waste Services |
| 3 | J.C. Elliot LF | Nueces | 5,717,100 | 1972 | 2005 | City of Corpus Christi, TX |
| 4 | Galveston County LF | Galveston | 7,822,500 | 1973 | 2025 | Allied Waste Services |
| 5 | Mill Creek LF | Tarrant | 4,815,500 | 1973 | 2002 | Allied Waste Services |
| 6 | City of Lubbock LF | Lubbock | 2,177,800 | 1975 | 2008 | City of Lubbock |
| 7 | City of Pampa LF | Gray | 1,176,200 | 1975 | 2007 | City of Pampa |
| 8 | Colorado City Landfill | Mitchell | 1,545,200 | 1975 | 2020 | City of Colorado City |
| 9 | Comal County LF | Comal | 3,817,620 | 1975 | 2010 | Waste Management, Inc. |
| 10 | Amarillo LF | Potter | 7,031,400 | 1976 | 2050 | City of Amarillo |
| 11 | C&T Landfill | Hidalgo | 3,844,000 | 1976 | 2004 | Duncan Disposal, Inc. |
| 12 | City Of Sweetwater LF | Nolan | 1,283,800 | 1976 | 2040 | City of Sweetwater |
| 13 | City Of Weatherford LF | Parker | 1,079,000 | 1976 | 2060 | IESI, Inc. |
| 14 | Fort Worth Southeast Landfill | Tarrant | 5,299,400 | 1976 | 2036 | City of Fort Worth, TX |
| 15 | SLF | Colorado | 1,980,400 | 1976 | 2002 | Safety Clean |
| 16 | Austin Community LF | Travis | 10,380,188 | 1977 | 2001 | Waste Management, Inc. |
| 17 | City of Grand Prairie LF | Dallas | 2,835,800 | 1977 | 2021 | City of Grand Prairie |
| 18 | City of Nacogdoches Landfill | Nacogdoches | 1,296,200 | 1977 | 2033 | City of Nacogdoches |
| 19 | Westside Sanitary LF | Tarrant | 9,955,600 | 1977 | 2005 | Waste Management, Inc. |
| 20 | Whispering Pines LF | Harris | 6,405,000 | 1978 | 2017 | Allied Waste Services |
| 21 | City of Perryton Landfill | Ochiltree | 1,631,100 | 1979 | 2006 | City of Perryton |
| 22 | City of McKinney LF | Collin | 3,957,000 | 1980 | 2004 | City of McKinney |
| 23 | Nelson Gardens LF | Bexar | 11,800,000 | 1980 | 1993 | City of San Antonio |
| 24 | Camelot Landfill | Denton | 6,044,700 | 1981 | 2019 | City of Farmers Branch |
| 25 | City of Irving Landfill | Dallas | 2,063,900 | 1981 | 2065 | City of Irving, TX |
| 26 | Hillside Landfill | Grayson | 2,526,400 | 1981 | 2023 | Waste Management, Inc. |
| 27 | Sprint Fort Bend County LF | Fort Bend | 1,664,372 | 1981 | 2020 | The Sprint Companies |
| 28 | Williamson County LF | Williamson | 2,134,700 | 1981 | 2040 | Waste Management, Inc. |
| 29 | BFI - Abilene Landfill | Jones | 7,921,300 | 1982 | 2067 | Ray Knowles |
| 30 | City of Victoria Landfill | Victoria | 2,556,000 | 1982 | 2040 | City of Victoria |
| 31 | City of Wichita Falls LF | Wichita | 4,073,200 | 1982 | 2021 | City of Wichita Falls |
| 32 | North Texas Waste/Maxwell Creek LF | Collin | 6,083,700 | 1982 | 2004 | District |
| 33 | Pine Hill LF | Gregg | 12,141,700 | 1982 | 2060 | 4S Oil Company |
| 34 | City of Beaumont LF | Jefferson | 2,868,800 | 1983 | 2021 | City of Beaumont |
| 35 | Clint LF | EI Paso | 4,904,400 | 1983 | 2006 | City of El Paso |
| 36 | Royal Oaks Landfill | Cherokee | 1,044,200 | 1983 | 2030 | Allied Waste Services |
| 37 | Turkey Creek LF | Johnson | 3,733,200 | 1983 | 2025 | Allied Waste Services |
| 38 | McCombs LF | EI Paso | 4,137,100 | 1984 | 2046 | City of El Paso |
| 39 | CSC Disposal and Landfill | Ellis | 4,254,250 | 1985 | 2100 | Republic Services, Inc. |
| 40 | Lacy-Lakeview LF | McLennan | 1,306,200 | 1985 | 2020 | Waste Management, Inc. |
| 41 | City of Laredo LF | Webb | 3,180,000 | 1986 | 2015 | City of Laredo |
| 42 | City of Port Arthur Landfill | Jefferson | 1,802,100 | 1986 | 2044 | City of Port Arthur |
| 43 | Southwest Landfill (Amarillo) | Randall | 3,393,200 | 1987 | 2025 | Allied Waste Services |
| 44 | Sprint LF | Harris | 2,041,600 | 1987 | 2005 | Landfill Owner |
| 45 | Altair Disposal Services LLC | Colorado | 9,195,000 | 1988 | 2004 | Clean Harbors |
| 46 | Greenwood Farms Landfill | Smith | 3,087,300 | 1989 | 2020 | City of Tyler |
| 47 | Texas Disposal Systems LF | Travis | 4,408,900 | 1990 | 2050 | Texas Disposal Systems |
| 48 | Golden Triangle Landfill | Jefferson | 2,310,400 | 1991 | 2021 | Allied Waste Services |
| 49 | Blue Ridge LF | Fort Bend | 4,113,900 | 1993 | 2025 | Allied Waste Services |
| 50 | Brazoria County Disposal LF | Brazoria | 6,279,700 | 1993 | 2050 | Republic Services, Inc. |
| 51 | WMI/E & D Waste Systems Inc. LF | Galveston | 3,202,900 | 1994 | 2022 | Waste Management, Inc. |
| 52 | Charter Waste Landfill | Ector | 1,300,000 | N/A | N/A | Republic Services, Inc. |
| 53 | City of Temple Landfill | Bell | 3,600,000 | N/A | N/A | City of Temple |
| 54 | Eastside Landfill | Tarrant | N/A | N/A | N/A | Waste Management, Inc. |

Table 6-11: Landfill Gas-Fired Power Plants: Potential

| Proj. No. | Landfill Name | City | County | (tons) | Opened | Closure Year | Landfill Owner Organization |
|-----------|--------------------------------|----------------|--------------|-----------|--------|--------------|-----------------------------|
| 1 | Pleasant Oaks Landfill | Mount Pleasant | Titus | N/A | 1960 | 2012 | City of Mount Pleasant |
| 2 | Sinton | Sinton | San Patricio | N/A | 1972 | 2002 | Allied Waste Services |
| 3 | City of Richardson LF | Richardson | Collin | 825,218 | 1975 | 1990 | City of Richardson |
| 4 | City of Cleburne Landfill | Cleburne | Johnson | 1,583,200 | 1976 | N/A | Landfill Owner |
| 5 | Itasca Landfill | Itasca | Hill | N/A | 1977 | 2017 | Allied Waste Services |
| 6 | Quail Canyon | Lubbock | Lubbock | 200,200 | 1977 | 1993 | Allied Waste Services |
| 7 | Hutchins Landfill | Hutchins | Dallas | 1,000,000 | 1978 | 1992 | Allied Waste Services |
| 8 | Maloy Landfill | Commerce | Hunt | 610,000 | 1979 | 2030 | Republic Services, Inc. |
| 9 | Mexia Landfill | Mexia | Limestone | N/A | 1983 | 2019 | Allied Waste Services |
| 10 | Pecan Prairie Landfill | Kingston | Hunt | 1,479,900 | 1984 | 1998 | Waste Management, Inc. |
| 11 | Trashaway San Angelo Landfill | San Angelo | Tom Green | 790,000 | 1984 | N/A | Republic Services, Inc. |
| 12 | Kerrville Landfill | Kerrville | Kerr | N/A | 1985 | 2006 | City of Kerrville |
| 13 | Lewisville Landfill | Lewisville | Denton | N/A | 1986 | 2003 | Allied Waste Services |
| 14 | ECD Landfill | Ennis | Ellis | N/A | 1988 | 2089 | Allied Waste Services |
| 15 | Bell Processing Inc. LF | Wichita Falls | Wichita | N/A | 1990 | 2001 | Bell Processing Inc |
| 16 | Laidlaw/Wilmer LF | Wilmer | Dallas | 686,400 | 1992 | 2001 | Landfill Owner |
| 17 | BFI LF | Abilene | Taylor | 745,888 | 1993 | 1997 | Pine Street Salvage Company |
| 18 | City of Corsicana LF | Corsicana | Navarro | 788,100 | 1993 | 2100 | Landfill Owner |
| 19 | Gulfwest Facility | Anahuac | Chambers | N/A | 1993 | 2017 | Allied Waste Services |
| 20 | Bell County/Sparks LF | Belton | Bell | 343,200 | 1994 | 2001 | Bell County |
| 21 | Ellis County LF | Palmer | Ellis | 892,320 | 1994 | N/A | Waste Management, Inc. |
| 22 | El Centro Landfill | Robstown | Nueces | N/A | 2000 | 2013 | Allied Waste Services |
| 23 | Best Pak Disposal Inc. LF | Pattison | Waller | N/A | N/A | 2001 | Waste Management, Inc. |
| 24 | Hazelwood Enterprises, Inc. LF | N/A | N/A | N/A | N/A | N/A | Landfill Owner |
| 25 | New Boston Landfill | New Boston | Bowie | N/A | N/A | N/A | N/A |
| 26 | Newton County Landfill | Mauriceville | Newton | N/A | N/A | N/A | N/A |
| 27 | North County C&D Landfill | League City | Galveston | N/A | N/A | N/A | Republic Services, Inc. |
| 28 | Paris Landfill | Paris | Lamar | N/A | N/A | N/A | N/A |
| 29 | Rio Grande Valley | Donna | Hidalgo | N/A | N/A | N/A | Allied Waste Services |



| County | County No | No Of Projects |
|-----------|-----------|----------------|
| Archer | 1 | 1 |
| Bastrop | 2 | 2 |
| Bexar | 3 | 11 |
| Blanco | 77 | 1 |
| Brazoria | 5 | 1 |
| Brazos | 6 | 1 |
| Brewster | 78 | 1 |
| Brown | 7 | 1 |
| Burnet | 8 | 2 |
| Caldwell | 9 | 2 |
| Calhoun | 10 | 1 |
| Cameron | 11 | 1 |
| Childress | 13 | 1 |
| Collin | 14 | 4 |
| Colorado | 15 | 1 |
| Comal | 16 | 3 |

| County | County No | No Of Projects |
|-----------|-----------|----------------|
| Dallas | 17 | 5 |
| Denton | 18 | 1 |
| DeWitt | 19 | 1 |
| EI Paso | 20 | 2 |
| Fayette | 21 | 2 |
| Galveston | 23 | 4 |
| Gillespie | 24 | 1 |
| Gonzales | 25 | 2 |
| Gregg | 27 | 1 |
| Guadalupe | 28 | 2 |
| Harris | 29 | 20 |
| Harrison | 30 | 1 |
| Hays | 67 | 2 |
| Henderson | 79 | 1 |
| Hidalgo | 31 | 1 |

| County | County No | No Of Projects |
|------------|-----------|----------------|
| Hunt | 80 | 6 |
| Jeff Davis | 81 | 1 |
| Jefferson | 82 | 1 |
| Jones | 33 | 1 |
| Kendall | 34 | 1 |
| Kimble | 35 | 1 |
| Kinney | 36 | 1 |
| Lampasas | 37 | 1 |
| Lee | 38 | 1 |
| Limestone | 39 | 1 |
| Llano | 39 | 3 |
| Maverick | 40 | 1 |
| Nueces | 44 | 1 |
| Potter | 46 | 1 |
| Presidio | 47 | 1 |

| County | County No | No Of Projects |
|------------|-----------|----------------|
| San Saba | 84 | 1 |
| Scurry | 49 | 1 |
| Smith | 50 | 1 |
| Sutton | 51 | 1 |
| Taylor | 53 | 1 |
| Tom Green | 54 | 1 |
| Travis | 55 | 108 |
| Uvalde | 56 | 2 |
| Ward | 59 | 1 |
| Washington | 60 | 5 |
| Webb | 61 | 3 |
| Wharton | 62 | 1 |
| Wichita | 63 | 2 |
| Williamson | 64 | 1 |
| Wood | 65 | 1 |

Figure 6-1: Solar Photovoltaic Projects throughout Texas




Figure 6-2: Solar Thermal Projects throughout Texas




Figure 6-3: Hydropower Plants throughout Texas




Figure 6-4: Geothermal Projects Installed throughout Texas




Figure 6-5: Landfill Gas-Fired Power Projects Installed throughout Texas




Figure 6-6: Annual Electric Savings per County from PV Projects




Figure 6-7: Ozone Season Day Electric Savings per County from PV Projects




Figure 6-8: NOx Emissions Reductions per County from PV Projects




Figure 6-9: Ozone Season Day NOx Emissions Reductions per County from PV Projects




Figure 6-10: Annual Electric Savings per County from Solar Thermal Projects




Figure 6-11: Ozone Season Day Electric Savings per County from Solar Thermal Projects




Figure 6-12: NOx Emissions Reductions per County from Solar Thermal Projects




Figure 6-13: Ozone Season Day NOx Emissions Reduction per County from Solar Thermal Projects

7 REVIEW OF ERCOT'S RENEWABLE ENERGY CREDIT PROGRAM INFORMATION

7.1 Introduction

In this section, the information posted on ERCOT's Renewable Energy Credit Program site www.texasrenewables.com was reviewed for use in the ESL's report to the TCEQ. In particular, the information posted under the "Public Reports" tab was downloaded and assembled into an appropriate format for review. This includes ERCOT's 2001- 2008 reports to the Legislature, which were converted into tabular format for analysis and inserted into this report. Similarly, information from ERCOT's listing of REC generators was inspected to determine how it compared with other sources of information the ESL has assembled. Table 7-1 to Table 7-5 contains the list of REC generators that ERCOT has assembled up until the end of 2008.

7.2 Summary of Renewable Projects in Texas

Each year ERCOT is required to compile a list of grid-connected sources that generate electricity from renewable energy and report them to the Legislature. Table 7-6 contains the data reported by ERCOT from 2001- 2008 and Table 7-7 summarizes the same.

Figure 7-1, Figure 7-2 and Figure 7-3 have been included to better illustrate the annual data collected by ERCOT. In the figures and tables it is clear to see that the electricity generated by wind each year is the largest single source of renewable energy in Texas—which has grown from 565,597 MWh in 2001 to 16,286,383 MWh in 2008. This is followed by landfill gas: which has grown from 29,412 MWh in 2002 to 386,606 MWh in 2008; hydroelectric: 30,639 (2001) to 445,428 (2008); biomass: 39,496 MWh (2003) to 70,833 MWh in 2008 and lastly solar: 87 MWh (2002) to 3,338 MWh (2008).

Table 7-1: ERCOT REC Generator List – Biomass

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|---------------------------------------|----------------------------------|-------------------------------|---|---------------------|--------------------------------|--------------------------|-----------------|--|
| Bio Energy (Austin) LLC | Bio Energy Austin LLC | DG_WALZE | DG_WALZE | DG_WALZE | 38 | Dennis Bollinger | Biomass | 25512 |
| Biofuels Power Corporation | Biofuels Power Inc. | 20174 | BFP Conroe | 35861 | 116 | Christopher Dufour | Biomass | 35861 |
| Biofuels Power Corporation | Biofuels Power Corporation | 20174 | Oak Ridge North | DG_RA | 118 | Chris Dufour | Biomass | 34211 |
| MeadWestvaco Texas LP | MeadWestvaco Texas LP | Eavadale Operitions | MeadWestvaco Eavadale Pulp and Paper Mill | Eavadale Texas | 63 | Angela Robinson | Biomass | 31646 |
| Rio Grande Valley Sugar Growers, Inc. | RGVSugar | RGVSugar | RGVSugar | RGVSugar | 97 | Steve Bearden | Biomass | 33421 |
| Snider Industries, LLP | Snider Industries, LLP | Snider_1 | Snider_1 | Snider_1 | 109 | Julianna Parr | Biomass | 35526 |

Table 7-2: ERCOT REC Generator List – Hydro

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|----------------------------------|----------------------------------|-------------------------------|-----------------------|---------------------|--------------------------------|--------------------------|-----------------|--|
| Guadalupe-Blanco River Authority | Guadalupe-Blanco River Authority | 05-631-1608-3000 | DG-MCQUEENEY | DG_MCQUE | 4 | Allen Ognoskie | Hydro | 20028 |
| Guadalupe-Blanco River Authority | Guadalupe-Blanco River Authority | 05-631-1608-3000 | DG_LAKEWOOD TAP | DG_LKWDT | 11 | Allen Ognoskie | Hydro | 20028 |
| Guadalupe-Blanco River Authority | Guadalupe-Blanco River Authority | 05-631-1608-3000 | CANYON | DG_CANYON | 12 | Allen Ognoskie | Hydro | 20028 |
| Maverick County Water Control | Maverick County Water | Maverick County | Maverick County Water | 20141 | 92 | Maverick County Water | Hydro | 34674 |
| Small Hydro of Texas, Inc. | Small Hydro of Texas, Inc. | 71 | DG_CUERO CSW | CUECPL | 13 | Linda A. Parker | Hydro | 24191 |

Table 7-3: ERCOT REC Generator List – Solar

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|-----------------------------------|----------------------------------|-------------------------------|--|-------------------------|--------------------------------|--------------------------|-----------------|--|
| Renewable Ventures | Nuon Renewable Ventures | NRV | Green Mountain Solar at Upper Kirby | USAPV003 | 19 | Nuon Renewable Ventures | Solar | 26410 |
| Renewable Ventures | Nuon Renewable Ventures | NRV | Green Mountain Solar at The Winston School | USAPV002 | 20 | Nuon Renewable Ventures | Solar | 26411 |
| The University of Texas - Houston | University of Texas - Houston | UTHSC | University Center Tower | University Center Tower | 42 | Rahsaan Arscott | Solar | No. 77027 |
| Aeolus Wind | Aeolus Wind, LLC | Aeolus Wind, LLC | North Texas | NA | 51 | Sarah Adams | Wind | NA |

Table 7-4: ERCOT REC Generator List – Landfill Gas

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|-------------------------------------|-------------------------------------|-------------------------------|--|---------------------|--------------------------------|--------------------------|-----------------|--|
| Bio Energy (Texas), LLC | Bio Energy (Texas) LLC | 32079 | Covel Gardens Landfill Gas Power Station | DG_MEDIN | 61 | John M. Love | Landfill gas | 20140 |
| Cromeco, Inc. | Cromeco, Inc. | Cromeco, Inc. | Cromeco, Inc. | Cromeco, Inc. | 76 | Steve Cromeens | Landfill gas | 29520 |
| Fortistar | G2 Energy (FW Regional) LLC | 77-998-1765 | DG_RDLML_1 Unit | FW Regional | 64 | John Bean | Landfill gas | 32558 |
| G2 Energy (Trinity Oaks) LLC | G2 Energy (Trinity Oaks) LLC | 828961529 | Trinity Oaks LFG Generating Facility | DG_KLBRG | 136 | Massimo Passini | Landfill gas | 36679 |
| Gas Recovery Systems, Inc. | Gas Recovery Systems | 20066 | Sunset Farms Electric | | 37 | Paul Hesson | Landfill gas | 24199 |
| Renovar Arlington, Ltd. | Renovar Arlington, Ltd. | Rnvr-1 | Village Creek | Vcreek | 53 | Lisette Cowger | Landfill gas | 31083 |
| Renovar Arlington, Ltd. | Renovar Arlington, Ltd. | Rnvr-2 | Village Creek | Vcreek | 54 | Lisette Cowger | Landfill gas | 31083 |
| Viridis Energy, LP - Baytown | Viridis Energy, LP - Baytown | 01-62-16561 | BAYTOWN | TRM | 33 | Mr Luong Nguyen | Landfill gas | 26811 |
| Viridis Energy, LP - Blue Bonnet | Viridis Energy, LP - Blue Bonnet | 93-01-27472 | BLUE BONNET | LB | 34 | Mr Luong Nguyen | Landfill gas | 26809 |
| Viridis Energy, LP - Coastal Plains | Viridis Energy, LP - Coastal Plains | 93-01-16145 | COASTAL PLAINS | ALVIN | 32 | Mr Luong Nguyen | Landfill gas | 26812 |
| Viridis Energy, LP - Conroe | Viridis Energy, LP - Conroe | Conroe | Conroe | Conroe | 35 | Mr Luong Nguyen | Landfill gas | 26808 |
| Viridis Energy, LP - Security | Viridis Energy, LP - Security | SECURITY | SECURITY | SECURITY | 36 | Mr Luong Nguyen | Landfill gas | 26810 |
| Viridis Energy, LP Atascocita | Viridis Energy, LP - Atascocita | 93-01-87393 | ATASCOCITA | HB | 29 | Mr Luong Nguyen | Landfill gas | 26813 |
| WM Renewable Energy, LLC | WM Renewable Energy, L.L.C. | Skyline | Skyline | DG_FERIS | 83 | Scott Burnell | Landfill gas | 20161 |
| WM Renewable Energy, LLC | WM Renewable Energy II, LLC | Austin | Austin | DG_SPRIN | 95 | Steven Korsgaard | Landfill gas | 20161 |

Table 7-5: ERCOT REC Generator List – Wind

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|---|--|---------------------------------|---|---------------------|--------------------------------|--------------------------|-----------------|--|
| American Wind Power Center | American Wind Power Center | Lubbock | AWPC | AWPC#1 | 60 | Coy F. Harris | Wind | 32470 |
| Brazos Wind, LP | Brazos Wiind LP | Brazos Wind | Green Mountain Energy Wind Farm at Brazos | BRAZ_WND1 | 44 | Scott McBride | Wind | 29025 |
| Brazos Wind, LP | Brazos Wind LP | Brazos Wind | Green Mountain Energy Wind Farm at Brazos | BRAZ_WND2 | 45 | Scott McBride | Wind | 29025 |
| Buffalo Gap Wind Farm 2, LLC | Buffalo Gap Wind Farm 2, LLC | 603768792 | Buffalo Gap Wind Farm | BUFF_GAP | 81 | William Barnes | Wind | 33477 |
| Buffalo Gap Wind Farm 3, LLC | Buffalo Gap Wind Farm 3, LLC | Buffalo Gap Wind Farm 3, LLC | Buffalo Gap Wind Farm | BUFF_GAP | 110 | Fang Qing | Wind | 35247 |
| Buffalo Gap Wind Farm LLC | Buffalo Gap Wind Farm, LLC | Buffalo Gap | Buffalo Gap Wind Farm | Buffalo Gap | 56 | Gabe Vaca | Wind | 31412 |
| Bull Creek Wind LLC | Bull Creek Wind LLC | Bull Creek Wind LLC | Bull Creek Wind LLC | Bull Creek Wind LLC | 131 | Michael Adcock | Wind | 36239 |
| Callahan Divide | FPL Energy Callahan Divide | 30385 | Callahan Wind Energy | 30385 | 55 | David Gonzalez | Wind | 30385 |
| Capricorn Ridge Wind II, LLC | Capricorn Ridge Wind II, LLC | CR4 | CR4 | CR4 | 114 | Daniel Sexton | Wind | 20210 |
| Capricorn Ridge Wind, LLC | Goat Mountain Wind LP | Goat Mountain Wind | Capridge | Capridge | 93 | Garson Knapp | Wind | 34549 |
| Champion Wind Farm, LLC | Airtricity Champion Wind Farm, LLC | 242 | Champion Wind Farm | TKWSW | 99 | Audrey Fogarty | Wind | 20182 |
| Delaware Mountain Wind Farm LP | DELAWARE MOUNTAIN WIND FARM LP | 16 | DELAWARE MOUNTAIN | DELAWARE | 9 | Linda Brandi | Wind | 23705 |
| Desert Sky Wind Farm 1 LP | Indian Mesa Power Partners I, L.P. | 999 | Indian Mesa I Wind Power | INDNENR | 16 | Richard Walker | Wind | 24921 |
| Desert Sky Wind Farm 2 LP | Indian Mesa Power Partners II, L.P. | 999 | Indian Mesa II Wind Power | INDNENR | 17 | Richard Walker | Wind | 24922 |
| ECR Panther Creek Wind Farm I and II, LLC | ECR Panther Creek Wind Farm I, LLC. | 259 | PANTHER CREEK | PC_NORTH | 113 | Crystal Walton | Wind | 20208 |
| ECR Panther Creek Wind Farm I and II, LLC | EC and R Panther Creek Wind Farm II, LLC | 259 | PANTHER CREEK | PC_SOUTH | 126 | Dean Tuel | Wind | 35779 |
| ECR Panther Creek Wind Farm III, LLC | ECR Panther Creek Creek Wind Farm III, LLC | PANTHER3 | PANTHER3 | PANTHER3 | 141 | Dean Tuel | Wind | 20239 |
| EI Paso Electric Company | EI Paso Electric | EPE | Hueco Mountain Wind Ranch | EPE1 | 1 | Monica Garcia | Wind | 23631 |
| Elbow Creek Wind Project, LLC | Elbow Creek Wind Project LLC | Elbow Creek | Elbow Creek | Elbow Creek | 127 | Scott McBride | Wind | Elbow Creek |
| Forest Creek Wind Farm, LLC | Airtricity Forest Creek Wind Farm, LLC | 210 | Forest Creek Wind Farm | MCDLD | 74 | John Franklin | Wind | 20166 |
| FPL Energy Horse Hollow II, LP | FPL Energy Horse Hollow II, LP | Horse Hollow II | Horse Hollow II | Horse Hollow II | 69 | John Mantyh | Wind | 32524 |
| FPL Energy Upton Wind I, L.P. | FPL Energy Upton Wind I, LP | 94 | KING MOUNTAIN SW | KING_SW | 6 | Jesse Nevarez | Wind | Unknown |
| FPL Energy Upton Wind II, LP | FPL Energy Upton Wind II, LP | 96 | KING MOUNTAIN NW | KING_NW | 7 | Jesse Nevarez | Wind | Unknown |
| FPL Energy Upton Wind IV, LP | FPL Energy Upton Wind IV, LP | 96 | KING MOUNTAIN SE | KING_SE | 15 | Jesse Nevarez | Wind | Unknown |

Table 7-5: ERCOT REC Generator List – Wind (cont.)

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|----------------------------------|---|----------------------------------|----------------------------------|----------------------------------|--------------------------------|--------------------------|-----------------|--|
| FPL Pecos Wind 1 LP, LLC | FPL Pecos Wind I & II, LP | 93 | WOODWARD1 | WOODWRD1 | 2 | Jesse Nevarez | Wind | Unknown |
| FPL Pecos Wind 2 LP, LLC | FPL Energy Pecos Wind I&II, LP | 93 | WOODWARD 2 | WOODWRD2 | 8 | Jesse Nevarez | Wind | 24296 |
| Goat Wind, LP | Goat Wind, LP | 809226603 | GOAT WIND LP | GOAT WIND | 98 | Johnny Johnson | Wind | 35439 |
| Hackberry Wind, LLC | Hackberry Wind LLC | HWFLLC | Hackberry Wind Farm | HWF | 124 | Matthew Burt | Wind | 20185 |
| High Plains Wnd Power LLC | High Plains Wind Power LLC | 20197 | High Plains Wind Power | High Plains Wind Power | 111 | Steven Maller | Wind | 34994 |
| Iberdrola Renewables, Inc. | Barton Chapel Wind LLC | Barton Chapel | Barton Chapel | Barton Chapel | 138 | Bobby Clark | Wind | 36825 |
| Iberdrola Renewables, Inc. | Penascal Wind Power LLC | Penascal | Penascal | Penascal | 139 | Dan Pitts | Wind | 36829 |
| Inadale Wind Farm, LLC | Inadale Wind Farm, LLC | Inadale Wind Farm, LLC | Inadale Wind Farm, LLC | INDL_INADALE1 | 134 | Dean Tuel | Wind | 36500 |
| Indian Mesa, L.P. | NWP INDIAN MESA WIND FARM LP | 17 | INDIAN MESA NWP | INDNNWP | 10 | Linda Brandi | Wind | 23745 |
| JD Wind 1 | JD Wind 1 | 20137 | JD Wind 1 | JD Wind 1 | 65 | Steve Maller | Wind | 32802 |
| JD Wind 10 LLC | JD Wind 10 | 20195 | JD Wind 10 | JD Wind 10 | 106 | Steven Maller | Wind | 34992 |
| JD Wind 11 LLC | JD Wind 11 | 20196 | JD Wind 11 | JD Wind 11 | 107 | Steven Maller | Wind | 34993 |
| JD Wind 2 | JD Wind 2 | 20138 | JD Wind 2 | JD Wind 2 | 66 | Steve Maller | Wind | 32803 |
| JD Wind 3 | JD Wind 3 | 20139 | JD Wind 3 | JD Wind 3 | 67 | Steve Maller | Wind | 32804 |
| JD Wind 4 | JD Wind 4 | 20153 | JD Wind 4 | JD Wind 4 | 75 | Steven Maller | Wind | 33760 |
| JD Wind 5 | JD Wind 5 | 20154 | JD Wind 5 | JD Wind 5 | 71 | Steven Maller | Wind | 32912 |
| JD Wind 6 | JD Wind 6 | 20155 | JD Wind 6 | JD Wind 6 | 72 | Steven Maller | Wind | 32913 |
| JD Wind 7 LLC | JD Wind 7 | 20193 | JD Wind 7 | JD Wind 7 | 108 | Steven Maller | Wind | 34990 |
| JD Wind 8 LLC | JD Wind 8 | 20194 | JD Wind 8 | JD Wind 8 | 105 | Steven Maller | Wind | 34991 |
| JD Wind 9 LLC | JD Wind 9 | 20189 | JD Wind 9 | JD Wind 9 | 104 | Steve Maller | Wind | 34924 |
| Llano Estacado | Llano Estacado Wind Ranch at White Deer | Shell | White Deer | White Deer Wind | 18 | Craig Dencklau | Wind | 23633 |
| Majestic Wind Power LLC | Majestic Wind Power LLC | Majestic Wind Power LLC | Majestic Wind Power | Majestic Wind Power | 117 | Kim Takayesu | Wind | 35871 |
| McAdoo Wind Energy LLC | McAdoo Wind Energy LLC | McAdoo Wind | McAdoo Wind Energy Center | MWEC | 119 | Scott Ebner | Wind | 35935 |
| Mesquite Wind, LLC | Mesquite Wind LLC | Horizon Wind | Horizon Wind | Horizon Wind | 68 | Brian Hayes | Wind | 32936 |
| Noble Great Plains Windpark, LLC | Noble Great Plains Windpark, LLC | Noble Great Plains Windpark, LLC | Noble Great Plains Windpark, LLC | Noble Great Plains Windpark, LLC | 120 | Harry Silton | Wind | 20227 |
| Notrees Windpower, LP | Notrees Windpower LP | Notrees | Notrees Windfarm | NWF | 137 | Jason Allen | Wind | 36350 |
| Ocotillo Windpower, LP | Ocotillo Windpower LP | Ocotillo Windpower | Ocotillo Windfarm | OWF | 122 | Jason Allen | Wind | 35453 |

Table 7-5: ERCOT REC Generator List – Wind (cont.)

| Company Name | Name Of Power Generating Company | Power Generating Company Code | Generator Site Name | Generator Site Code | Facility Identification Number | Unit Contact Information | Technology Type | Facility Noncompetitive Certification Data |
|-----------------------------------|--|-------------------------------|---------------------------------|---------------------|--------------------------------|------------------------------------|-----------------|--|
| Post Oak Wind, LLC | Post Oak Wind | Post Oak Wind | Post Oak Wind | Post Oak Wind | 78 | Brian Hayes | Wind | 33801 |
| Post Wind Farm LP | Post Wind Farm, LP | Post Wind | Post Wind | Post Wind | 70 | John Cote | Wind | 32525 |
| PYCO Industries, Inc. | PYCO Industries, Inc. | 70047 | PYCO Industries Plant #2 | 2 | 125 | PYCO Industries, Inc. Wind Farm | Wind | 36175 |
| Pyron Wind Farm, LLC | Pyron Wind Farm, LLC | Pyron Wind Farm, LLC | Pyron Wind Farm, LLC | PYR_PYRON1 | 135 | Dean Tuel | Wind | 36501 |
| Roscoe Wind Farm, LLC | Airtricity Roscoe Wind Farm, LLC | 243 | Roscoe Wind Farm | TKWSW1 | 100 | Audrey Fogarty | Wind | 20180 |
| Sand Bluff Wind Farm, LLC | Airtricity Sand Bluff Wind Farm, LLC | 211 | Sand Bluff Wind Farm | MCDLD | 77 | Phil Dutton | Wind | 20165 |
| Scurry County Wind II LLC | Scurry County Wind II LLC | scurry county wind II | Camp Springs Energy Center | CSEC | 101 | Scott Ebner | Wind | 35290 |
| Scurry County Wind, L.P. | Scurry County Wind, L.P. | scurry county wind | Camp Springs Energy Center | CSEC | 80 | Scott Ebner | Wind | 33902 |
| Sherbino I Wind Farm LLC | Sherbino I Wind Farm, LLC | 20220 | Sherbino I Wind Farm | KEO | 121 | James Holly | Wind | 35887 |
| Silver Star I Power Partners, LLC | Silver Star I Power Partners LLC | 20186 | Silver Star Wind | FLTCK | 123 | James C Holly | Wind | 35551 |
| Snyder Wind Farm, LLC | Snyder Wind Farm, LLC | 20187 | Snyder Wind Farm | ENAS | 96 | Eric Barreveld | Wind | 34754 |
| South Trent Wind LLC | South Trent Wind LLC | 35778 | South Trent Wind Farm | STWF | 115 | Kim Takayesu | Wind | 35750 |
| Sunray Wind, LLC | Sunray Wind, LLC | 20234 | Sunray Wind, LLC Wind Farm | Sunray Wind, LLC | 132 | William Root | Wind | 36672 |
| Sweetwater Wind Power LLC | Sweetwater Wind power LLC | 137899477 | Sweetwater Wind 1 | SWEETWND | 43 | Kim Takayesu | Wind | 28924 |
| Sweetwater Wind Power LLC | Sweetwater Wind Power | Sweet Wind 2 | Sweetwater Wind 2 | SWEETWND2 | 52 | Kim Takayesu | Wind | 30462 |
| Sweetwater Wind Power LLC | Sweetwater Wind Power | 603943148 | Sweetwater Wind 3 LLC AE | SWEETWND3 | 58 | Kim Takayesu | Wind | 31983 |
| Sweetwater Wind Power LLC | Sweetwater Wind Power | 603943148-3000 | Sweetwater Wind 3 LLC CPS | SWEETWND3 | 59 | Kim Takayesu | Wind | 31983 |
| Sweetwater Wind Power LLC | Sweetwater Wind 4 LLC | Sweetwater Wind 4 | Sweetwater Wind 4 LLC | Sweetwater Wind 4 | 79 | Kim Takayesu | Wind | 34058 |
| Sweetwater Wind Power LLC | Sweetwater Wind 5 LLC | Sweetwater Wind 5 | Sweetwater Wind 5 LLC | SWEETWN5 | 82 | Kim Takayesu | Wind | 34709 |
| Texas Gulf Wind LLC | Texas Gulf Wind LLC | Texas Gulf Wind LLC | Texas Gulf Wind LLC | TGW | 112 | Kim Takayesu | Wind | 35810 |
| Texas State Technical College | Texas State Technical College West Texas | TSTC | TSTC West Texas | DG ROSC2 | 133 | Ray Fried | Wind | 20240 |
| Trent Wind Farm, L.P. | Trent Wind Farm, L.P. | 70 | TRENT MESA WIND FARM | TRENT | 5 | Richard Walker | Wind | 24322 |
| Turkey Track Wind Energy LLC | Turkey Track Wind Energy LLC | Turkey Track Wind | Turkey Track Wind Energy Center | TTWEC | 128 | Scott Ebner | Wind | 36369 |
| Upton Wind III, LP | FPL Energy Upton Wind III, LP | 96 | KING MOUNTAIN NE | KING_NE | 14 | Jesse Nevarez | Wind | 20063 |
| Whirlwind Energy, LLC | Whirlwind Energy, LLC | WELLCC | Whirlwind Energy Center | WEC | 103 | Matthew Burt | Wind | 20172 |
| Wolf Ridge Wind, LLC | Wolf Ridge Wind, LLC | C41483 | WOLF RIDGE | WLFRIDGE | 129 | Rory Robinson | Wind | 36015 |

Table 7-6: Electricity Generation by Renewable Sources (MWh, ERCOT: 2001 – 2008 by Quarter)

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|-----------------|------|-----------|-----------|-----------|-----------|-----------|
| Biomass | 2001 | | | | | |
| Hydro | 2001 | | | | | |
| Landfill gas | 2001 | | | | | |
| Solar | 2001 | 0 | 0 | 11293 | 19346 | 30639 |
| Wind | 2001 | 0 | 0 | 201,118 | 364,479 | 565,597 |
| Totals | | 0 | 0 | 212,411 | 383,825 | 596,236 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|-----------------|------|-----------|-----------|-----------|-----------|-----------|
| Biomass | 2002 | | | | | |
| Hydro | 2002 | 105,817 | 69,165 | 80,154 | 56,956 | 312,093 |
| Landfill gas | 2002 | 8,216 | 7,073 | 6,986 | 7,137 | 29,412 |
| Solar | 2002 | 0 | 29 | 37 | 21 | 87 |
| Wind | 2002 | 611,708 | 716,896 | 622,262 | 500,618 | 2,451,484 |
| Totals | | 725,741 | 793,163 | 709,439 | 564,732 | 2,793,076 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|-----------------|------|-----------|-----------|-----------|-----------|-----------|
| Biomass | 2003 | 8,876 | 11,253 | 10,999 | 8,368 | 39,496 |
| Hydro | 2003 | 92,680 | 52,592 | 71,699 | 22,713 | 239,684 |
| Landfill gas | 2003 | 29,995 | 44,629 | 39,920 | 39,662 | 154,206 |
| Solar | 2003 | 32 | 70 | 69 | 49 | 220 |
| Wind | 2003 | 561,994 | 670,248 | 617,794 | 665,446 | 2,515,482 |
| Totals | | 693,577 | 778,792 | 740,481 | 736,238 | 2,949,088 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|-----------------|------|-----------|-----------|-----------|-----------|-----------|
| Biomass | 2004 | 6,274 | 11,459 | 11,482 | 7,725 | 36,940 |
| Hydro | 2004 | 55,638 | 52,735 | 52,350 | 74,067 | 234,791 |
| Landfill gas | 2004 | 52,801 | 47,964 | 53,659 | 49,018 | 203,443 |
| Solar | 2004 | 31 | 67 | 70 | 44 | 211 |
| Wind | 2004 | 815,010 | 1,014,396 | 610,157 | 770,066 | 3,209,629 |
| Totals | | 929,755 | 1,126,621 | 727,718 | 900,920 | 3,685,014 |

Table 7-6: Electricity Generation by Renewable Sources (MWh, ERCOT: 2001 – 2008 by Quarter) – (cont.)

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|------------------------|-------------|------------------|------------------|------------------|------------------|------------------|
| Biomass | 2005 | 13,921 | 15,069 | 14,764 | 14,883 | 58,637 |
| Hydro | 2005 | 108,974 | 106,893 | 61,189 | 33,246 | 310,302 |
| Landfill gas | 2005 | 52,118 | 51,193 | 56,166 | 54,301 | 213,777 |
| Solar | 2005 | 46 | 69 | 67 | 46 | 227 |
| Wind | 2005 | 801,232 | 1,246,182 | 869,508 | 1,304,646 | 4,221,568 |
| Totals | | 976,291 | 1,419,406 | 1,001,694 | 1,407,122 | 4,804,511 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|------------------------|-------------|------------------|------------------|------------------|------------------|------------------|
| Biomass | 2006 | 16,327 | 10,479 | 17,152 | 16,610 | 60,569 |
| Hydro | 2006 | 55,000 | 83,064 | 44,870 | 27,143 | 210,077 |
| Landfill gas | 2006 | 69,191 | 78,650 | 75,665 | 82,580 | 306,087 |
| Solar | 2006 | 26 | 43 | 41 | 26 | 136 |
| Wind | 2006 | 1,478,927 | 1,584,166 | 1,376,540 | 2,091,295 | 6,530,928 |
| Totals | | 1,619,471 | 1,756,402 | 1,514,268 | 2,217,654 | 7,107,797 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|------------------------|-------------|------------------|------------------|------------------|------------------|------------------|
| Biomass | 2007 | 13,052 | 15,061 | 11,991 | 11,720 | 51,823 |
| Hydro | 2007 | 66,084 | 120,486 | 139,965 | 56,346 | 382,882 |
| Landfill gas | 2007 | 84,367 | 86,372 | 85,612 | 99,987 | 356,339 |
| Solar | 2007 | 339.1 | 502.73 | 541.03 | 461.03 | 1,844 |
| Wind | 2007 | 1,961,152 | 2,029,806 | 2,020,869 | 3,327,929 | 9,339,756 |
| Totals | | 2,124,994 | 2,252,228 | 2,258,979 | 3,496,444 | 10,132,645 |

| Technology Type | Year | Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 | Total MWh |
|------------------------|-------------|------------------|------------------|------------------|------------------|------------------|
| Biomass | 2008 | 21,154 | 14,019 | 12,564 | 23,095 | 70,833 |
| Hydro | 2008 | 98,510 | 177,051 | 78,751 | 91,116 | 445,428 |
| Landfill gas | 2008 | 105,217 | 97,361 | 88,470 | 95,558 | 386,606 |
| Solar | 2008 | 446 | 862 | 992 | 1038 | 3,338 |
| Wind | 2008 | 4,030,973 | 4,737,188 | 2,639,509 | 4,878,713 | 16,286,383 |
| Totals | | 4,256,300 | 5,026,481 | 2,820,287 | 5,089,520 | 17,192,589 |

Table 7-7: Electricity Generation by Renewable Sources (MWh, ERCOT: 2001 – 2008 by Quarter)

| Technology Type | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 |
|-----------------|---------|-----------|-----------|-----------|-----------|-----------|------------|------------|
| Wind | 565,597 | 2,451,484 | 2,515,482 | 3,209,629 | 4,221,568 | 6,530,928 | 9,339,756 | 16,286,383 |
| Hydro | | 312,093 | 239,684 | 234,791 | 310,302 | 210,077 | 382,882 | 445,428 |
| Landfill gas | | 29,412 | 154,206 | 203,443 | 213,777 | 306,087 | 356,339 | 386,606 |
| Biomass | | | 39,496 | 36,940 | 58,637 | 60,569 | 51,823 | 70,833 |
| Solar | | 87 | 220 | 211 | 227 | 136 | 1,844 | 3,338 |
| Totals | 565,597 | 2,793,076 | 2,949,088 | 3,685,014 | 4,804,511 | 7,107,797 | 10,132,645 | 17,192,588 |




Figure 7-1: Electricity Generation by Renewable Sources (ERCOT: 2001 – 2008 Annual)




Figure 7-2: Electricity Generation by Renewable Sources Other Than Wind (ERCOT: 2001 – 2008 Annual)




Figure 7-3: Electricity Generation by Renewable Sources from Solar and Biomass (ERCOT: 2001 – 2008 Annual)

8 COMBINED HEAT AND POWER PROJECTS IN TEXAS

Texas leads the United States in Combined Heat and Power (CHP) applications, which is also known as cogeneration. About 23% of all CHP generation capacity in the US is located in Texas¹¹. This capacity produces 20% of the electricity in Texas¹². In Texas, typical power plants built by electric utilities are steam plants that are 25% - 35% efficient. The natural gas combined cycle power plants operate at about 50% efficiency. CHP technologies generate electrical and thermal energy in a single, integrated system close to the point of customer energy demand. A typical CHP system consists of a prime mover to generate electricity, a heat recovery system to capture heat, a control system, an exhaust system, and an acoustic enclosure. The thermal energy recovered in a CHP system can be used for heating or cooling in industry or buildings. Thus, CHP facilities are a major energy conservation technique with a high efficiency falling to the 70% - 85% range.

As of 2007, 16,829 MW of CHP technologies were integrated into infrastructure served by the Texas electrical grid according to the database maintained by DOE and Oak Ridge National Laboratory. Table 8-1 summarizes all of the CHP projects that began operation from 1921 to 2007 in Texas¹³, including the operation year, capacity, city located, type of prime mover and type of primary fuel, etc., for each CHP project. A report from Summit Blue Consulting LLC (Summit Blue Consulting LLC, 2008) identified 135 facilities currently operating CHP systems capable of generating 17,333 MW of power as of 2008. Figure 8-1 shows the map of existing CHP installations in Texas provided in the same report.

The ESL is working on developing a procedure to calculate annually creditable NOx emissions reductions from CHP facilities for the State Implementation Plan (SIP) credits. As part of this work, the ESL has sent a survey form to many CHP facilities in the Texas and is currently waiting for responses. Figure 8-2 shows the details of this survey form. Once the ESL gets the response back from the CHP facilities, the work on calculating annually creditable NOx emission reductions will be initiated and the results will be included in the future report when ready.

¹¹ USDOE, Energy Information Agency (EIA), 2005 data

¹² USDOE, Energy Information Agency (EIA), 2006 data

¹³ Information obtained from the website of Energy and Environmental Analysis Inc.

<http://www.eea-inc.com/chpdata/States/TX.html>




Figure 8-1: Map of Existing CHP Installations in Texas

(Source: "Combined Heat and Power in Texas: Status, Potential, and Policies to Foster Investment",
Summit Blue Consulting LLC, December 2008.)

Figure 8-2: ESL CHP Survey Form

| About Currently Installed System | | | | About Displaced System | | | |
|--|--|--|--|--|--|--|--|
| 1 Type of system: <input type="radio"/> Recip Engine- Rich burn <input type="radio"/> Recip Engine- Lean Burn <input type="radio"/> Recip Engine- Diesel <input type="radio"/> Microturbine <input type="radio"/> Combustion Turbine <input type="radio"/> Back Pressure Steam Turbine <input type="radio"/> Fuel Cell <input type="radio"/> Others <input type="text"/> | | | | Displaced Thermal: 1. Type of system: <input type="radio"/> Gas Boiler <input type="radio"/> Distillate oil boiler <input type="radio"/> Residual oil boiler <input type="radio"/> Coal Boiler <input type="radio"/> Propane Boiler <input type="radio"/> Electric Resistance or Heat pump <input type="radio"/> Others <input type="text"/> | | | |
| 2 Electricity generating capacity: <input type="text"/> kW/ Unit | | | | 2. Generating efficiency of the displaced boiler: <input type="text"/> % | | | |
| 3 Number of identical units in system: <input type="text"/> | | | | Displaced Cooling: 1. Type of system | | | |
| 4 How many hours per year does the CHP system operate? Average number of hours per year <input type="text"/> | | | | 2. Efficiency of the cooling system: COP: <input type="text"/> or kW/ton: <input type="text"/> | | | |
| 5 Does the CHP provide Heating or Cooling or both? <input type="radio"/> Heating Only <input type="radio"/> Cooling Only <input type="radio"/> Heating and Cooling If heating and cooling: How many of the total hours are in cooling mode? Average number of hours per year <input type="text"/> | | | | <input type="radio"/> Roof Top Unit <input type="radio"/> Reciprocating Compressor, Air Cooled <input type="radio"/> Rotary Screw Compressor, Air Cooled <input type="radio"/> Centrifugal Compressor, Water Cooled <input type="radio"/> Others <input type="text"/> | | | |
| If heating and cooling: Does the system provide Simultaneous Heating and Cooling? <input type="radio"/> Yes <input type="radio"/> No | | | | | | | |
| 6 Fuel type: <input type="radio"/> Natural Gas <input type="radio"/> Diesel Fuel <input type="radio"/> Distillate Oil <input type="radio"/> Coal <input type="radio"/> Propane <input type="radio"/> Biomass <input type="radio"/> Other (Including Renewables) | | | | General Information | | | |
| 7 Electricity generating efficiency: <input type="text"/> % | | | | Company Name: <input type="text"/> | | | |
| 8 Base power to heat ratio: Power to Heat Ratio <input type="text"/> | | | | Address: <input type="text"/> | | | |
| 9 Does the system incorporate Duct Burners? <input type="radio"/> Yes <input type="radio"/> No If Yes, a) What is the total fuel input capacity of the burners for each CHP unit? <input type="text"/> MMBtu/hr | | | | Contact Person: <input type="text"/> | | | |
| b) During the hours the CHP is operating, how much do the duct burners operate? As the percentage of CHP operating hours <input type="text"/> % | | | | Email Address: <input type="text"/> | | | |
| If Applicable: | | | | Phone Number: <input type="text"/> | | | |
| 10 Type of absorption chiller used and its Coefficient of Performance: Type <input type="text"/> COP <input type="text"/> | | | | Note: The collected information in this survey will be kept confidential and will not be disclosed. It will be only used for the purposes of the determination, as state/county, of the emissions reduction that the CHP technology provides. | | | |
| 11 Cooling capacity of the system: <input type="text"/> Cooling Tons | | | |  Energy Systems Laboratory Texas Engineering Experiment Station Texas A&M University | | | |

Table 8-1: CHP units located in Texas as of 2007

| State | City | Organization Name | Facility Name | Application | Op Year | Prime Mover | Capacity (kw) | Fuel Type | SIC4 | NAICS |
|-------|-------------------|---|--|------------------------|---------|-------------|---------------|-----------|------|--------|
| TX | Freeport | Dow Chemical | Dow Chemical Freeport Energy Center | Chemicals | 2007 | CC | 224,000 | NG | 2819 | 325188 |
| TX | Pineland | Temple Inland | Temple Inland | Wood Products | 2007 | B/ST | 978 | WOOD | 2421 | 321113 |
| TX | Austin | Dell Childrens Hospital | Dell Childrens Hospital | Hospitals/Healthcare | 2006 | CT | 4,600 | NG | 8062 | 62211 |
| TX | Fort Worth | Kaufman County Paper Recycling | Paper Recycling | Solid Waste Facilities | 2006 | CT | 4,000 | NG | 4953 | 562212 |
| TX | Galveston | Moody Gardens | Moody Gardens | Museums/Zoos | 2005 | FCEL | 200 | NG | 8422 | 71213 |
| TX | Snyder | Kinder Morgan Production Company | EG178 Facility / Snyder Gas Plant | Oil/Gas Extraction | 2005 | CC | 132,000 | NG | 1311 | 211111 |
| TX | Austin | Austin Energy | Domain Industrial Park | Misc. Manf. | 2004 | CT | 5,000 | NG | 3999 | 339999 |
| TX | Texas City | South Houston Green Power LP / Green Power 2 / Cinergy | BP Texas City Refinery | Refining | 2004 | CC | 580,000 | NG | 2911 | 32411 |
| TX | Deer Park | Calpine - Deer Park Energy Center | Shell Chemical Company | Refining | 2003 | CC | 792,000 | NG | 2911 | 32411 |
| TX | Addis | Calpine - Central LP | Baytown Energy Center LP / Bayer Corporation | Refining | 2002 | CC | 913,000 | NG | 2911 | 32411 |
| TX | Corpus Christi | Calpine - Corpus Christi Energy Center | Citgo Refining | Refining | 2002 | CC | 523,000 | NG | 2911 | 32411 |
| TX | Channelview | Reliant Energy Power OPS II Inc | Reliant Energy Channelview LP / Equistar | Chemicals | 2001 | CT | 293,000 | NG | 2800 | 325 |
| TX | Deer Park | BP Amoco Chemicals Company / INEOS Olefins & Polymers | BP Solvay Polyethylene North America | Refining | 2001 | CT | 20,000 | OTR | 2911 | 32411 |
| TX | Fort Worth | Arlington Landfill | Village Creek Municipal WWTP | Wastewater Treatment | 2001 | CT | 10,600 | BIO MASS | 4952 | 22132 |
| TX | Harrison | Calpine - Channel Energy Center | Lyondell-CITGO Refining L.P. | Refining | 2001 | CC | 527,000 | NG | 2911 | 32411 |
| TX | Longview | Eastex CoGeneration LP | Eastex Cogeneration Facility / Eastman Chemical | Chemicals | 2001 | CC | 467,700 | NG | 2800 | 325 |
| TX | Orange | SRW Cogeneration LP | SRW Cogeneration Limited Partnership / Conoco Global/ DuPont | Chemicals | 2001 | CC | 420,000 | NG | 2800 | 325 |
| TX | Port Arthur | BASF Corp | NROC Cogeneration Facility | Chemicals | 2001 | CT | 83,200 | NG | 2899 | 325998 |
| TX | Baytown | LCY Elastomers / Enichem Americas, Inc. | LCY Elastomers | Chemicals | 2000 | CT | 5,300 | NG | 2800 | 325 |
| TX | El Paso | Leviton Manufacturing Inc | Leviton Manufacturing Co | Electronics | 2000 | ERENG | 1,800 | OIL | 3612 | 335311 |
| TX | Gregory | LG&E Power Inc./Gregory Power Partners | Reynolds Metals Sherwin Alumina Plant | Chemicals | 2000 | CC | 412,000 | NG | 2819 | 325188 |
| TX | Orange | E.I. Du Pont De Nemours & Company | Du Pont Sabine River Works | Chemicals | 2000 | CC | 220,000 | NG | 2800 | 325 |
| TX | Port Arthur | Premcor Refining Group / Air Products And Chemicals, Inc. | Clark Refining & Marketing / Premcor | Refining | 2000 | CC | 40,600 | NG | 2911 | 32411 |
| TX | Port Arthur | BASF / Fina Petrochemicals LP | Steam Cracker Cogen Project | Refining | 2000 | CT | 70,900 | NG | 2911 | 32411 |
| TX | Borger | Borger Energy Associates LP | Black Hawk Station | Chemicals | 1999 | CT | 253,800 | NG | 2869 | 325199 |
| TX | Freeport | BASF Corp | Freeport Project | Chemicals | 1999 | CC | 86,700 | NG | 2819 | 325188 |
| TX | Gregory/Ingleside | Occidental Energy Ventures & Conoco Global Power | Ingleside Cogeneration Facility | Chemicals | 1999 | CC | 440,000 | NG | 2869 | 325199 |
| TX | Sabine | Reliant Energy / Air Liquide / Bayer | Bayer Corporation Rubber Plant | Rubber/Plastics | 1999 | CC | 100,000 | NG | 3039 | 326299 |
| TX | Houston | Toshiba Manufacturing | Manufacturing Facility | Misc. Manf. | 1998 | FCEL | 200 | NG | 3900 | 339999 |
| TX | Pasadena | Calpine - Pasadena I & II | Chevron/Philips Petroleum | Chemicals | 1998 | CC | 751,000 | NG | 2800 | 325 |
| TX | San Antonio | Lackland AFB Hospital | Lackland AFB Hospital | Hospitals/Healthcare | 1998 | CT | 10,400 | NG | 8062 | 62211 |
| TX | Sweeny | Sweeny Cogeneration LP | Phillips Sweeny Complex | Refining | 1998 | CT | 470,000 | NG | 2911 | 32411 |
| TX | Cleburne | Tenaska IV Texas Partners Ltd. | Steam Host Is Distilled Water | Chemicals | 1996 | CC | 267,000 | NG | 2899 | 325998 |
| TX | El Paso | R.E. Thomason Hospital | Thomason Hospital Central Plant | Hospitals/Healthcare | 1996 | ERENG | 2,400 | NG | 8062 | 62211 |
| TX | Texas City | Union Carbide Corporation | Union Carbide Chemicals & Plastics Co | Chemicals | 1996 | CC | 84,500 | NG | 2821 | 325211 |
| TX | Deer Park | Houston Lighting & Power | Dupont Cogeneration Project | Chemicals | 1995 | CC | 162,000 | NG | 2869 | 325199 |
| TX | Freeport | Dow Chemical USA. - Texas Division | Oyster Creek Project | Chemicals | 1994 | CC | 424,000 | NG | 2819 | 325188 |
| TX | Pecos | Freeport McMoran | Freeport McMoran | Refining | 1994 | CT | 5,200 | NG | 2911 | 32411 |
| TX | Dallas | Dallas County | Lew Sterrett/North Tower Cogen Facility | General Gov't | 1993 | CT | 1,000 | NG | 9111 | 92111 |
| TX | Port Neches | Air Liquide America | Port Neches Plant | Chemicals | 1993 | CT | 41,200 | NG | 2813 | 32512 |
| TX | Port Neches | Huntsman Petrochemicals | JCO Oxides Olefins Plant | Chemicals | 1993 | CT | 71,260 | NG | 2819 | 325188 |
| TX | Fort Worth | Kimmon Quartz Ltd. | Fossil Creek Project | Stone/Clay/Glass | 1992 | ERENG | 550 | NG | 3211 | 327211 |
| TX | Seminole | Union Oil Company of California/Unocal | North Riley Unit | Refining | 1992 | ERENG | 2,000 | NG | 2911 | 32411 |
| TX | Texas City | S&L Cogeneration | S&L Cogeneration | Chemicals | 1992 | CC | 52,000 | NG | 2813 | 32512 |
| TX | Alvin | Solutia, Inc. | Chocolate Bayou Plant | Chemicals | 1990 | B/ST | 55,300 | NG | 2899 | 325998 |
| TX | Austin | Texas Department Of Mental Health | Austin State Hospital | Hospitals/Healthcare | 1990 | CT | 2,200 | NG | 8062 | 62211 |

Table 8-1: CHP units located in Texas as of 2007 (cont.)

| State | City | Organization Name | Facility Name | Application | Op Year | Prime Mover | Capacity (kw) | Fuel Type | SIC4 | NAICS |
|-------|---------------------|--|---|----------------------|---------|-------------|---------------|-----------|------|--------|
| TX | Beaumont | E.I. Du Pont De Nemours & Company | Beaumont Petrochemical Plant | Chemicals | 1990 | CT | 33,800 | NG | 2822 | 325212 |
| TX | Houston | Valero Refing Co. / Hill Petroleum Company | Hill Petroleum Refinery | Refining | 1990 | CT | 16,200 | NG | 2911 | 32411 |
| TX | Houston | ICC Technologies, Inc. | Aire-Technics, Inc. | Machinery | 1990 | ERENG | 150 | NG | 3569 | 333999 |
| TX | Lubbock | City of Lubbock | Brandon | Utilities | 1990 | CT | 21,000 | NG | 4939 | 221112 |
| TX | Lubbock | Texas Tech University | Texas Tech University | Colleges/Univ. | 1990 | B/ST | 935 | NG | 8221 | 61131 |
| TX | South Padre Island | American Private Power, Inc. | 310 Padre Boulevard | Hotels | 1990 | ERENG | 240 | OIL | 7011 | 72111 |
| TX | Baytown | Exxon Chemical Company | Exxon Baytown Olefins Plant | Refining | 1989 | CC | 439,500 | NG | 2911 | 32411 |
| TX | Corpus Christi | CCPC Chemical, Inc. / Occidental | CCPC Chemical, Inc. | Chemicals | 1989 | CT | 37,880 | NG | 2824 | 325222 |
| TX | Corpus Christi | Equistar Chemicals LP | Corpus Christi Plant | Refining | 1989 | CT | 45,000 | NG | 2911 | 32411 |
| TX | Houston | Rice University | Rice University Power Plant | Colleges/Univ. | 1989 | CC | 7,000 | NG | 8221 | 61131 |
| TX | Paris | Tenaska III Texas Partners | Campbell Soup (Texas), Inc. | Food Processing | 1989 | CC | 223,000 | NG | 2032 | 311422 |
| TX | Port Lavaca | BP Amoco Chemicals Company | BP Chemicals Green Lake Plant | Refining | 1989 | B/ST | 35,000 | OTR | 2911 | 32411 |
| TX | San Marcos | Southwest Texas State University | Southwest Texas State University | Colleges/Univ. | 1989 | ERENG | 6,000 | NG | 8221 | 61131 |
| TX | Austin | Minnesota Mining & Manufacturing Co. | 3M Research Development & Admin. Center | Office Buildings | 1988 | ERENG | 14,300 | NG | 6512 | 53112 |
| TX | Corpus Christi | Koch Refining Company | Koch Refining Company | Refining | 1988 | CT | 49,000 | NG | 2911 | 32411 |
| TX | Denton | American Private Power, Inc. | Sheraton Hotel, 2211 I35 East North | Hotels | 1988 | ERENG | 115 | NG | 7011 | 72111 |
| TX | Denver City | BP Amoco Chemicals Company | Wasson Field Cogeneration Facility (II) | Chemicals | 1988 | CT | 20,660 | NG | 2813 | 32512 |
| TX | Fort Worth | Alcon Laboratories, Inc. | Alcon Laboratories, Inc. | Primary Metals | 1988 | CT | 3,500 | NG | 3300 | 331 |
| TX | Houston | Shell Oil Company | Westhollow Technology Center | Oil/Gas Extraction | 1988 | CT | 3,725 | NG | 1311 | 211111 |
| TX | Mont Belvieu | Chevron USA., Inc. | Warren Petroleum Company | Oil/Gas Extraction | 1988 | CT | 10,000 | NG | 1311 | 211111 |
| TX | Port Arthur | Fina Oil & Chemical Company | Fina Oil & Chemical Company | Refining | 1988 | CC | 37,130 | NG | 2911 | 32411 |
| TX | Waco | Baylor University | Baylor University | Colleges/Univ. | 1988 | CT | 3,300 | NG | 8221 | 61131 |
| TX | Beaumont | Goodyear Tire & Rubber Company | Beaumont/East Chemical Plant | Chemicals | 1987 | CC | 23,000 | NG | 2822 | 325212 |
| TX | Big Springs | Power Resources, Inc. | Fina Oil & Chemical/American Petrofina | Refining | 1987 | CC | 200,000 | NG | 2911 | 32411 |
| TX | El Paso | Tenet Hospital Ltd | Providence Memorial Hospital | Hospitals/Healthcare | 1987 | ERENG | 4,200 | NG | 8062 | 62211 |
| TX | Liberty Hill | Gabriel Mills Energy Company | Greenhouse Project | Agriculture | 1987 | ERENG | 2,000 | NG | 182 | 111419 |
| TX | Pasadena | Air Products & Chemicals, Inc. | Air Products Manufacturing Corp | Chemicals | 1987 | CT | 3,460 | NG | 2816 | 325131 |
| TX | Point Comfort | Formosa Plastics Corporation, USA | Point Comfort Project | Chemicals | 1987 | CC | 524,800 | NG | 2821 | 325211 |
| TX | Texas City | Texas City Cogeneration. | Union Carbide - Texas City Plant | Chemicals | 1987 | CC | 450,000 | NG | 2869 | 325199 |
| TX | Victoria | E.I. Du Pont De Nemours & Company | Du Pont Nylon/Polyethylene Plant | Chemicals | 1987 | CT | 75,000 | NG | 2821 | 325211 |
| TX | Wichita Falls | Wichita Falls Energy Company | Vetrotex/Certainteed Corporation | Stone/Clay/Glass | 1987 | CC | 80,000 | NG | 3229 | 327212 |
| TX | Yates | Marathon | Marathon | Refining | 1987 | CT | 5,600 | NG | 2911 | 32411 |
| TX | Big Spring | Fina Oil & Chemical Company | Big Spring Texas Refinery | Refining | 1986 | B/ST | 1,500 | NG | 2911 | 32411 |
| TX | Borger | Sid Richardson Carbon & Gas Company | Sid Richardson Carbon & Gas Company | Chemicals | 1986 | B/ST | 30,000 | WAST | 2895 | 325182 |
| TX | El Paso | Phelps Dodge Corporation | Phase II Cogeneration Facility | Primary Metals | 1986 | CT | 19,600 | NG | 3331 | 331411 |
| TX | El Paso | Bruce Foods Corporation | Ashley's Division | Food Processing | 1986 | ERENG | 220 | NG | 2033 | 311421 |
| TX | El Paso | Hospital Corporation Of America | Vista Hills Medical Center | Hospitals/Healthcare | 1986 | ERENG | 180 | NG | 8062 | 62211 |
| TX | Houston | Uncle Ben's, Inc. | Uncle Ben's Rice | Food Processing | 1986 | B/ST | 1,000 | BIOMASS | 2044 | 311212 |
| TX | Pasadena | AES Corporation | AES Deepwater Inc | Chemicals | 1986 | B/ST | 143,000 | WAST | 2869 | 325199 |
| TX | Alvin | BP Amoco Chemicals Company | Chocolate Bayou Facility | Refining | 1985 | CT | 36,300 | NG | 2911 | 32411 |
| TX | Channelview/Houston | Cogen Lyondell, Inc. | ARCO Chemicals/Lyondell Petrochemical | Refining | 1985 | CC | 564,000 | NG | 2911 | 32411 |
| TX | Gilmer | Dean Lumber Company | Dean Lumber Company | Wood Products | 1985 | B/ST | 540 | WOOD | 2421 | 321113 |
| TX | Pasadena | Clear Lake Cogeneration L.P. / Calpine | Hoechst Celanese Chemical Company | Chemicals | 1985 | CC | 345,000 | NG | 2821 | 325211 |
| TX | Texas City | South Houston Green Power / BP-Amoco Oil Company | Amoco Oil Company/Power 4 | Refining | 1985 | CC | 170,000 | NG | 2911 | 32411 |
| TX | Corpus Christi | Coastal Refining & Marketing | Coastal Refining & Marketing Inc | Refining | 1984 | CT | 46,800 | NG | 2911 | 32411 |

Table 8-1: CHP units located in Texas as of 2007 (cont.)

| State | City | Organization Name | Facility Name | Application | Op Year | Prime Mover | Capacity (kw) | Fuel Type | SIC4 | NAICS |
|-------|-----------------|---|--|--------------------|---------|-------------|---------------|-----------|------|--------|
| TX | Mt. Belvieu | Enterprise Products Company | Enterprise Products Company | Refining | 1984 | CT | 25,700 | NG | 2911 | 32411 |
| TX | Pasadena | Crown Central Petroleum Corporation | Crown Central Petroleum Corporation | Refining | 1984 | B/ST | 6,000 | WAST | 2911 | 32411 |
| TX | Pasadena | Air Liquide America Corp | Bayou Cogeneration Plant | Chemicals | 1984 | CT | 300,000 | NG | 2813 | 32512 |
| TX | Sundown | BP Amoco Chemicals Company | Mallet Cogeneration Facility | Oil/Gas Extraction | 1984 | CT | 18,000 | NG | 1311 | 211111 |
| TX | Borger | Engineered Carbons, Inc. | Engineered Carbons Division | Chemicals | 1983 | B/ST | 20,000 | WAST | 2895 | 325182 |
| TX | Corpus Christi | Valero Refining Company | Saber Refining | Refining | 1983 | B/ST | 67,700 | WAST | 2911 | 32411 |
| TX | Marshall | Snider Industries, Inc | Snider Industries Inc | Wood Products | 1983 | B/ST | 5,000 | WOOD | 2421 | 321113 |
| TX | Port Arthur | Port Arthur Steam Energy / Great Lakes Carbon Corp | Premcor Refining Group | Refining | 1983 | B/ST | 15,000 | WAST | 2911 | 32411 |
| TX | Port Lavaca | Carbide/Graphite Group Inc | Seadrift Coke LP | Refining | 1983 | B/ST | 7,600 | WAST | 2911 | 32411 |
| TX | Bishop | Hoechst Celanese Corporation | Hoechst Celanese Corporation | Chemicals | 1982 | CC | 44,200 | NG | 2823 | 325221 |
| TX | Deer Park | Owl Energy Resources Inc / Oxy Vinyls | Houston Chemical Complex Battleground Site | Chemicals | 1982 | CC | 270,000 | NG | 2810 | 325998 |
| TX | Houston | Texas Petrochemicals Corp | Texas Petrochemicals Houston Plant | Refining | 1982 | B/ST | 35,000 | NG | 2911 | 32411 |
| TX | Richardson | University Of Texas System | University Of Texas At Dallas | Colleges/Univ. | 1980 | ERENG | 3,500 | NG | 8221 | 61131 |
| TX | San Antonio | University Of Texas System | University Of Texas At San Antonio | Colleges/Univ. | 1980 | ERENG | 3,500 | NG | 8221 | 61131 |
| TX | Pampa | Hoechst Celanese Corporation | Celanese Pampa Plant | Chemicals | 1979 | B/ST | 30,000 | COAL | 2821 | 325211 |
| TX | Dallas | Lone Star Energy/Enserch/TXU | Univ. Of Texas Health Science Center | Colleges/Univ. | 1978 | ERENG | 4,600 | NG | 8221 | 61131 |
| TX | Port Arthur | Chevron USA., Inc. | Chevron's Port Arthur Refinery | Refining | 1975 | CC | 62,000 | NG | 2911 | 32411 |
| TX | Santa Rosa | Rio Grande Valley Sugar Growers | Rio Grande Valley Sugar Growers | Food Processing | 1973 | B/ST | 7,500 | BIOMASS | 2061 | 311311 |
| TX | Texarkana | International Paper Company | Texarkana Mill | Pulp and Paper | 1972 | B/ST | 65,000 | WAST | 2621 | 322121 |
| TX | Houston | Rhone Poulenc Chemical Company | Houston Facility | Chemicals | 1970 | B/ST | 7,500 | NG | 2834 | 325412 |
| TX | Orange | Inland-Orange, Inc. | Orange Pulp & Paper Mill | Pulp and Paper | 1967 | B/ST | 49,000 | WAST | 2652 | 322213 |
| TX | Hereford | Holly Sugar Corporation | Holly Sugar Corporation | Food Processing | 1965 | B/ST | 4,100 | NG | 2063 | 311313 |
| TX | Seadrift | Seadrift Cogeneration | Union Carbide Corporation | Chemicals | 1964 | CC | 156,000 | NG | 2813 | 32512 |
| TX | Taft | Arco Oil & Gas Company | Taft Gasoline Plant | Refining | 1964 | CT | 1,400 | NG | 2911 | 32411 |
| TX | Texas City | BP Amoco Chemicals Company | Texas City Refinery Facility | Refining | 1964 | CC | 117,900 | NG | 2911 | 32411 |
| TX | Texas City | Hill Petroleum Company | Hill Petroleum Company | Refining | 1963 | CT | 16,200 | NG | 2911 | 32411 |
| TX | Dallas | Rock Tenn Company | Rock Tenn Company | Pulp and Paper | 1959 | B/ST | 4,000 | NG | 2631 | 32213 |
| TX | Bridgeport | Liquid Energy | Liquid Energy | Refining | 1958 | ERENG | 1,520 | NG | 2911 | 32411 |
| TX | Point Comfort | Alcoa World Alumina LLC | Point Comfort Operations | Chemicals | 1958 | B/ST | 63,100 | NG | 2819 | 331311 |
| TX | Beaumont | ExxonMobil Corp | Mobil Beaumont Refinery | Refining | 1957 | B/ST | 600,000 | NG | 2911 | 32411 |
| TX | Port Arthur | Star Enterprise | Texaco Refining And Marketing Inc. | Refining | 1957 | CC | 158,200 | NG | 2911 | 32411 |
| TX | Evadale | Westvaco / Temple-Inland Forest Products Corporatin | Evandale Pulp & Paperboard | Pulp and Paper | 1954 | B/ST | 48,200 | WAST | 2631 | 32213 |
| TX | Corpus Chritsi | Reynolds Metals Co | Reynolds Metals Co Sherwin Plant | Primary Metals | 1953 | B/ST | 39,000 | OTR | 3341 | 331314 |
| TX | Corpus Christi | American Chrome & Chemicals Co | American Chrome & Chemicals Co | Chemicals | 1952 | B/ST | 610 | NG | 2819 | 325188 |
| TX | Freeport | Dow Chemical USA. - Texas Division | Energy Systems And Technical Services | Chemicals | 1952 | CC | 1,228,600 | NG | 2819 | 325188 |
| TX | Baytown | ExxonMobil Corp | Exxon Baytown Refinery | Refining | 1950 | B/ST | 160,000 | NG | 2911 | 32411 |
| TX | Grand Saline | Morton Salt Company | Morton Salt Company | Chemicals | 1949 | B/ST | 3,990 | NG | 2899 | 325998 |
| TX | Deer Park | Shell Oil Company | Shell Manufacturing Complex | Refining | 1943 | CC | 250,000 | NG | 2911 | 32411 |
| TX | College Station | Texas A&M University | Cogeneration Facility | Colleges/Univ. | 1935 | CT | 40,000 | NG | 8221 | 61131 |
| TX | Austin | University Of Texas At Austin | University Of Texas At Austin | Colleges/Univ. | 1933 | CC | 120,000 | NG | 8221 | 61131 |
| TX | Marshall | Norit Americas Inc | Norit Americas Inc.Marshall Plant | Chemicals | 1921 | B/ST | 2,000 | COAL | 2810 | 325998 |

9 REPORTING OF NOX EMISSIONS CREDITS TO THE TCEQ (PRELIMINARY)

9.1 Introduction

The Energy Systems Laboratory (Laboratory), at the Texas Engineering Experiment Station of the Texas A&M University System, in fulfillment of its responsibilities under Texas Health and Safety Code Ann. § 388.003 (e), Vernon Supp. 2002, submits this sixth annual report, Energy Efficiency/Renewable Energy (EE/RE) Impact in the Texas Emissions Reduction Plan (Preliminary Report) to the Texas Commission on Environmental Quality.

In this preliminary report, the NOx emissions savings from the energy-efficiency programs from multiple Texas State Agencies working under Senate Bill 5 and Senate Bill 7 in a uniform format to allow the TCEQ to consider the combined savings for Texas' State Implementation Plan (SIP) planning purposes. This required that the analysis should include the cumulative savings estimates from all projects projected through 2020 for both the annual and Ozone Season Day¹⁴ (OSD) NOx reductions. The NOx emissions reduction from all these programs were calculated using estimated emissions factors for 2007 from the US Environmental Protection Agency (US EPA) eGRID database, which had been specially prepared for this purpose.

In 2008, the cumulative total annual electricity savings from all programs is 20,380,240 MWh/year (12,727 tons-NOx/year). The total cumulative OSD electricity savings from all programs is 48,602 MWh/day, which would be a 2,025 MW average hourly load reduction during the OSD period (31.38 tons-NOx/day). By 2013, the total cumulative annual electricity savings will be 32,736,151 MWh/year (20,395 tons-NOx/year). The total cumulative OSD electricity savings from all programs will be 80,866 MWh/day, which would be a 3,369 MW average hourly load reduction during the OSD period (52.10 tons-NOx/day). A summary of the savings for 2008 and 2013 is presented in the table below.

| | 2008 | 2013 |
|---|------------|------------|
| Annual Electricity Savings (MWh/yr) | 20,380,240 | 32,736,151 |
| Annual Emissions reductions (tons NOx/yr) | 12,727 | 20,395 |
| OSD Electricity Savings (MWh/day) | 48,602 | 80,866 |
| OSD Emissions reductions (tons NOx/day) | 31.38 | 52.10 |

¹⁴ An ozone season day (OSD) represents the daily average emissions during the period that runs from mid-July to mid -September.

9.2 Legislative Background

In 2001, the Texas Emissions Reduction Plan (TERP), established by the 77th Texas Legislature with the enactment of Senate Bill 5 (SB 5), identified that Energy Efficiency and Renewable Energy (EE/RE) measures make an important contribution to a comprehensive approach for meeting the minimum federal ambient air quality standards. In 2003 through 2007, the 78th, 79th and 80th Legislatures enhanced the use of EE/RE programs for meeting the TERP. The 78th Legislature enhanced the use of EE/RE programs for meeting TERP goals by requiring the Texas Commission on Environmental Quality (TCEQ) to promote EE/RE as a means to improve air quality standards and to develop a methodology for computing emissions reduction for use in the State Implementation Plan (SIP) from EE/RE programs.

The 79th Legislature expanded the scope of the SIP-eligible credits by adding savings from the State Renewable Portfolio Standards from the generation of electricity from renewable sources; specifically requiring the TCEQ to develop methods to quantify emissions reductions from renewable energy; and required the Laboratory to develop at least 3 alternative methods for achieving a 15 percent greater potential energy savings in residential, commercial and industrial construction. In the 80th Legislature several new energy efficiency initiatives were introduced, including: requiring the Laboratory to provide written recommendations to the State Energy Conservation Office (SECO) about whether or not the energy efficiency provisions of latest published edition of the International Residential Code (IRC), or the International Energy Conservation Code (IECC), are equivalent to or better than the energy efficiency and air quality achievable under the editions adopted under the 2001 IRC/IECC; requiring the Laboratory to develop a standardized report format to be used by providers of home energy ratings; and encouraging the Laboratory to cooperate with an industry organization or trade association to develop guidelines for home energy ratings, including training.

9.3 Calculation of Integrated NOx Emissions Reductions from Multiple State Agencies Participating in the Texas Emissions Reduction Plan (TERP)

In January 2005, the Laboratory was asked by the Texas Commission on Environmental Quality (TCEQ) to develop a method by which the NOx emissions savings from the energy-efficiency programs from multiple Texas State Agencies working under Senate Bill 5 and Senate Bill 7 could be reported in a uniform format to allow the TCEQ to consider the combined savings for Texas' State Implementation Plan (SIP) planning purposes. This required that the analysis should include the cumulative savings estimates from all projects projected through 2020 for both the annual and Ozone Season Day (OSD) NOx reductions. The NOx emissions reduction from all these programs were calculated using estimated emissions factors for 2007 from the US Environmental Protection Agency (US EPA) eGRID database, which had been specially prepared for this purpose. The different programs included in the 2006 cumulative analysis are:

- ESL Single-family new construction
- ESL Multi-family new construction
- ESL Commercial new construction
- Federal Buildings
- Furnace Pilot Light Program
- PUC Senate Bill 7 and Senate Bill 5 Program
- SECO Senate Bill 5 Program
- Electricity generated by wind farms in Texas (ERCOT)¹⁵
- SEER13 upgrades to Single-family and Multi-family residences

The Laboratory's single-family and multi-family programs include the energy savings attained by constructing new residences in Texas according to the IECC 2000/2001 building code (IECC 2000). The baseline for comparison for the code programs is the published data on residential construction characteristics by the National Association of Home Builders (NAHB) for 1999 (NAHB 1999). Annual

¹⁵ ERCOT is the Electric Reliability Council of Texas.

electricity (MWh) and natural gas (MBtu) savings are from the Laboratory's Annual Reports to the TCEQ (Haberl et al., 2002 - 2007).

The Texas Public Utility Commission's (PUC) Senate Bill and Senate Bill 7 programs include their incentive and rebates programs managed by the different Utilities for Texas (PUC 2007). These include the Residential Energy Efficiency Programs (REEP) as well as the Commercial & Industrial Standard Offer Programs (C&I SOP). The energy efficiency measures include high efficiency HVAC equipment, variable speed drives, increased insulation levels, infiltration reduction, duct sealing, Energy Star Homes, etc. Annual electricity savings according to the utilities (or Power Control Authorities – PCAs) were reported for the different programs completed in the years 2001 through 2008. The PUC also reported the savings from the Senate Bill 5 grant program which was conducted in 2002 and 2003.

The Texas State Energy Conservation Office (SECO) funds energy-efficiency programs are directed towards school districts, government agencies, city and county governments, private industries and residential energy consumers. For the 2008 reporting year SECO submitted annual energy savings values for 149 projects, which included projects funded by SECO and by Energy Service projects.

The Electric Reliability Council of Texas (ERCOT) electricity production from currently installed green power generation (wind) in Texas is reported. Projections through 2013 include planned projects by ERCOT, annual growth factors beyond 2013 comply with the Legislative requirements. Actual measured electricity production for 2001 through 2008, were included.

Finally, NOx emissions reductions from several other programs are also reported, including: *energy efficiency measures applied to Federal buildings in Texas, reductions from the elimination of pilot lights in residential furnaces, and reductions from the installation of SEER 13 air conditioners in existing residences.*

9.4 Description of the Analysis Method

Annual and Ozone Season Day (OSD) NOx emissions reduction were calculated for 2008 and cumulatively from 2006 to 2020 using several factors to discount the potential savings. These factors include an annual degradation factor, a transmission and distribution factor, a discount factor and growth factors as shown in Table 9-1, and are described as follows:

Annual degradation factor: This factor was used to account for an assumed decrease in the performance of the measures installed as the equipment wears down and degrades. With the exception of electricity generated from wind, an annual degradation factor of 5% was used for all the programs¹⁶. This value was taken from a study by Kats et al. (1996).

Transmission and distribution loss: This factor adjusts the reported savings to account for the loss in energy resulting from the transmission and distribution of the power from the electricity producers to the electricity consumers. For this calculation, the energy savings reported at the consumer level are increased by 7% to give credit for the actual power produced that is lost in the transmission and distribution system on its way to the customer. In the case of electricity generated by wind, the T&D losses were assumed to cancel out since wind energy is displacing power produced by conventional power plants; therefore, there is no net increase or decrease in T&D losses.

Initial discount factor: This factor was used to discount the reported savings for any inaccuracies in the assumptions and methods employed in the calculation procedures. For the Laboratory's single- and multi-family program, the discount factor was assumed to be 20%. For PUC's Senate Bill 5 and Senate Bill 7

¹⁶ A degradation of 5% per year would accumulate as a 5%, 10%, 15%...etc, degradation in performance. Although the assumption of this high level of degradation may not actually occur, it was chosen as a conservative estimate. For wind energy, a degradation factor of 0% was used. The choice of a 0% degradation factor for wind is based on two year's of analysis of measured wind data from all Texas wind farms that shows no degradation, on average, for a two year period after the wind farms became operational.

programs and electricity from wind, the discount factor was taken as 25%. For the savings in the SECO program, the discount factor was 60%.

Growth factor: The growth factors shown in Table 9-1 were used to account for several different factors. Growth factors for single-family (3.25%) and multi-family residential (1.54%) construction are projections based on the average growth rate for these housing types from recent U.S. Census data for Texas. Growth factors for wind energy are from the Texas Public Utilities Commission¹⁷. No growth was assumed for Federal buildings, pilot lights, PUC programs and SECO entries.

Figure 9-1 shows the overall information flow that was used to calculate the NOx emissions savings from the annual and Ozone Season Day (OSD) electricity savings (MWh) from all programs. For the Laboratory's single-family and multi-family code-implementation programs, the annual and ozone season savings were calculated from DOE-2 hourly simulation models¹⁸. The base case is taken as the average characteristics of single- and multi-family residences for Texas published by the National Association of Home Builders for 1999 (NAHB 1999). The OSD consumption is the average daily consumption for the period between July 15 and September 15, 1999. The annual electricity savings from PUC programs were calculated using deemed savings tables and spreadsheets created for the utilities incentive programs by Frontier Associates in Austin, Texas (PUC 2007).

The SECO electricity savings were submitted as annual savings by project¹⁹. A description of the measures completed for the project was also submitted for information purposes. The electricity production from wind farms in Texas was from the actual on-site metered data measured at 15-minute intervals.

Integration of the savings from the different programs into a uniform format allowed for creditable NOx emissions to be evaluated using different criteria as shown in Table 9-1. These include evaluation across programs, evaluation across individual counties by program, evaluation by SIP area, evaluation for all ERCOT counties except Houston/Galveston, and evaluation within a 200 km radius of Dallas/Ft. Worth.

9.5 Calculation Procedure

ESL Single-family and Multi-family. The calculation of the annual and OSD electricity savings reported for the years 2002 through 2008 included the savings from code-compliant new housing in all 41 non-attainment and affected counties as reported in the Laboratory's annual report submitted by the Laboratory to the Texas Commission of Environmental Quality (TCEQ). The savings for 2001 were also incorporated, since some of the programs were reporting savings from September to December 2001. From 2005 to 2008, the annual and OSD electricity savings were calculated for new residential construction in all the counties in ERCOT region, which includes the 41 non-attainment and affected counties. These savings were then tabulated by county and program. Using the calculated values through 2008, savings were then projected to 2020 by incorporating the different adjustment factors mentioned above.

In these calculations, it was assumed that the same amount of electricity savings from the code-complaint construction would be achieved for each year after 2008 through 2020²⁰. The projected energy savings through 2020, according to county, were then divided into the different Power Control Authorities (PCA) in eGRID. To determine which PCA was to be used, or in counties with multiple PCA, the allocation to each PCA by county was obtained from PUC's listing published in the Laboratory's 2005 annual report²¹.

¹⁷ The growth factors for wind energy through 2012 are based on permitted wind farms registered with the Texas Public Utilities Commission, http://www.puc.state.tx.us/electric/maps/gen_tables.xls. Growth factors for 2013 through 2020 assume a linear projection based on the permits for 2011 and 2012.

¹⁸ These values are based on a performance analysis as defined by Chapter 4 of IECC 2000/2001. This analysis is discussed in the Laboratory's annual reports to the TCEQ.

¹⁹ The reporting requirements to the SECO did not require energy savings by project type, although for selected sites, energy savings by project type was available. Annual savings were reported by SECO in 2004. Values for 2005 to 2007 use the adjusted values from 2004 as shown, www.seco.cpa.state.tx.us.

²⁰ This would include the appropriate discount and degradation factors for each year.

²¹ Haberl et al., 2005, pp. 197.

For the 2008 annual and OSD NOx emissions calculations, the US EPA's 2007 eGRID were used²². An example of the eGRID spreadsheet²³ is given in Table 9-2. The total electricity savings for each PCA were used to calculate the NOx emissions reduction for each of the different counties using the emissions factors contained in eGRID. Similar calculations were performed for each year for which the analysis was required. The cumulative NOx emissions reduction for the electricity savings from residential new construction for 2006 through 2020 is provided in Table 9-3. NOx emissions reduction is provided in Table 9-4.

ESL-Commercial Buildings. The annual and OSD electricity savings for 2002 through 2008 for commercial buildings were obtained from the annual reports for 2005 and 2007 submitted by the Laboratory to TCEQ²⁴. These savings were also tabulated by county and program. Using the calculated values through 2008, savings were then projected to 2020 by incorporating the different adjustment factors mentioned above²⁵. In the projected 2008 cumulative electricity savings, it was assumed that the same amount of electricity savings from 2008 would be achieved for each year after 2008 through 2020. Similarly to the single family calculations, the projected energy saving numbers through 2020, by county, were allocated into the appropriate Power Control Authorities (PCA).

Federal Buildings. Energy savings achieved from Energy Savings Performance Contracts (ESPCs) were also reported in 2008. This includes savings (estimated) from energy conservation measures implemented in Federal Buildings in Texas. The 2008 savings include projects implemented in 14 Federal buildings reported by the regional office of the Department of Energy. Annual kWh savings reported for each of the projects were divided by 365 to obtain the average Ozone Season Day savings²⁶. In the calculation for 2008, it was assumed that the electricity savings from 2006 would also be achieved for each year from 2008 through 2020 after the appropriate degradation factors were applied. Similarly to the single family calculations, the projected energy saving numbers through 2020, by county, were proportioned into the PUC's Power Control Authorities (PCA) and the cumulative NOx emission reduction values calculated.

Furnace Pilot Light Program. For the furnace pilot light program savings, the N.G. energy savings achieved by retrofitting existing furnaces in single-family and multi-family residences for the entire residential stock for Texas have been projected until 2020. Pilot light removal saves an estimated 500 Btu/hr of natural gas for each hour of operation for the entire life of the furnace when the furnace is replaced with a code-compliant replacement. The energy savings for the Ozone Season Day are calculated by dividing the annual number by 365. It is also being assumed that of the total furnaces that were retrofitted, 75% are operational during the Ozone Season Period. Cumulative NOx emissions reduction for the N.G. savings from the removal of furnace pilot lights were also calculated by county for 2006 through 2020 by SIP area²⁷.

PUC-Senate Bill 7. For the PUC Senate Bill 7 program savings, the annual electricity savings for 2001 through 2008 were obtained from the Public Utilities Commission²⁸. Using these values savings were

²² This required two separate versions of the 2007 eGRID, which were specially prepared for Texas by Mr. Art Diem at the US EPA. One of the versions contains estimates of annual SOx, NOx and CO2 data for 2007, using a 25% capacity factor. The second version contains estimates of SOx, NOx and CO2 data for 2007 for an average day in the ozone season period, which runs from Mid July to Mid September.

²³ To use this spreadsheet electricity savings for each PCA is entered in the bottom row of the spreadsheet (MWh). The spreadsheet then allocates the MWh of electricity savings according to the counties (blue columns) where the PCA owned and operated a power plant. Totals for all PCAs are then listed on the far right columns (white columns). Similar spreadsheets for the 2007 eGRID exist for SOx and CO2.

²⁴ These savings include new construction in office, assembly, education, retail, food, lodging and warehouse construction as defined by Dodge building type (Dodge 2005), using energy savings from the Pacific Northwest National Laboratory (USDOE 2004), and data from CBECS (1995 - 2003).

²⁵ This also includes the appropriate discount and degradation factors for each year.

²⁶ This method yields suitable OSD values for lighting retrofits and/or retrofits that are not weather dependent. In the case of retrofits to cooling systems, weather normalization would increase the OSD savings substantially. Retrofits to heating systems would be reduced by weather normalization.

²⁷ These use the NOx/MBtu values provided in the US EPA AP 42 guideline.

²⁸ In a similar fashion to the previous programs, to obtain the Ozone Season Day (OSD) savings, the annual electricity savings were divided by 365.

projected through 2020 by incorporating the different adjustment factors mentioned above. Similar savings were assumed for each year after 2008 until 2020. The 2008 annual and OSD eGRID was also used to calculate the NOx emissions savings for the PUC-Senate Bill 7 program. The total electricity savings for each PCA was used to calculate the NOx emissions reduction for each county using the emissions factors contained in the US EPA's eGRID spreadsheet. The cumulative NOx emissions reduction for each county, by SIP area, for the different programs was then calculated.

PUC-Senate Bill 5 Grants Program. To calculate the annual electricity savings from the PUC's Senate Bill 5 program, electricity savings were also obtained from the Public Utilities Commission²⁹. The annual and average day electricity savings were then proportioned according to the PCA and program. Using the actual reported numbers through 2008, savings through 2020 were projected incorporating the different adjustment factors mentioned above³⁰. The 2008 annual and OSD eGRID were used to calculate the NOx emissions savings for PUC-Senate Bill 5 Grants Program. The total electricity savings for each PCA were used to calculate the NOx emissions reduction for each of the different counties.

SECO Savings. The annual electricity savings from energy conservation projects reported by political subdivisions for 35 counties through 2008 were obtained from the State Energy Conservation Office³¹. These submittals included information gathered from SECO's website³² and paper submittals³³. The annual and average day electricity values were then summarized according to county and program. Using the actual reported numbers for 2004, savings through 2020 were projected using the different adjustment factors mentioned above. In a similar fashion to the previous programs, it was assumed that the same amount of electricity savings will be achieved for each year after 2005 until 2020. The 2008 annual and OSD eGRID were then used to calculate the NOx emissions savings for the SECO program.

Electricity Generated by Wind Farms. The measured electricity production from all the wind farms in Texas for 2001 through 2008 was obtained from the Energy Reliability Council of Texas (ERCOT). To obtain the annual production, the 15-minute data were summed for the 12 months, while for the OSD period the data were converted to average daily electricity production during the months of July, August and September. Using the reported numbers for 2008, savings through 2020 were projected incorporating the different adjustment factors mentioned above. The 2008 annual and OSD eGRID were then used to calculate the NOx emissions reduction for the electricity generated by Texas' wind farms³⁴. The total electricity savings for each PCA was used to calculate the NOx emissions reduction for each of the different counties.

SEER 13 Single-Family and Multi-family. In January of 2006, Federal regulations mandated that the minimum efficiency for residential air conditioners be increased to SEER 13 from the previous SEER 10. Although the electricity savings from new construction reflected this change in values, the annual and OSD electricity savings from the replacement of the air conditioning units by air conditioners with an efficiency of SEER 13 in existing residences needed to be calculated.

²⁹ In a similar fashion as the PUC's Senate Bill 7 program, the annual electricity savings numbers were then divided by 365 to get average electricity savings per day for OSD calculations. The preferred approach would be to weather-normalize the savings and then calculate savings for the OSD period. However, only annual values were obtained for the 2005 report to the TCEQ. Dividing the annual values by 365 is probably a reasonable approach for lighting projects. However, this undercounts potential savings from electric loads associated with the cooling season.

³⁰ Since the savings for the PUC's Senate Bill 5 were only reported for two years these savings actually reduced due to the imposed degradation factor.

³¹ In a similar fashion as the PUC's Senate Bill 5 and 7 programs, these annual electricity savings numbers were divided by 365 to get average electricity savings per day for the OSD calculations.

³² This web site was developed for SECO by the Laboratory, at the request of the TCEQ.

³³ In these submittals, there were several municipalities whose electricity or natural consumption increased in 2004 as compared to 2001, which caused the reported savings from these municipalities to be negative. Since no additional information was reported from these projects that might have indicated what the cause of this was, it was assumed that the energy conservation projects were working as designed, but that other factors had changed the energy consumption. Therefore, in the final values of electricity savings from the political subdivisions that reported to SECO for the calculation of annual and OSD NOx reductions, the negative savings were omitted.

³⁴ This credited the electricity generated by the wind farm to the utility that either owned the wind farm or was associated with the wind farm owner.

In the 2008 report to the TCEQ, the annual and OSD electricity savings for all the counties in ERCOT region as well as the 41 non-attainment and affected counties was calculated for the retrofit. Using the numbers for 2008, the savings through 2020 were projected by incorporating the appropriate adjustment factors³⁵. In this analysis it was assumed that an equal number of existing houses had their air conditioners replaced, as reported for 2007, by the air conditioner manufacturers. This replacement rate continued until all the existing air conditioner stock was replaced with SEER 13 air conditioners. The total electricity savings for each PCA were used to calculate the NOx emissions reduction for each of the different county using the emissions factors contained in the 2007 eGRID. Cumulative NOx emissions reduction for each county by SIP area was also calculated.

9.6 Results

The total cumulative annual and OSD electricity savings for all the different programs in the integrated format was calculated using the adjustment factors shown Table 9-1 for 2001 through 2020 as shown in Table 9-3. NOx emissions reduction from the electricity and natural gas savings for the annual and OSD for all the programs in the integrated format is shown in Table 9-4. In Table 9-3 and Table 9-4 annual values are shown for 2005, and cumulative annual values are shown 2006 through 2020. The OSD NOx emissions reduction is also shown in Figure 9-2 as stacked bar charts and in Figure 9-3 for the individual components.

In 2008 (Table 9-3), the cumulative annual electricity savings³⁶ from code-compliant residential and commercial construction is calculated to be 1,551,569 MWh/year (6.8% of the total electricity savings), savings from retrofits to Federal buildings is 206,960 MWh/year (0.9%), savings from furnace pilot light retrofits is 2,548,904 MBtu/year, savings from the PUC's Senate Bill 5 and Senate Bill 7 programs is 2,015,453 MWh/year (8.8%), savings from SECO's Senate Bill 5 program is 445,357 MWh/year (1.9%), electricity savings from green power purchases (wind) is 15,171,518 MWh/year (66.2%), and savings from residential air conditioner retrofits³⁷ is 989,385 MWh/year (4.3%). The total savings from all programs is 22,929,144 MWh/year.

In 2008, the cumulative OSD electricity savings from code-compliant residential and commercial construction is calculated to be 6,904 MWh/day (14.2%), savings from retrofits to Federal buildings is 567 MWh/day (1.2%), savings from furnace pilot light retrofits is 6,983 MBtu/day, savings from the PUC's Senate Bill 5 and Senate Bill 7 programs is 5,522 MWh/day (11.4%), savings from SECO's Senate Bill 5 program is 1,220 MWh/day (2.5%), electricity savings from green power purchases (wind) are 25,575 MWh/day (52.6%), and savings from residential air conditioner retrofits are 7,017 MWh/day (14.5%). The total savings from all programs is 48,602 MWh/day, which would be a 2,025 MW average hourly load reduction during the OSD period.

By 2013, the cumulative annual electricity savings from code-compliant residential and commercial construction is calculated to be 2,045,171 MWh/year (5.8% of the total electricity savings), savings from retrofits to Federal buildings will be 402,732 MWh/year (1.1%), savings from furnace pilot light retrofits will remain at 2,548,904 MBtu/year, savings from the PUC's Senate Bill 5 and Senate Bill 7 programs will be 3,527,334 MWh/year (10.0%), savings from SECO's Senate Bill 5 program will be 489,440 MWh/year (1.4%), electricity savings from green power purchases (wind) will be 23,985,240 MWh/year (68.0%), and savings from residential air conditioner retrofits³⁸ will be 2,286,233 MWh/year (6.5%). The total savings from all programs will be 35,285,055 MWh/year.

By 2013, the cumulative OSD electricity savings from code-compliant residential and commercial construction is calculated to be 12,110 MWh/day (15%), savings from retrofits to Federal buildings will be 1,103 MWh/day (1.4%), savings from furnace pilot light retrofits will remain at 6,983 MBtu/day, savings

³⁵ Additional details about this calculation are contained in the Laboratory's 2006 Annual Report to the TCEQ, available at the Senate Bill 5 web site "eslsb5.tamu.edu".

³⁶ This includes the savings from 2001 through 2008.

³⁷ This assumes air conditioners in existing homes are replaced with the more efficient SEER 13 units, versus an average of SEER 11, which is slightly more efficient than the previous minimum standard of SEER 10.

³⁸ This assumes air conditioners in existing homes are replaced with the more efficient SEER 13 units, versus an average of SEER 11, which is slightly more efficient than the previous minimum standard of SEER 10.

from the PUC's Senate Bill 5 and Senate Bill 7 programs will be 9,664 MWh/day (11.9%), savings from SECO's Senate Bill 5 program will be 1,341 MWh/day (1.7%), electricity savings from green power purchases (wind) will be 40,432 MWh/day (50.0%), and savings from residential air conditioner retrofits will be 16,216 MWh/day (20%). The total savings from all programs will be 80,866 MWh/day, which would be a 3,369 MW average hourly load reduction during the OSD period.

In 2008 (Table 9-4) the cumulative annual NOx emissions reduction³⁹ from code-compliant residential and commercial construction is calculated to be 1,091 tons-NOx/year (8.6% of the total NOx savings), savings from retrofits to Federal buildings is 158 tons-NOx/year (1.2%), savings from furnace pilot light retrofits is 117 tons-NOx/year (0.9%), savings from the PUC's Senate Bill 5 and Senate Bill 7 programs is 1,426 tons-NOx/year (11.2%), savings from SECO's Senate Bill 5 program is 340 tons-NOx/year (2.7%), electricity savings from green power purchases (wind) is 8,914 tons-NOx/year (70.0%), and savings from residential air conditioner retrofits is 682 tons-NOx/year (5.3%). The total NOx emissions reduction from all programs is 12,727 tons-NOx/year.

In 2008, the cumulative OSD NOx emissions reduction from code-compliant residential and commercial construction is calculated to be 6 tons-NOx/day (19.2%), savings from retrofits to Federal buildings is 0.42 tons-NOx/day (1.3%), savings from furnace pilot light retrofits is 0.32 tons-NOx/day (1.0%), savings from the PUC's Senate Bill 5 and Senate Bill 7 programs is 3.82 tons-NOx/day (12.1%), savings from SECO's Senate Bill 5 program is 0.92 tons-NOx/day (2.9%), electricity savings from green power purchases (wind) are 15.13 tons-NOx/day (48.2%), and savings from residential air conditioner retrofits are 4.77 tons-NOx/day (15.2%). The total NOx emissions reduction from all programs is 31.38 tons-NOx/day.

By 2013, the cumulative NOx emissions reduction from code-compliant residential and commercial construction is calculated to be 1,435 tons-NOx/year (7% of the total NOx savings), savings from retrofits to Federal buildings will be 308 tons-NOx/year (1.5%), savings from furnace pilot light retrofits will be 117 tons-NOx/year (0.6%), savings from the PUC's Senate Bill 5 and Senate Bill 7 programs will be 2,495 tons-NOx/year (12.2%), savings from SECO's Senate Bill 5 program will be 373 tons-NOx/year (1.8%), electricity savings from green power purchases (wind) will be 14,092 tons-NOx/year (69.1%), and savings from residential air conditioner retrofits will be 1,574 tons-NOx/year (7.7%). The total NOx emissions reduction from all programs will be 20,395 tons-NOx/year.

By 2013, the cumulative OSD NOx emissions reduction from code-compliant residential and commercial construction is calculated to be 8.32 tons-NOx/day (15.9%), savings from retrofits to Federal buildings will be 0.81 tons-NOx/day (1.6%), savings from furnace pilot light retrofits will be 0.32 tons-NOx/day (0.6%), savings from the PUC's Senate Bill 5 and Senate Bill 7 programs will be 6.69 tons-NOx/day (12.8%), savings from SECO's Senate Bill 5 program will be 1.01 tons-NOx/day (1.9%), electricity savings from green power purchases (wind) will be 23.92 tons-NOx/day (45.9%), and savings from residential air conditioner retrofits will be 11.03 tons-NOx/day (21.2%). The total NOx emissions reduction from all programs will be 52.10 tons-NOx/day.

9.7 Summary

This preliminary report the NOx emissions savings from the energy-efficiency programs from multiple Texas State Agencies working under Senate Bill 5 and Senate Bill 7 in a uniform format to allow the TCEQ to consider the combined savings for Texas' State Implementation Plan (SIP) planning purposes. This required that the analysis should include the cumulative savings estimates from all projects projected through 2020 for both the annual and Ozone Season Day⁴⁰ (OSD) NOx reductions. The NOx emissions reduction from all these programs were calculated using estimated emissions factors for 2009 from the US Environmental Protection Agency (US EPA) eGRID database, which had been specially prepared for this purpose.

³⁹ These NOx emissions reduction were calculated with the US EPA's 2007 eGRID for annual (25% capacity factor) and Ozone Season Day OSD.

⁴⁰ An ozone season day (OSD) represents the daily average emissions during the period that runs from mid-July to mid -September.

In 2008, the cumulative total annual electricity savings from all programs is 22,929,144 MWh/year (12,727 tons-NOx/year). The total cumulative OSD electricity savings from all programs is 48,602 MWh/day, which would be a 2,025 MW average hourly load reduction during the OSD period (31.38 tons-NOx/day). By 2013, the total cumulative annual electricity savings from will be 35,285,055 MWh/year (20,395 tons-NOx/year). The total cumulative OSD electricity savings from all programs will be 80,866 MWh/day, which would be a 3,369 MW average hourly load reduction during the OSD period (52.10 tons-NOx/day).

The Laboratory has and will continue to provide leading-edge technical assistance to counties and communities working toward obtaining full SIP credit for the energy efficiency and renewable energy projects that are lowering emissions and improving the air for all Texans. The Laboratory will continue to provide superior technology to the State of Texas through efforts with the TCEQ and US EPA. The efforts taken by the Laboratory have produced significant success in bringing EE/RE closer to US EPA acceptance in the SIP.

Table 9-1: Final Adjustment Factors used for the Calculation of the Annual and OSD NOx Savings for the Different Programs

| | ESL-Single Family ¹⁶ | ESL-Multifamily ¹⁶ | ESL-Commercial ¹⁶ | Federal Buildings ¹⁵ | Furnace Pilot Light Program ¹⁵ | PUC (SB7) ¹⁵ | PUC (SB5 Grant Program) ¹⁵ | SECO ¹⁵ | Wind-ERCOT ⁸ | SEER13 Single Family | SEER13 Multifamily |
|---|---------------------------------|-------------------------------|------------------------------|---------------------------------|---|-------------------------|---------------------------------------|--------------------|-------------------------|----------------------|--------------------|
| Annual Degradation Factor ¹¹ | 5.00% | 5.00% | 5.00% | 5.00% | 5.00% | 5.00% | 5.00% | 5.00% | 0.00% | 5.00% | 5.00% |
| T&D Loss ⁹ | 7.00% | 7.00% | 7.00% | 7.00% | 0.00% | 7.00% | 7.00% | 7.00% | 0.00% | 7.00% | 7.00% |
| Initial Discount Factor ¹² | 20.00% | 20.00% | 20.00% | 20.00% | 20.00% | 25.00% | 25.00% | 60.00% | 25.00% | 20.00% | 20.00% |
| Growth Factor | 3.25% | 1.54% | 3.25% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | Actual Rates | N.A. | N.A. |
| Weather Normalized | Yes | Yes | Yes | No | No | No | No | No | See note 7 | Yes | Yes |




Figure 9-1: Process Flow Diagram of the NOx Emissions Reduction Calculations

Table 9-3: Annual and OSD Electricity Savings for the Different Programs

| Program | Annual | | | | | | | | | | | | | | | |
|-----------------------------------|-----------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
| ESL-Single Family (MWh) | 225,389 | 1,001,051 | 1,197,537 | 1,256,764 | 1,313,777 | 1,368,371 | 1,420,340 | 1,469,480 | 1,515,583 | 1,558,446 | 1,597,862 | 1,633,626 | 1,665,533 | 1,693,376 | 1,716,950 | 1,736,050 |
| ESL-Multifamily (MWh) | 9,228 | 37,821 | 51,312 | 63,156 | 74,493 | 85,311 | 95,599 | 105,346 | 114,541 | 123,171 | 131,227 | 138,696 | 145,568 | 151,830 | 157,472 | 162,483 |
| ESL-Commercial (MWh) | 63,456 | 129,063 | 192,036 | 231,649 | 270,392 | 308,184 | 344,944 | 380,592 | 415,047 | 448,228 | 480,055 | 510,445 | 539,320 | 566,597 | 592,196 | 616,037 |
| Federal Buildings (MWh) | 52,276 | 109,073 | 159,415 | 206,960 | 251,708 | 293,659 | 332,813 | 369,171 | 402,732 | 433,496 | 461,464 | 486,635 | 509,009 | 528,586 | 545,366 | 559,350 |
| Furnace Pilot Light Prog. (MMBtu) | 2,209,050 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 |
| PUC (SB7) (MWh) | 302,192 | 1,362,701 | 1,630,383 | 2,003,432 | 2,353,192 | 2,679,663 | 2,982,846 | 3,262,739 | 3,519,343 | 3,752,658 | 3,962,684 | 4,149,421 | 4,312,869 | 4,453,028 | 4,569,898 | 4,663,479 |
| PUC (SB5 grant program) (MWh) | 0 | 13,633 | 12,827 | 12,021 | 11,215 | 10,409 | 9,603 | 8,797 | 7,991 | 7,186 | 6,380 | 5,574 | 4,768 | 3,962 | 3,156 | 2,350 |
| SECO (MWh) | 115,360 | 293,764 | 353,701 | 445,357 | 457,921 | 468,611 | 477,428 | 484,371 | 489,440 | 492,636 | 493,959 | 493,408 | 490,983 | 486,685 | 480,513 | 472,468 |
| Wind-ERCOT (MWh) | 2,867,049 | 6,699,696 | 9,193,504 | 15,171,518 | 20,115,442 | 22,082,748 | 22,595,958 | 23,280,238 | 23,985,240 | 24,711,593 | 25,459,941 | 26,230,952 | 27,025,312 | 27,843,728 | 28,686,928 | 29,555,662 |
| SEER13-Single Family (MWh) | 0 | 374,246 | 624,639 | 913,010 | 1,185,311 | 1,441,594 | 1,681,860 | 1,906,108 | 2,114,339 | 2,306,551 | 2,482,746 | 2,642,923 | 2,787,083 | 2,915,224 | 2,803,568 | 2,590,509 |
| SEER13-Multifamily (MWh) | 0 | 31,634 | 52,532 | 76,375 | 98,620 | 119,281 | 138,371 | 155,904 | 171,894 | 186,354 | 199,298 | 210,738 | 220,690 | 229,165 | 219,722 | 202,900 |
| Total Annual (MWh) | 3,634,949 | 10,052,682 | 13,467,885 | 20,380,240 | 26,132,070 | 28,857,830 | 30,079,762 | 31,422,747 | 32,736,151 | 34,020,320 | 35,275,615 | 36,502,419 | 37,701,133 | 38,872,181 | 39,775,770 | 40,561,288 |
| Total Annual (MMBtu) | 2,209,050 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 | 2,548,904 |

| Program | Ozone Season Day - OSD | | | | | | | | | | | | | | | |
|-----------------------------------|------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|---------|
| | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
| ESL-Single Family (MWh) | 776 | 5,537 | 6,519 | 6,904 | 7,275 | 7,809 | 8,138 | 8,450 | 8,744 | 9,019 | 9,274 | 9,507 | 9,717 | 9,904 | 10,065 | 10,199 |
| ESL-Multifamily (MWh) | 36 | 192 | 271 | 351 | 428 | 508 | 577 | 643 | 706 | 765 | 820 | 871 | 919 | 962 | 1,002 | 1,037 |
| ESL-Commercial (MWh) | 0 | 800 | 1,189 | 1,447 | 1,700 | 1,966 | 2,205 | 2,436 | 2,660 | 2,876 | 3,082 | 3,280 | 3,467 | 3,645 | 3,811 | 3,967 |
| Federal Buildings (MWh) | 0 | 299 | 437 | 567 | 690 | 805 | 912 | 1,011 | 1,103 | 1,188 | 1,264 | 1,333 | 1,395 | 1,448 | 1,494 | 1,532 |
| Furnace Pilot Light Prog. (MMBtu) | 5,819 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 |
| PUC (SB7) (MWh) | 828 | 3,733 | 4,467 | 5,489 | 6,447 | 7,342 | 8,172 | 8,939 | 9,642 | 10,281 | 10,857 | 11,368 | 11,816 | 12,200 | 12,520 | 12,777 |
| PUC (SB5 grant program) (MWh) | 0 | 37 | 35 | 33 | 31 | 29 | 26 | 24 | 22 | 20 | 17 | 15 | 13 | 11 | 9 | 6 |
| SECO (MWh) | 316 | 805 | 969 | 1,220 | 1,255 | 1,284 | 1,308 | 1,327 | 1,341 | 1,350 | 1,353 | 1,352 | 1,345 | 1,333 | 1,316 | 1,294 |
| Wind-ERCOT (MWh) | 5,836 | 14,936 | 20,763 | 25,575 | 33,908 | 37,225 | 38,090 | 39,243 | 40,432 | 41,656 | 42,918 | 44,217 | 45,556 | 46,936 | 48,357 | 49,822 |
| SEER13-Single Family (MWh) | 0 | 2,666 | 4,449 | 6,503 | 8,442 | 10,268 | 11,979 | 13,576 | 15,059 | 16,428 | 17,683 | 18,824 | 19,851 | 20,764 | 19,969 | 18,451 |
| SEER13-Multifamily (MWh) | 0 | 213 | 354 | 514 | 664 | 803 | 931 | 1,049 | 1,157 | 1,254 | 1,341 | 1,418 | 1,485 | 1,542 | 1,479 | 1,365 |
| Total OSD (MWh) | 7,791 | 29,219 | 39,453 | 48,602 | 60,840 | 68,037 | 72,339 | 76,700 | 80,866 | 84,837 | 88,610 | 92,186 | 95,565 | 98,745 | 100,022 | 100,451 |
| Total OSD (MMBtu) | 5,819 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 | 6,983 |

Table 9-4: Annual and OSD NOx Emissions Reduction Values for the Different Programs

| Program | Annual (in tons NOx) | | | | | | | | | | | | | | | |
|-----------------------------|----------------------|-------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
| ESL-Single Family | 158 | 708 | 843 | 883 | 922 | 960 | 996 | 1,029 | 1,061 | 1,090 | 1,117 | 1,141 | 1,163 | 1,182 | 1,198 | 1,210 |
| ESL-Multifamily | 6 | 26 | 35 | 44 | 51 | 59 | 66 | 73 | 79 | 85 | 91 | 96 | 100 | 105 | 109 | 112 |
| ESL-Commercial | 44 | 90 | 136 | 164 | 192 | 218 | 245 | 270 | 295 | 319 | 341 | 363 | 384 | 403 | 421 | 438 |
| Federal Buildings | 40 | 84 | 122 | 158 | 193 | 225 | 255 | 283 | 308 | 332 | 353 | 373 | 390 | 405 | 418 | 428 |
| Furnace Pilot Light Program | 102 | 117 | 117 | 117 | 117 | 117 | 117 | 117 | 117 | 117 | 117 | 117 | 0 | 0 | 0 | 0 |
| PUC (SB7) | 237 | 1,074 | 1,157 | 1,421 | 1,668 | 1,899 | 2,113 | 2,311 | 2,492 | 2,657 | 2,805 | 2,937 | 3,052 | 3,151 | 3,234 | 3,553 |
| PUC (SB5 grant program) | 0 | 6 | 5 | 5 | 5 | 4 | 4 | 4 | 3 | 3 | 3 | 2 | 2 | 1 | 1 | 1 |
| SECO | 67 | 224 | 270 | 340 | 349 | 357 | 364 | 369 | 373 | 376 | 377 | 376 | 374 | 371 | 366 | 360 |
| Wind-ERCOT | 2,465 | 4,152 | 5,688 | 8,914 | 11,818 | 12,974 | 13,276 | 13,678 | 14,092 | 14,519 | 14,958 | 15,411 | 15,878 | 16,359 | 16,854 | 17,365 |
| SEER13-Single Family | 0 | 258 | 430 | 629 | 816 | 993 | 1,158 | 1,313 | 1,456 | 1,589 | 1,710 | 1,820 | 1,920 | 2,008 | 1,931 | 1,784 |
| SEER13-Multifamily | 0 | 22 | 36 | 53 | 68 | 82 | 95 | 107 | 118 | 128 | 137 | 145 | 152 | 158 | 151 | 140 |
| Total Annual (Tons NOx) | 3,119 | 6,760 | 8,839 | 12,727 | 16,200 | 17,889 | 18,689 | 19,554 | 20,395 | 21,214 | 22,009 | 22,782 | 23,415 | 24,143 | 24,683 | 25,392 |

| Program | Ozone Season Day - OSD (in tons Nox/day) | | | | | | | | | | | | | | | |
|-----------------------------|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
| ESL-Single Family | 0.76 | 3.85 | 4.50 | 4.76 | 5.01 | 5.37 | 5.60 | 5.80 | 6.00 | 6.19 | 6.36 | 6.51 | 6.65 | 6.77 | 6.88 | 6.97 |
| ESL-Multifamily | 0.03 | 0.13 | 0.18 | 0.24 | 0.29 | 0.35 | 0.39 | 0.44 | 0.48 | 0.52 | 0.56 | 0.59 | 0.63 | 0.66 | 0.68 | 0.71 |
| ESL-Commercial | 0.26 | 0.55 | 0.82 | 1.00 | 1.17 | 1.36 | 1.52 | 1.68 | 1.84 | 1.98 | 2.13 | 2.26 | 2.39 | 2.52 | 2.63 | 2.74 |
| Federal Buildings | 0.11 | 0.22 | 0.32 | 0.42 | 0.51 | 0.59 | 0.67 | 0.74 | 0.81 | 0.87 | 0.93 | 0.98 | 1.02 | 1.06 | 1.10 | 1.12 |
| Furnace Pilot Light Program | 0.28 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 | 0.00 | 0.00 | 0.00 | 0.00 |
| PUC (SB7) | 0.64 | 2.61 | 3.10 | 3.81 | 4.47 | 5.09 | 5.66 | 6.19 | 6.68 | 7.12 | 7.51 | 7.87 | 8.18 | 8.44 | 8.66 | 8.84 |
| PUC (SB5 grant program) | 0.00 | 0.02 | 0.02 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.00 | 0.00 | 0.00 |
| SECO | 0.18 | 0.61 | 0.73 | 0.92 | 0.95 | 0.97 | 0.99 | 1.00 | 1.01 | 1.02 | 1.02 | 1.02 | 1.02 | 1.01 | 0.99 | 0.98 |
| Wind-ERCOT | 5.85 | 9.27 | 12.98 | 15.13 | 20.06 | 22.03 | 22.54 | 23.22 | 23.92 | 24.65 | 25.39 | 26.16 | 26.96 | 27.77 | 28.61 | 29.48 |
| SEER13-Single Family | 0.00 | 1.81 | 3.03 | 4.42 | 5.74 | 6.98 | 8.15 | 9.23 | 10.24 | 11.17 | 12.03 | 12.80 | 13.50 | 14.12 | 13.58 | 12.55 |
| SEER13-Multifamily | 0.00 | 0.15 | 0.24 | 0.35 | 0.45 | 0.55 | 0.63 | 0.71 | 0.79 | 0.85 | 0.91 | 0.97 | 1.01 | 1.05 | 1.01 | 0.93 |
| Total OSD (Tons NOx) | 8.09 | 19.53 | 26.24 | 31.38 | 38.99 | 43.61 | 46.48 | 49.36 | 52.10 | 54.70 | 57.17 | 59.49 | 61.36 | 63.40 | 64.15 | 64.31 |




Figure 9-2: Cumulative OSD NOx Emissions Reduction Projections through 2020




Figure 9-3: Cumulative OSD NOx Emissions Reduction Projections through 2020

References

- CBECS 1995, 1999, 2003. USDOE Commercial Building Energy Characteristics Survey. U.S.D.O.E. Energy Information Agency Report.
- Dodge. 2005. MarkeTrack: McGraw-Hill Construction Analytics. McGraw-Hill Construction Information Group, 148 Princeton-Hightstown Rd., Hightstown, N.J. <http://dodge.construction.com>.
- ICC. 1999. 2000 International Energy Conservation Code. Falls Church, VA: International Code Council, Inc.
- ICC. 2001. 2001 Supplement to the International Energy Conservation Code. Falls Church, VA: International Code Council, Inc.
- Haberl, J., Culp, C., Yazdani, B., Fitzpatrick, and Turner, D., 2002, "Texas's senate Bill 5 Legislation for Reducing Pollution in Non-attainment and Affected Areas," Annual Report to the Texas Natural Resource Conservation Commission, July, Energy Systems Laboratory Report ESL-TR-02/07-01.
- Haberl, J., Culp, C., Yazdani, B., Fitzpatrick, T., Bryant, J., Turner, D., 2003, "Energy Efficiency/Renewable Energy Impact in the Texas Emissions Reduction Plan (TERP)," Volume II – Technical Report, Annual Report to the Texas Commission on Environmental Quality, September 2002 to August 2003, Energy Systems Laboratory Report ESL-TR-03/12-04.
- Haberl, J., Culp, C., Yazdani, B., Gilman, D., Fitzpatrick, T., Muns, S., Verdict, M., Ahmed, M., Liu, B., Baltazar-Cervantes, J.C., Bryant, J., Degelman, L., Turner, D. 2004. "Energy Efficiency/Renewable Energy Impact in the Texas Emissions Reduction Plan (TERP)", Volume II – Technical Report, Annual Report to the Texas Commission on Environmental Quality, September 2003 to August 2004, Energy Systems Laboratory Report ESL-TR-04/12-04.
- Haberl, J., Culp, C., Yazdani, B., Gilman, D., Fitzpatrick, T., Muns, S., Verdict, M., Ahmed, M., Liu, B., Baltazar-Cervantes, J.C., Bryant, J., Degelman, L., and Turner, D. 2006. "Energy Efficiency/Renewable Energy Impact in the Texas Emissions Reduction Plan (TERP)", Volume II – Technical Report, Annual Report to the Texas Commission on Environmental Quality, September 2004 to December 2005, Energy Systems Laboratory, Report ESL-TR-06-06-08.
- Haberl, J., Culp, C., Yazdani, B., Gilman, D., Fitzpatrick, T., Muns, S., Verdict, M., Ahmed, M., Liu, Z., Baltazar-Cervantes, J-C, Mukhopadhyay, J., Degelman, L., Turner, D. 2007. "Energy Efficiency/Renewable Energy Impact in the Texas Emissions Reduction Plan (TERP)", Volume II – Technical Report, Annual Report to the Texas Commission on Environmental Quality, September 2004 to December 2005, Energy Systems Laboratory, Report ESL-TR-07-12-01.
- Haberl, J. S., Liu, Z., Baltazar-Carvantes, J. C., Subbarao, K., Gilman, D., Culp, C., Yazdani, B., Turner, W. D., Chandrasekaran, V. 2008. "Energy Efficiency/Renewable Energy Impact in the Texas Emissions Reduction Plan (TERP)", Volume II—Technical Report, Annual Report to the Texas Commission on Environmental Quality, January 2007 – December 2007, Energy Systems Laboratory, Report ESL-TR-08-08-01.
- NAHB 1999. Builder Practices Survey Reports, National Association of Home Builders, Research Center, Upper Marlboro, Maryland (September).
- Kats, G.H. et al. 1996. "Energy Efficiency as a Commodity," ACEEE Summer Study on Energy Efficiency in Buildings.
- PUC 2007, Public Utility Commission of Texas, available at: <http://www.puc.state.tx.us/>

USDOE 2004. Building Energy Standards Program: Determination Regarding Energy Efficiency Improvements in the Energy Standard for Buildings, Except Low-Rise Residential Buildings, ASHRAE/IESNA Standard 90.1-1999. Docket No. (Docket No. EE-DET-02-001). Washington, D.C. <http://www.energycodes.gov/implement/pdfs/FR_com_notice.pdf>

10 APPENDIX A

10.1 Presentation in March 2008

March 19, 2008 – Presentation to the TCEQ about the calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas

STATEWIDE AIR EMISSIONS CALCULATIONS FROM ENERGY EFFICIENCY, WIND AND RENEWABLES

TCEQ, ESL, HARC meeting

March 19, 2008

Energy Systems Laboratory
Texas Engineering Experiment Station
Texas A&M University System

Agenda

1. Introductions (All)
2. Wind and Renewables Reporting (ESL)
3. Energy Efficiency/Renewable Energy Reporting (ESL)
4. Integrated, Cumulative NOx Emissions Reductions from Several State Agencies (ESL)
5. Energy and NOx Emissions Reductions from Combined Heat and Power (CHP) Projects (HARC)
6. Discussion (All)
7. Adjourn

Introduction
ESL's Legislative Requirements

Senate Bill 5 (77th Legislature, 2001)

SB 205, Texas Emissions Reduction Plan
SB 206, 2001 Evaluation Of State Energy Efficiency Programs (with PUC)

SB 300, Texas Building Energy Performance Standards

SB 301, 2001 Evaluation Of Building Energy Efficiency Performance Standards
SB 302, 2001, Enforcement Of Energy Standards Outside Of Municipality
SB 303, 2001, Standardization Of Information And Inspection And Checks
SB 304, 2001, Development Of Home Energy Ratings
TCEQ Resolution 2001-001

HB 2311, Texas Building Energy Performance Standards
HB 2312, SB 304, 2001, Enforcement Of Energy Standards Outside Of Municipality
HB 2313, SB 304, 2001, Energy-Efficient Building Program

HB 300, Texas Building Energy Performance Standards
HB 2229, SB 304, 2001 Certification Of Municipal Inspectors
HB 2230, Texas Building Energy Performance Standards
HB 2231, Health and Safety Code

HB 2232, SB 304, 2001 Development Of Creditable Statewide NOx Emissions Reductions Credits From Energy Efficiency and Renewable Energy
HB 2233, SB 304, 2001 Construction Action Relating To Water Heaters
TCEQ Resolution 2001-001

HB 2301, HB 2302, SB 304, 2001, Subsection (b)(1), (b)(2), (b)(3) that allows SEC to adopt new w/d of the TCEQ based on written recommendations from the Laboratory.
An E-2001-001 Resolution of Standardization of Standards & Report formats for newly constructed residential

HB 2303, Health and Safety Code
(SB 12) Section 300, 2001, subsection (b)(1), (b)(2) allows SEC to adopt new w/d of the SECC based on written recommendations from the Laboratory.

Introduction
ESL's Legislative Requirements

1. Evaluation Of State Energy Efficiency Programs (with PUC).

2. Building Energy Efficiency Performance Standards.

3. Information And Technical Assistance.

4. Development of Creditable Statewide NOx Emissions Reductions Credits From Energy Efficiency and Renewable Energy.

5. Development Of Home Energy Ratings.

6. Certification of Municipal Inspectors.

7. Development of Creditable Statewide NOx Emissions Credits from Wind and Other Renewables.

8. Evaluate IECC/ASHRAE Standard for Stringency and Report to SEC.

9. Development of Standardized Report Formats for Newly Constructed Residences.

Introduction
Energy Emissions and Impact Factor

| | Use | NOx | Upgrade Avg. Life | Impact Factor |
|-------------|-----|-----|-------------------|---------------|
| Industries: | 60% | 23% | 5 – 20 yr | 1 – 5 |
| Vehicles: | 19% | 54% | 7 – 10 yr | 4 – 5 |
| Buildings: | 21% | 22% | 25 – 50 yr | 5 – 11 |

Buildings substantially impact emissions!

SOURCE: Estimate Use/USDOE EIA, 1990
Research Emissions/TNCC 2002

Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data

Figure 10-1: Slides presented on March 19, 2008 (Part 1)

Electricity Production from Wind Farms (2002-2007)

Total Wind Power Generation (Source: ERCOT & PIAQ)

- Installed capacity of wind turbines was 3,028 MW (March 2007).
- Announced new project capacity is 3,125 MW by 2010.
- Lowest electricity period occurs during Ozone Season Period.

Calculating NOx Reductions from Wind Farms

What issues did TCEQ ask ESL to resolve to calculate OSP NOx reductions from wind farms in the base year?

Large variations in measured power vs base year power production in the OSP.

Calculating NOx Reductions from Wind Farms

How was this issue resolved?

First, studied data from 40 kW research turbine in Randall Co.

Compared on-site vs NOAA wind data.

Calculating NOx Reductions from Wind Farms

Hourly electricity produced vs on-site wind data acceptable for hourly modeling.

Issue: hourly on-site data not always available.

Next, looked at hourly electricity produced vs NOAA wind data.

Issue: too much scatter.

Calculating NOx Reductions from Wind Farms

Result: Daily Wind Speed at 1000ft (NOAA)

Modeling daily electricity vs daily wind data (on-site vs NOAA).

Result: on-site, 3P CP on-site model, acceptable.

Modeled daily electricity vs daily wind data (NOAA).

Result: 3P CP NOAA model also acceptable.

Figure 10-2: Slides presented on March 19, 2008 (Part 2)

Calculating NOx Reductions from Wind Farms

Capacity Factors Using Daily Models

Next, compared NOAA and on-site daily models to see how well the predicted OSP electricity production. (Result: acceptable).

Calculating NOx Reductions from Wind Farms

Final result: prediction of NOx reduction in 1999 and 2007 (annual and OSP) by county using EPA's 2007 eGRID.

Calculating NOx Reductions from Wind Farms

Summary

- Creditable procedure developed for calculating weather-normalized electricity production in any base year.
- NOx emissions reductions calculated using EPA's 2007 eGRID.
- Procedure approved by stakeholders: ERCOT, TCEQ, EPA others.
- Procedure being considered by EPA for use nationally.

Calculating NOx Reductions from Wind Farms

Final issue: TCEQ asked ESL to develop an integrated tool to project NOx reductions from wind farms through 2020 by county, using eGRID, including:

- + discount,
- + degradation,
- + T&D losses &
- + growth.

Calculating NOx Reductions from Wind Farms

Recommendation

- Reduce 20% discount factor to 10-15% to be consistent with uncertainty calculations.

Figure 10-3: Slides presented on March 19, 2008 (Part 3)

Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data

NOx Reductions from Wind Farms: Improving Predictions w/ANNs

Challenge: Current analysis uses daily models to predict daily OSPN O_x reductions in 1999 base year.

An improvement to this analysis would use hourly models to predict hourly OSPN O_x reductions in 1999.

Problem: there are large variations in hourly wind speeds for on-site (hub-height) vs NOAA.

NOx Reductions from Wind Farms: Improving Predictions w/ANNs

Proposed Solution: Use of Artificial Neural Networks (ANNs) can synthesize on-site (hub height) wind speeds from NOAA weather data.

Preliminary Result: ANN predicted on-site, hub-height wind speeds appear to be an acceptable substitute.

NOx Reductions from Wind Farms: Improving Predictions w/ANNs

Predicted on-site, hub-height wind speeds capture hourly magnitudes and diurnal patterns.

NOx Reductions from Wind Farms: Improving Predictions w/ANNs

Future: Investigate the use of meteorological wind models to predict on-site, hub-height wind speeds in the base year.

Important for TCEQ to have hourly NO_x emissions reductions in base year for use in photochemical models.


Summary

- Hourly ANN modeling procedures developed for predicting on-site, hub-height wind speeds appear to be acceptable.
- Such procedures could be used to predict on-site wind speeds in the base year when on-site data are not available.
- Hourly models could directly feed photochemical models for base year.
- ANN models require at least 6 to 9 months of on-site data for training ANNs.
- Meteorological models being studied for future wind predictions

Figure 10-4: Slides presented on March 19, 2008 (Part 4)


Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data



NOx Reductions from Wind Farms: Degradation Analysis

Currently: TCEQ uses a conservative 5% degradation factor for future predictions from wind farms.



TCEQ asked the ESL to review measured data from Texas wind farms to see if degradation was present.

12-month sliding analysis used to review data from all Texas wind farms.

NOx Reductions from Wind Farms: Degradation Analysis

Result: Degradation not present in measured wind data.
Recommendation: TCEQ should reduce 5% degradation factor to 1 to 2% or less for future predictions from wind farms.

| Wind Farm | First 12 months Period of the Year of Wind Power | | Second 12 months Period of the Year of Wind Power | | Third 12 months Period of the Year of Wind Power | | Fourth 12 months Period of the Year of Wind Power | | No. of Months of Data | Capacity (MW) |
|-------------------------------|--|--------------|---|--------------|--|--------------|---|------------|-----------------------|---------------|
| | First 12 months Starting 1/1 | MW | Second 12 months Starting 1/1 | MW | Third 12 months Starting 1/1 | MW | Fourth 12 months Starting 1/1 | MW | | |
| Indian Wells 1 | 24.0 | 21.2 | 8.1% | 26.1 | -11.4% | 23.0 | 23.5% | 48 | 52.3 | |
| Indian Wells 2 | 24.0 | 19.2 | 8.3% | 16.1 | -13.4% | 23.2 | 21.1% | 48 | 52.3 | |
| Coldwater | 24.0 | 19.2 | 8.5% | 16.4 | -16.8% | 21.8 | 16.7% | 30 | 40 | |
| Denton 50 | 24.0 | 27.2 | 8.5% | 23.1 | -4.7% | 24.4 | 28.7% | 48 | 140 | |
| Rockport 100 | 24.0 | 24.0 | 8.5% | 25.2 | 4.2% | 24.1 | 4.6% | 48 | 140 | |
| King Mountain 100 | 24.0 | 26.8 | 8.5% | 40.2 | +50.7% | 85.6 | 26.6% | 78 | 140 | |
| King Mountain 150 | 24.0 | 21.1 | -1.3% | 18.4 | -14.8% | 23.0 | 12.7% | 48 | 140 | |
| King Mountain 200 | 24.0 | 23.2 | 2.1% | 39.4 | +54.2% | 95.5 | 23.7% | 48 | 140 | |
| Big Spring | 24.0 | 23.8 | 2.5% | 23.8 | 0.0% | 23.1 | 2.7% | 48 | 140 | |
| Southwest Wind | 24.0 | 24.4 | 2.5% | 29.8 | +21.7% | 61.1 | 0.0% | 48 | 140 | |
| Total | 576.0 | 525.6 | -8.5% | 576.0 | -8.5% | 576.0 | -8.5% | 288 | 52.3 | |
| Average of All Regimes | 12.0 | | | 12.0 | | 12.0 | | | | |




Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data



NOx Reductions from Wind Farms: Curtailment Analysis

Currently: Daily base year predictions of electricity from selected wind farms contain periods of curtailment.
TCEQ wanted to know what future electricity production would be like in the Ozone Season Period if curtailment were removed.



NOx Reductions from Wind Farms: Curtailment Analysis

Use of model without curtailment shows periods of significant differences in power outputs over annual period.

Largest periods in winter and spring.

Significant periods in OSP.





Figure 10-5: Slides presented on March 19, 2008 (Part 5)

NOx Reductions from Wind Farms: Curtailment Analysis

| Predicted MWh in 2002 OSD Using Power Curve and On-site Wind | 2002-2003 Measured in OSD | Curtailment and Maintenance Factor for OSD Period |
|--|---------------------------|---|
| 51,565 | 39,679 | 28.4% |

| Predicted MWh Using Power Curve and On-site Wind (Jul 02 - Jan 03) | 2002-2003 Measured (Jul 02 - Jan 03) | Curtailment and Maintenance Factor for Jul - Jan 03 |
|--|--------------------------------------|---|
| 125,354 | 99,737 | 22.6% |


Result:
Models showed uncurtailed electricity would be:
+20 - 30% in OSP
+40 - 50% in Nov-Jan at the case study site.



NOx Reductions from Wind Farms: Degradation and Curtailment Analysis

Summary


- Degradation analysis completed for TCEQ shows little if any degradation in electricity produced by Texas wind farms.
- Curtailment analysis completed for TCEQ shows that uncurtailed electricity can be calculated using hourly data and used for forecasts.
- Curtailment at the case study Indian Mesa site is 20-30% of OSP electricity production.



NOx Reductions from Wind Farms: Degradation and Curtailment Analysis


Recommendations

- Reduce or eliminate degradation factor.
- Include both curtailed and uncurtailed predictions of wind power to better estimate future wind power capability.




Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data



NOx Reductions from Other Renewables

The ESL has also located renewable energy sites, quantified electricity and natural gas savings and quantified NOx emissions reductions using eGRID and EPA's AP-42 database.



Wind and Renewables

1. NOx Reductions from Wind Farms in 2005
2. Improved Predictions of On-site Wind Speeds Using ANNs
3. Degradation Analysis & Curtailment Analysis
4. Other Renewables
5. Estimating Hourly Solar Data from Limited Meteorological Data




Figure 10-6: Slides presented on March 19, 2008 (Part 6)

NOx Reductions from Other Renewables

Estimating Hourly Solar Data from Limited Meteorological Data

Calculation of weather-normalized NO_x emissions reductions requires contiguous weather data from representative Texas sites.

Issue: Since 2001 the availability of solar radiation data in Texas has created sites with large gaps of missing data.

Proposed solution: synthesize missing solar data.

NOx Reductions from Other Renewables

Estimating Hourly Solar Data from Limited Meteorological Data

Issue: National model for synthesizing hourly global horizontal solar radiation can be inaccurate for hot/humid locations.

Proposed solution: Derive new model that corrects for this inaccuracy. Use new model to synthesize missing solar data.

NOx Reductions from Other Renewables

Summary

- PV, solar thermal, hydroelectric, geothermal and landfill gas sites located and creditable emissions reductions quantified.
- New, improved solar radiation model developed to fill missing solar radiation data.

NOx Reductions from Other Renewables

Recommendation

- Add more solar radiation sites in selected areas of Texas.

Energy Efficiency Reporting

1. NOx Reductions From New Residential/Commercial Construction
2. NOx Reductions From Existing Buildings
 - NOx Reductions from Furnace Pilot Lights
 - NOx Reductions from SEER 13 Air Conditioners
3. Verification Efforts
4. Above Code Reporting Efforts/Tool Development

Energy Efficiency Reporting

Electricity and N.G. reductions calculated from new code-compliant residential construction (single-family, multi-family).

Representative house types created and energy use simulated for code-compliant (IECC 2001) vs pre-code construction.

Per-house, fuel-neutral savings then multiplied by new construction permits (US Census).

Figure 10-7: Slides presented on March 19, 2008 (Part 7)

Energy Efficiency Reporting

Electricity and N.G. reductions calculated from new commercial construction (office, retail, educational, food, lodging, assembly, warehouse).

Energy savings calculated by comparing code-compliant (ASHRAE Standard 90.1-1999) vs pre-code construction.

National data used to calculate construction activity for Texas region.

Energy Efficiency Reporting

NOx emissions reductions calculated from new residential and commercial construction using EPA's eGRID and AP-42 (Result: 10.75 tons/OSD).

Energy Efficiency Reporting

1. NOx Reductions From New Residential/Commercial Construction
2. NOx Reductions From Existing Buildings
 - NOx Reductions from Furnace Pilot Lights
 - NOx Reductions from SEER 13 Air Conditioners
3. Verification Efforts
4. Above Code Reporting Efforts/Tool Development

Energy Efficiency Reporting

TCEQ asked the ESL to calculate NOx emissions reductions from the new Federal regulations for SEER 13 air conditioners.

The ESL calculated electricity savings for new construction and for existing home replacements across Texas.

NOx emissions reductions were then calculated using eGRID.

Savings are 11 tons NOx/OSD

Energy Efficiency Reporting

- New furnaces and replacement furnaces use hot surface ignition instead of pilot lights (500 Btu/hr savings per household).
- NOx emissions reductions from furnaces in new construction already calculated as part of new construction calculations by the ESL.
- TCEQ asked the ESL to calculate NOx emissions reductions from furnace replacements in existing residences (Result = 0.3 tons/OSD)

Energy Efficiency Reporting

1. NOx Reductions From New Residential/Commercial Construction
2. NOx Reductions From Existing Buildings
 - NOx Reductions from Furnace Pilot Lights
 - NOx Reductions from SEER 13 Air Conditioners
3. Verification Efforts
4. Above Code Reporting Efforts/Tool Development

Figure 10-8: Slides presented on March 19, 2008 (Part 8)

Energy Efficiency Reporting
Verification Efforts: Commercial Office

As part of the QAPP the EPA has requested verification of simulated savings.

The ESL is developing a calibrated simulation of a case-study office building to verify simulated savings against measured data.

Energy Efficiency Reporting
Verification Efforts: K-12 School

The ESL is developing a calibrated simulation of a K-12 school to verify simulated savings against measured data.

Energy Efficiency Reporting
Verification Efforts: Single-family Residential House

The ESL has been using a calibrated simulation of a single-family residence to verify simulated savings against measured data.

Energy Efficiency Reporting
Verification Efforts: Single-family Residential Utility Bill Analysis

Monthly utility bill analysis performed on houses before/after Building Code (9/2001).

Results: 13–16% savings agrees with simulations.

Effort needs to be expanded.

Energy Efficiency Reporting
Verification Efforts: Solar Test Bench

The ESL has been using measured data from a solar test bench to verify savings from low-e window glazing and glazing in case study buildings.

Result: data in good agreement with simulation.

Energy Efficiency Reporting

1. NOx Reductions From New Residential/Commercial Construction
2. NOx Reductions From Existing Buildings
 - NOx Reductions from Furnace Pilot Lights
 - NOx Reductions from SEER 13 Air Conditioners
3. Verification Efforts
4. Above Code Reporting Efforts/Tool Development

Figure 10-9: Slides presented on March 19, 2008 (Part 9)

Energy Efficiency Reporting

Above Code Reporting Efforts/Tool Development - Residential

The ESL is developing 15% above code measures for residential new construction, including the calculation of NOx emissions reductions.

Individual Measures

| Individual Measure | Annual Savings (Ton/Year) |
|---|---------------------------|
| Residential Hot Water Efficiency | 0.7% |
| Central Gas Furnace (100% AFUE) | 0.7% |
| Central Air Conditioner (13 SEER) | 0.7% |
| Residential Heat Pump (13 SEER) | 0.7% |
| All Residential Air Conditioning Systems | 0.7% |
| Residential HVAC, Air Distribution and Airflow Control in Commercial Spaces | 0.7% |
| Residential Fan Efficiency (0.7% NOx savings) | 0.7% |
| Residential Air Filtration (0.7% NOx savings) | 0.7% |
| Residential Glazing Efficiency (0.7% NOx savings) | 0.7% |
| Residential Windows (0.7% NOx savings) | 0.7% |
| Residential Duct Sealing (0.7% NOx savings) | 0.7% |
| Residential Insulation (0.7% NOx savings) | 0.7% |

Annual Gas Heating (Brazoria, Fort Bend, Galveston, Harris, Montgomery and Waller Counties)

NOx

Table A-10: 15% Above Code Residential Measures - Residential Gas Heating (Brazoria, Fort Bend, Galveston, Harris, Montgomery and Waller Counties)

Source: Energy Systems Laboratory

Energy Efficiency Reporting

Above Code Reporting Efforts/Tool Development - Commercial

The ESL is developing 15% above code measures for new commercial construction, including the calculation of NOx emissions reductions.

Individual Measures

| Individual Measure | Annual Savings (Ton/Year) |
|---|---------------------------|
| Residential and Commercial Measures | 18.7% |
| 1. Glazing (Faster) (2.2 to 0.80 Dual-pane) | 8.6% |
| 2. Lighting (1.2 to 0.60) | 8.6% |
| 3. Computer Power Management | 1.2% |
| 4. HVAC System Efficiency | 1.2% |
| 5. CHP/Cooling | 0.4% |
| 6. Motor Fan Control | 0.3% |
| 7. Energy Efficient Equipment | 0.3% |
| 8. Other Cool Roof | 0.3% |
| 9. Appliance Efficiency (0.3%) | 0.3% |
| 10. Window/Wall Insulation (from Commercial to Residential) | 0.4% |
| 11. Window/Wall Insulation (from Residential to Commercial) | 0.1% |

Annual Gas Heating (Brazoria, Fort Bend, Galveston, Harris, Montgomery and Waller Counties)

NOx

Table A-10: 15% Above Code Residential Measures - Residential Gas Heating (Brazoria, Fort Bend, Galveston, Harris, Montgomery and Waller Counties)

Source: Energy Systems Laboratory

Energy Efficiency Reporting

Summary

- NOx emissions reductions calculated for residential/commercial new construction.
- NOx emissions reductions calculated for SEER 13 air conditioners.
- NOx emissions reductions calculated for furnace pilot lights (new and existing buildings).
- Verification efforts underway (office, K-12, residential, utility bill analysis, low-e glazing testing).
- 15% above code developed (residential & commercial).

Source: Energy Systems Laboratory

Agenda

1. Introductions (All)
2. Wind and Renewables Reporting (ESL)
3. Energy Efficiency/Renewable Energy Reporting (ESL)
4. Integrated Cumulative NOx Emissions Reductions from Several State Agencies (ESL)
5. Energy and NOx Emissions Reductions from Combined Heat and Power (CHP) Projects (HARC)
6. Discussion (All)
7. Adjourn

Source: Energy Systems Laboratory

Integrated NOx Savings

In 2005 the TCEQ initiated a program to determine integrated NOx emissions savings (2013 and beyond) to allow for savings to be reported to the EPA

TCEQ

State Agencies included:

- TEES/ESL
- PUC
- SECO
- EPCC/Wind

Savings Integration allows:

- Annual, OSD savings
- By County
- By SIP
- By Program
- Integration tool = Adjustable Discount, Degradation, T&D losses

Source: Energy Systems Laboratory

Integrated NOx Savings: Results

Cumulative NOx emissions reductions calculated across state programs (2013)

OSD NOx Reduction Levels (All TCEQ)

OSD NOx Reduction Levels (All TCEQ)

Code Compliance (10.75 tons/day)
Federal Buildings (0.61 tons/day)
Furnace Pilot Lights (0.32 tons/day)
PUCs SB7, SB8 programs (4.78 tons/day)
SECO Portfolio Sub. (0.84 tons/day)
Green Power (Wind) (12.32 tons/day)
SEER 13 Refrigerants (11.03 tons/day)
Total (40.86 tons/day)

Annual Reporting to the TCEQ, papers, QAPP, etc.

Source: Energy Systems Laboratory

Figure 10-10: Slides presented on March 19, 2008 (Part 10)

Summary: Tech Transfer to Help Reduce Energy Use Emissions Reductions


- eCalc Energy & Emissions Calculator
 - Residential, Commercial
 - Municipal buildings, traffic lights, streetlights, water
 - Solar thermal, PV, wind
- Synchronous NOx Emissions Calculator
 - Quick results for MWh savings in any county
- International Code Compliance Calculator (ICC)
 - Calculates code compliance for 2001 IECC + SEER 13
 - Allows for 15% above code compliance calculations
- 15% above-code measures (41 Cos.)
 - Residential – 11 measures
 - Commercial – 10 measures



Energy Efficiency Reporting

Summary


- NOx emissions reductions calculated for residential/commercial new construction.
- NOx emissions reductions calculated for SEER 13 air conditioners.
- NOx emissions reductions calculated for furnace pilot lights (new and existing buildings).
- Verification efforts underway (office, K-12, residential, utility bill analysis, low-e glazing testing).
- 15% above code developed (residential & commercial).



Energy Efficiency & Renewables Energy Reporting


Overall Recommendations

- Reduce 20% discount factor for wind to 10-15% to be consistent with uncertainty calculations.
- Reduce or eliminate degradation factor for wind.
- Include both curtailed and uncurtailed predictions of wind power to better estimate future wind power capability.
- Add more solar radiation sites in selected areas of Texas.
- TCEQ needs to coordinate 2007 Integrated NOx emissions reductions effort for June 2008 delivery.



Discussion

- How can the ESL best support TCEQ with NOx emissions reductions accounting from EE/RE?
- Need to find additional NOx emissions reduction opportunities (e.g., building commissioning, SEER XX, CFLs, above code construction, etc.).
- Texas NOx emissions reductions calculations being used in ESL's EPA Center of Excellence for Displaced Emissions Reductions (CEDER).



ESL CONTACT INFORMATION



Jeff Haberl: jeffhaberl@ees.tamu.edu
 Bahman Yazdani: bahmanyazdani@ees.tamu.edu
 Charles Culp: charlesculp@ees.tamu.edu
<http://eslsb5.tamu.edu>

Figure 10-11: Slides presented on March 19, 2008 (Part 11)

10.2 Presentation in May 2008

May 2008 – Presentation to the Texas Clean Air Working Group about the calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas









Figure 10-12: Slides presented in May, 2008 (Part 1)

Calculating NOx Reductions from Wind Farms

Final issue: TCEQ asked ESL to develop an integrated tool to project NOx reductions from wind farms through 2020 by county, using eGRID, including:

- + discount,
- + degradation,
- + T&D losses & growth.

Introduction Energy Emissions and Impact Factor

| | Use | NOx | Upgrade | Impact Factor |
|-------------|-----|-----|------------|---------------|
| Industries: | 60% | 23% | 5 - 20 yr | 1 - 5 |
| Vehicles: | 19% | 54% | 7 - 10 yr | 4 - 5 |
| Buildings: | 21% | 22% | 25 - 50 yr | 5 - 11 |

Buildings substantially impact emissions!

SOURCE: Standard Use LOS/ODSA, 1990
Baseline Emissions: TMRC2 2000

Energy Efficiency Reporting

NOx emissions reductions calculated from new residential and commercial construction using EPA's eGRID and AP-42 (Result: 10.75 tons/OSD).

Integrated NOx Savings

In 2005 the TCEQ initiated a program to determine integrated NOx emissions savings (2013 and beyond) to allow for savings to be reported to the EPA

State Agencies included:

- TEES/ESL
- PUC
- SECO
- ERCOT/Wind

Savings Integration allows:

- Annual OSD savings
- By County
- By SIP
- By Program
- Integration tool - Adjustable Discount, Degradation, T&D losses

Integrated NOx Savings: Results

| Program | Contribution (tons/day) |
|----------------------|-------------------------|
| Code Compliance | 10.75 |
| Federal Buildings | 0.61 |
| Fluorescent Lights | 0.32 |
| PUC/SB7 566 programs | 4.78 |
| SECO/Political Sub. | 0.84 |
| Green Power/Wind | 1.23 |
| SEER 13 Retrofit | 11.03 |
| Total | 40.86 |

Annual Reporting to the TCEQ, papers, QAPP, etc.

ESL CONTACT INFORMATION

Jeff Haberk: jeffhaberk@ees.tamus.edu
Bahman Yazdani: bahmanyazdani@ees.tamus.edu
Charles Culp: charlesculp@ees.tamus.edu
<http://eslsb5.tamu.edu>

Figure 10-13: Slides presented in May, 2008 (Part 2)

10.3 Presentation on May 22, 2008

May 22, 2008 – Presentation to the EPA Technical Forum about calculation of NOx emissions reductions from energy efficiency and renewable energy, conference call.









Figure 10-14: Slides presented on May 22, 2008 (Part 1)

Calculating NOx Reductions from Wind Farms

Final Issue: TCEQ asked ESL to develop an integrated tool to project NOx reductions from wind farms through 2020 by county, using eGRID, including:

- + discount,
- + degradation,
- + T&D losses & growth.

Source: Energy Systems Laboratory

Energy Efficiency Reporting

NOx emissions reductions calculated from new residential and commercial construction using EPA's eGRID and AP-42 (Result: 10.75 tons/OSD).

Total OMB NOx Reductions (Residential & Commercial Buildings)

| Category | Value |
|-------------|-------|
| Residential | 10.75 |
| Commercial | 0.32 |
| Total | 11.07 |

Source: Energy Systems Laboratory

Integrated NOx Savings

In 2005 the TCEQ initiated a program to determine integrated NOx emissions savings (2013 and beyond) to allow for savings to be reported to the EPA

State Agencies included:

- TEES/ESL
- PUC
- SECO
- ERCOT/Wind

Savings Integration allows:

- Annual, OSD savings
- By County
- By SLP
- By Program
- Integration tool - Adjustable Discount, Degradation, T&D losses

Source: Energy Systems Laboratory

Integrated NOx Savings: Results

Cumulative NOx emissions reductions calculated across state programs (2013)

Code Compliance (10.75 tons/day)
Federal Buildings (0.31 tons/day)
Furnace Prod Lights (0.32 tons/day)
PUCs SB/SBS programs (4.78 tons/day)
SECO Partition Sub. (0.84 tons/day)
Green Power (Wind) (12.32 tons/day)
SEER 13 Retrofits (11.03 tons/day)
Total (40.86 tons/day)

Annual Reporting to the TCEQ, papers, QAPP, etc.

ESL CONTACT INFORMATION

Jeff Haberl: jeffhaberl@ees.tamu.edu
 Bahman Yazdani: bahmanyazdani@ees.tamu.edu
 Charles Culp: charlesculp@ees.tamu.edu
<http://eslsb5.tamu.edu>


Figure 10-15: Slides presented on May22, 2008 (Part 2)

August 2009

Energy Systems Laboratory, Texas A&M University System

10.4 Presentation on September 17, 2008

September 17, 2008 – Presentation to the University of Texas Department of Architecture about the calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas



ACKNOWLEDGEMENTS

Faculty/Staff: Charles Culp, Bahman Yazdani, Cynthia Montgomery, Betty Liu, Juan Carlos Baltazar, Jaya Mukhopadhyay, Don Gilman, Kyle Marshall, Robert Stackhouse, Kathy McKelvey, Jason Cordes, Larry Degelman, Sherrie Hughes, Jessica Coffin, Stephen O'Neal.

Students: Mini Malhotra, Piljae Im, Simge Andolsun, Hyojin Kim, Sandeep Kota, Hee Jo, Grant Marvin, Matt Moss, Craig Menning.

TCEQ: Vince Meiller, Theresa Pella.

USEPA: Art Diem, Julie Rosenberg.

BACKGROUND

- U.S.E.P.A. closely monitors areas that exceed safe levels of Ozone.
- Reducing oxides of nitrogen (NO_x) contributes to reductions in Ozone.
- Hence, controlling NO_x emissions is a priority in Texas.

Houston...we have a problem!

LEGISLATIVE RESPONSE

41 Counties in Texas designated non-attainment or affected.

Senate Bill 5 (77th Legislature, 2001)
Ch. 291. Texas Energy Reduction Plan
Sec. 291.001 Sec. 291.002 Energy Efficiency Programs (with PUC)
Ch. 291. Texas Building Energy Performance Standards
Sec. 291.001 Adoption Of Energy Efficiency Performance Standards
Sec. 291.002 Enforcement Of Energy Efficiency Performance Standards Outside Of Municipality
Sec. 291.003 Energy Efficiency Program And Technical Assistance
Sec. 291.004 Dissemination Of Home Energy Ratings

TERP Amended (78th Legislature, 2003)
Ch. 291. Texas Building Energy Performance Standards
Sec. 291.001 Sec. 291.002 Enforcement Of Energy Standards Outside Of Municipality
Sec. 291.003 Sec. 291.004 Energy Efficient Building Program
Ch. 291. Texas Building Energy Performance Standards
Sec. 291.005 Sec. 291.006 Certification Of Mutual Inspectors

TERP Amended (79th Legislature, 2005)
Ch. 291. Health and Safety Code
Sec. 211.001 Sec. 291.002 Development of Creditable Standards for Emissions from New Residential Buildings
Sec. 211.002 Sec. 291.003 Commission Action Relating to Water Heaters

TERP Amended (80th Legislature, 2007)
Ch. 291. Health and Safety Code
Sec. 291.001 Sec. 291.002 Development of Creditable Standards for Emissions from New Residential Buildings
Sec. 291.003 Sec. 291.004 Commission Action Relating to Water Heaters





Figure 10-16: Slides presented on September 17, 2008 (Part 1)

SPATIAL & TEMPORAL TRACKING

- Required NOAA, NREL/UT & TOEG weather data sources to be gathered, missing data filled, and prepared for use by EE/PE applications

IECC CODE SF, MF SAVINGS

To quantify the reduction of NOx emissions due to the implementation of 2000 IECC with 2001 Supplement for new residential construction:

- Prototype simulation models were created for both single and multifamily configurations using DOE-2.1e simulation software
- The simulation models were then modified to accommodate the different scenarios for envelope and HVAC systems found typically in residences
- These simulation models were then linked to a web-based graphic user interface and US-EPA's eGRID to convert the energy savings to NOx emissions reduction

["ecalc.tamu.edu"](http://ecalc.tamu.edu)

HOW MUCH SAVINGS? SF & MF

PRECODE VS 2000/2001 IECC

- For both single and multifamily houses with electric HVAC equipment have lower annual energy consumption
- For single family, a house with slab-on-grade is the least consumptive vs a house with crawl space

- Similarly 2-story single family house uses less energy than 1-story house
- For multifamily, less savings for code-compliance due to less window area
- 128,804 single family
- 29,972 multifamily

COMMERCIAL BUILDING SAVINGS

To quantify the reduction of NOx emissions due to the implementation of ASHRAE Standard 90.1-1999:

- Prototype simulation models were created using the DOE-2.1e simulation software
 - 1 story
 - >3 story
 - >100 story
- The models were then modified to accommodate the requirements of both ASHRAE Standard 90.1-1989 (baseline) and 1999 (new construction).
- The models were then linked to a web-based graphic user interface and US-EPA's eGRID to convert the energy savings to NOx emissions reduction

HOW MUCH SAVINGS? COMMERCIAL

CORPORATION BETWEEN ASHRAE 90.1-1989 AND 1999:

- For the same building, ASHRAE 90.1-1999 is 13.4% less consumptive than ASHRAE 90.1-1989
- More stringent requirements for the lighting power density (LPD) in 1999 make up for 45% of the total decrease
- Boiler staging in 1999 also allows for a 12% decrease in the annual energy consumption as compared to 1989
- More stringent envelope requirements also help decreasing fan and auxiliary energy consumption in 1999

EXTENDING THE METHOD

USED USDOE, DODGE & CBECS DATA:

- PNNL study of ASHRAE Standard 90.1 1989 VS 1999.
- Dodge/CBEC data used to characterize new construction (122 million ft²)
- Peak savings calculated with eCALC
- Categories include:
 - Assembly
 - Education
 - Food
 - Lodging
 - Office
 - Retail
 - Warehouse

Figure 10-17: Slides presented on September 17, 2008 (Part 2)

August 2009


Energy Systems Laboratory, Texas A&M University System

ENERGY SAVINGS

ESTIMATED ANNUAL ENERGY SAVINGS FOR CODE-COMPLIANT RESIDENTIAL AND COMMERCIAL CONSTRUCTION:

2005 Annual Energy Savings:
 Total = 347,930 MWh/year
 Single-family = 263,656 MWh/year
 Multi-family = 9,210 MWh/year
 Commercial = 75,072 MWh/year
 N.G. savings (SF, MF and CO) = 689,737 MWh/year

2005 Peak Energy OSD Savings
 Total = 1,795 MWh/OSD
 Single-family = 1,298 MWh/OSD
 Multi-family = 39 MWh/OSD
 Commercial = 457 MWh/OSD
 N.G. savings (SF, MF and CO) = 1,209 MWh/OSD




NOx SAVINGS: SF, MF, COM, N.G.

ESTIMATED NOx SAVINGS FOR CODE-COMPLIANT RESIDENTIAL AND COMMERCIAL CONSTRUCTION:

2005 Annual NOx Savings:
 Total = 267 tons-NOx/year
 Single-family = 160 tons-NOx/year
 Multi-family = 6 tons-NOx/year
 Commercial = 48 tons-NOx/year
 N.G. savings = 32 tons-NOx/year

2005 Peak OSD NOx Savings
 Total = 1.26 tons-NOx/OSD
 Single-family = 0.88 tons-NOx/OSD
 Multi-family = 0.03 tons-NOx/OSD
 Commercial = 0.29 tons-NOx/OSD
 N.G. savings = 0.06 tons-NOx/OSD




OTHER EE MEAS: LIGHTS, WATER

Community Projects



- Municipal models use:
 - DOE-2 simulations for new buildings
 - Component models for street & traffic lights
 - Monthly utility billing models for before-after analysis
 - eGRID calculates emissions by PCA for 1999 and 2007.

METHODOLOGY: STREET LIGHTS




The flowchart details the methodology for street lights analysis, starting from project setup and weather data collection, through data entry into eCALC, and finally outputting results like annual energy savings and NOx emissions reduction.

METHODOLOGY: STREET LIGHTS

STREET LIGHTS ANALYSIS - UTILITY BILL MODE :

- The monthly energy consumption bill is divided by the number of days in each month to obtain the average daily energy consumption for each billing period (i.e. KWh/day).
- The data set containing the average daily temperature and average daily energy consumption for each month is then analyzed with the LM to determine a weather normalized energy consumption.
- The daily energy consumption is predicted by applying the 1999 daily average temperature data from NOAA into the developed two-parameter regression model.

Energy Consumption of Street Lights



Linear Regression Model for Street Lights

METHODOLOGY: TRAFFIC LIGHTS

TRAFFIC LIGHTS ANALYSIS - UTILITY BILL MODE :

- The utility bill analysis for traffic lights follows the same procedure as that of street lights.
- One parameter regression models (i.e. mean model) were chosen, based on an analysis of more than 2.0 traffic light utility meters from the City of College Station, Texas.

Average Daily Energy Consumption of Traffic Lights




Figure 10-18: Slides presented on September 17, 2008 (Part 3)

OTHER MODELS: RENEWABLES

- Renewable tools use:
 - F-CHART for solar thermal
 - PV F-CHART for photovoltaics
 - ASHRAE IMT utility billing analysis for wind energy
 - eGRID calculates emissions by PCA for 1999 and 2007.

RENEWABLES: WHAT ARE THEY?

METHODOLOGY: SOLAR PV ANALYSIS

- User selects solar system characteristics (i.e., type, collectors, tilt, etc.).
- eCalc calculates energy savings from installation of solar system using F-CHART.
- Output from F-CHART weather normalized with ASHRAE IMT. Coefficients fed to 1999 peak extractor.
- Peak extractor then calculates 1999 annual and peak-day energy savings, which are fed to eGRID.
- eGRID then calculates 1999 and 2007 emissions reduction by PCA

METHODOLOGY: SOLAR PV ANALYSIS

User selects solar PV system characteristics (i.e., type, area, tilt, etc.).

eCalc calculates energy savings from installation of solar system using PV-F-CHART

| Month | Load | Peak | 1999 | 2007 |
|-------|--------|------|-------|------|
| Jan | 120.1 | 0.0 | 100.0 | 0.0 |
| Feb | 122.1 | 0.0 | 100.0 | 0.0 |
| Mar | 120.9 | 0.0 | 100.0 | 0.0 |
| Apr | 104.3 | 0.0 | 100.0 | 0.0 |
| May | 79.9 | 0.0 | 100.0 | 0.0 |
| Jun | 49.7 | 0.0 | 100.0 | 0.0 |
| Jul | 97.1 | 0.0 | 100.0 | 0.0 |
| Aug | 118.4 | 0.0 | 100.0 | 0.0 |
| Sep | 144.2 | 0.0 | 100.0 | 0.0 |
| Oct | 903.8 | 0.0 | 100.0 | 0.0 |
| Nov | 754.5 | 0.0 | 100.0 | 0.0 |
| Dec | 9701.9 | 0.0 | 100.0 | 0.0 |

METHODOLOGY: SOLAR PV ANALYSIS

The output from PV-F-CHART is weather normalized with ASHRAE IMT. A break-point linear regression model as a function of outside temperature fits very well the generation of electricity from a solar PV system.

The obtained annual energy savings and the peak day energy savings will be input to the eGrid

Figure 10-20: Slides presented on September 17, 2008 (Part 5)




Figure 10-21: Slides presented on September 17, 2008 (Part 6)




Figure 10-22: Slides presented on September 17, 2008 (Part 7)




Figure 10-23: Slides presented on September 17, 2008 (Part 8)

RESULTS: WIND ANALYSIS

| Wind Site Name | Caps. | NGCA Number of Wind | FCI | Capacity (MW) | 2004 Average of Wind Power Output (MWh) | NGCA Current of Wind Power Output (MWh) | NGCA Current of Wind Power Output (%) |
|---------------------|-------|------------------------|------|------------------|---|---|---|
| ANSON WIND | NGCA | 0.00 | 0.00 | 14 | 213,620 | 187,140 | 90 |
| ANSON WIND 2 | NGCA | 0.00 | 0.00 | 10 | 134,320 | 101,410 | 76 |
| BERTRAM WIND | NGCA | 0.00 | 0.00 | 10 | 212,000 | 160,200 | 75 |
| BROWNS WIND | NGCA | 0.00 | 0.00 | 114 | 410,047 | 428,649 | 100 |
| BUCKHORN WIND | NGCA | 0.00 | 0.00 | 10 | 12,840 | 12,840 | 100 |
| BUCKHORN WIND 2 | NGCA | 0.00 | 0.00 | 10 | 24,040 | 17,280 | 71 |
| BUCKHORN WIND 3 | NGCA | 0.00 | 0.00 | 10 | 24,040 | 17,280 | 71 |
| CALDWELL 2 WIND | NGCA | 0.00 | 0.00 | 210 | 214,920 | 178,980 | 83 |
| CALDWELL 3 WIND | NGCA | 0.00 | 0.00 | 224 | 181,071 | 169,449 | 93 |
| CALDWELL 4 WIND | NGCA | 0.00 | 0.00 | 238 | 213,876 | 191,012 | 88 |
| CALDWELL 5 WIND | NGCA | 0.00 | 0.00 | 110 | 194,072 | 164,070 | 85 |
| CEDARWOOD WIND | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| COOPER WIND | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| DEERFIELD WIND | NGCA | 0.00 | 0.00 | 10 | 231,760 | 204,440 | 88 |
| DODGE CITY WIND | NGCA | 0.00 | 0.00 | 423 | 240,710 | 205,357 | 85 |
| ELKHORN WIND | NGCA | 0.00 | 0.00 | 76.0 | 193,007 | 201,297 | 102 |
| ERICKSON WIND | NGCA | 0.00 | 0.00 | 79.0 | 217,022 | 221,419 | 102 |
| EVANS WIND | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| FISHER WIND | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| GARDEN WIND | NGCA | 0.00 | 0.00 | 76.0 | 144,783 | 210,267 | 138 |
| GOETZ WIND | NGCA | 0.00 | 0.00 | 88 | 21,676 | 21,672 | 99 |
| HOLLYWOOD WIND | NGCA | 0.00 | 0.00 | 124 | 322,018 | 368,018 | 112 |
| JORDAN WIND | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| KIDNEY SPRINGS WIND | NGCA | 0.00 | 0.00 | 52 | 210,840 | 204,332 | 98 |
| LAWRENCE WIND | NGCA | 0.00 | 0.00 | 52 | 212,223 | 192,178 | 90 |
| MADISON WIND | NGCA | 0.00 | 0.00 | 120 | 414,930 | 414,910 | 99 |
| MADISON WIND 2 | NGCA | 0.00 | 0.00 | 140 | 143,970 | 147,720 | 102 |
| MADISON WIND 3 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 4 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 5 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 6 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 7 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 8 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 9 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| MADISON WIND 10 | NGCA | 0.00 | 0.00 | 10 | 14,720 | 14,720 | 100 |
| TOTAL | | | | 2,041 | 4,753,237 | 4,821,530 | 101.0% |

* Wind Power in Millions of Kilowatts (MWh)
** Only one month of data available for reading

RESULTS: WIND ANALYSIS

Wind Power Generation in Texas

The chart shows monthly wind power generation in Texas from January to December. The highest generation is in March at approximately 3,000 GWh, while the lowest is in August at approximately 1,500 GWh.

Wind Power Generation in Ozone Season Period in Texas

This chart highlights the ozone season period, showing a significant peak in July at about 2,800 GWh, followed by June and August around 2,500 GWh.

ISSUES: WIND ANALYSIS

- Degradation?
- Distribution of power on the grid?
- Curtailment?

ISSUES: WIND ANALYSIS

Degradation? Measured Site Loss Capacity for Wind Farms

A bar chart showing measured site loss capacity for various wind farms across different regions. The highest capacity is in the Hill Country region, followed by the South Texas region.

Hourly Wind Power Generation

Two line graphs show hourly wind power generation from September 2007 to September 2008. The top graph shows a general decline in power output over time, while the bottom graph shows a more detailed daily variation.

ISSUES: WIND ANALYSIS

Distribution of power on the grid?

A map of the ERCOT region showing power flow distribution across four zones: North, South, West, and East. Pink arrows indicate power flow between these zones.

Curtailment? Measured Power vs. Measured Wind Speed

A scatter plot showing the relationship between measured wind speed and measured power. A red shaded area represents the 'Rate or Curve' for wind power generation, while green dots represent actual measured data points.

Figure 10-24: Slides presented on September 17, 2008 (Part 9)

ISSUES: WIND ANALYSIS

Curtailment?

| | |
|---|---|
| Predicted MWH in 2002 Grid Using Power and Demand | 2002-2003 Measured MWh and Demand Factor for 2002 |
| 114,000 | 114,000 |
| Curtailment and Demand Factor for 2003 | 2003-2004 Measured Mwh and Demand Factor |
| 20,000 | 20,000 |

INTEGRATED NOX SAVINGS

IN 2005 TCEQ INITIATED A PROGRAM TO DETERMINE INTEGRATED EMISSIONS SAVINGS (2009 & BEYOND) TO REPORT SAVINGS TO EPA

State Agencies included:
TEES/SECOS,
- PUC,
- SECOS,
- EROOT/Wind

INTEGRATED NOX SAVINGS

INTEGRATED EMISSIONS SAVINGS (2013)

- OGD City/Key
- SECOS
- PUC
- SECOS Political Sub.
- Green Power (Wind)
- Residential AC Retrofits
- Total (58.5 tons/day)

RELATED WORK: 15% ABOVE CODE

Natural Gas Heating (Bastrop, Caldwell, Hays, Travis and Williamson Counties)

Table 1a: 15% Above Code Savings (Residential - Natural Gas Heating)
Bastrop, Caldwell, Hays, Travis and Williamson Counties

| Category | Total Residential Units | Estimated Savings | Estimated Cost |
|-------------------|-------------------------|-------------------|----------------|
| Residential Units | 1,000,000 | \$15,000,000 | \$15,000,000 |
| Commercial Units | 100,000 | \$1,500,000 | \$1,500,000 |
| Total | 1,100,000 | \$16,500,000 | \$16,500,000 |

Table 1b: 15% Above Code Savings (Commercial - Natural Gas Heating)
Bastrop, Caldwell, Hays, Travis and Williamson Counties

| Category | Total Commercial Units | Estimated Savings | Estimated Cost |
|------------------|------------------------|-------------------|----------------|
| Commercial Units | 100,000 | \$1,500,000 | \$1,500,000 |
| Total | 100,000 | \$1,500,000 | \$1,500,000 |

RELATED WORK: ecalc.tamu.edu

RELATED WORK: ICCC CALCULATOR

Figure 10-25: Slides presented on September 17, 2008 (Part 10)

August 2009

Energy Systems Laboratory, Texas A&M University System

RELATED WORK: ICCC CALCULATOR

Inputs simplified to match basic house configuration for 2006 Code, includes:

- 1 or 2 floors
- House dimensions
- Orientation
- R-values
- SHGC
- Heating/Cooling efficiencies

RELATED WORK: ICCC CALCULATOR

Provides synchronous feedback to user:

- Checking of inputs
- Context-sensitive help screens automatically appear
- Additional help provided if requested

RELATED WORK: ICCC CALCULATOR

Provides additional features (if requested):

- Shading by overhangs
- Wall R-values
- Ceiling R-values

RELATED WORK: ICCC CALCULATOR

Provides additional features (if requested):

- Window SHGC
- Window U-value
- Area by Orientation
- Cooling Efficiency
- Heating Efficiency
- DHW Efficiency
- Duct in Conditioned Space?

STATE OF TEXAS
Home Energy Report

Home Address: Austin

Energy Score: **A+**

This indicates the approximate energy usage of the same home built to current Texas Building Energy Performance Standard.

Home Features

| | |
|---|--------------------|
| Year Built: | 2008 |
| Total Floor Area: | 2500 sq ft |
| Average Ceiling Height: | 8 ft |
| Home Facing: | South |
| Wall Insulation R-Rating: | 13 |
| Ceiling Insulation R-Rating: | 38 |
| Total Window Area: | 400 sq ft |
| Window Type: | Double Pane, Low-E |
| Mechanical requirement, in conditioned space: | No |
| Heating Type: | Natural Gas |
| Year Furnace Installed: | 2008 |
| A/C Efficiency SEER: | 11 |
| Water Heater Date of Mfg: | 2008 |

Comments:

Concise #: 001
IRIS Data Entered By: Home Owner
Date: 8/17/2008

Emissions Reduction for County:

| | | | |
|------|---------------|-----------|---------|
| MEIC | Date Baseline | Last Date | Current |
| SOR | | | |
| CGI | | | |

This section will document emissions reductions that are a result of confirmed energy efficiency improvements over time.

The data from this report is approximate in nature. It gives a score based on general inputs from the user provided. The score represents an estimated annual energy consumption and cost savings compared to a standard and standard energy characteristics used in building modeling (i.e. thermostat, temperature, equipment types, plug-in receptacles, average number of occupants, type of fuel used, etc.). The score is not a precise energy usage and may be based on these and other factors.

For additional information about the energy performance of this home, please contact the Homeowner, their energy provider and ask for a comprehensive energy audit. This will include an inspection of the energy system and building envelope, identification of potential energy savings, and recommendations for the integrity of the HVAC duct systems. The next result of a comprehensive energy audit will be a detailed analysis of energy costs per gallon for a vehicle—and suggestions of new, low-cost and other arrangements that can be made to make the home more energy efficient.

Logos: **SECO**, **HERO**




Figure 10-26: Slides presented on September 17, 2008 (Part 11)

FUTURE WORK: HELPING OTHER STATES

Air Quality
Excellent
Good
Moderate
Unhealthy
Very Unhealthy
Hazardous

May 30, 2006 12:00 am EDT
June 17, 2006 12:00 am EDT
July 1, 2006 12:00 am EDT
July 10, 2006 12:00 am EDT

ESL Contact Information

Jeff Haberl: jeffhaberl@ees.tamu.edu
Bahman Yazdani: bahmanyazdani@ees.tamu.edu
Charles Culp: charlesculp@ees.tamu.edu
<http://eslsb5.tamu.edu>

Figure 10-27: Slides presented on September 17, 2008 (Part 12)

10.5 Presentation on September 25, 2008

September 25, 2008 – Presentation to the EPA Blue Skyways conference about calculation of NOx emissions reductions from energy efficiency and renewable energy, Kansas City, MO

QUANTIFICATION OF ENERGY AND EMISSIONS SAVED IN ENERGY EFFICIENCY/RENEWABLE ENERGY (EE/RE) PROGRAMS IN TEXAS

September 25, 2008

Jeff S. Haberl
Energy Systems Laboratory
Texas A&M University

ACKNOWLEDGEMENTS

Faculty/Staff: Charles Culp, Bahman Yazdani, Cynthia Montgomery, Betty Liu, Juan Carlos Baltazar, Jaya Mukhopadhyay, Don Gilman, Kyle Marshall, Robert Stackhouse, Kathy McElveen, Jason Cordes, Larry Degelman, Sherrie Hughes, Jessica Coffin, Stephen O'Neal.

Students: Mini Malhotra, Piljae Im, Simge Andolsun, Hyojin Kim, Sandeep Kota, Hee Jo, Grant Marvin, Matt Moss, Craig Menning.

TCEQ: Steve Anderson, Alfred Reyes, Vince Meiller, Theresa Pella.

TPUC: Theresa Gross, Jess Totten

SECO: Dub Taylor, Glenn Jennings

HARC: David Hitchcock, Dan Bullock

ERCOT: Warren Lasher

USEPA: Art Diem, Julie Rosenberg.

BACKGROUND

- U.S.E.P.A. closely monitors areas that exceed safe levels of Ozone.
- Reducing oxides of nitrogen (NO_x) contributes to reductions in Ozone.
- Hence, controlling NO_x emissions is a priority in Texas.

Houston...we have a problem!

Houston: Clear day vs. Ozone day

LEGISLATIVE RESPONSE

41 Counties in Texas designated non-attainment or affected.

TEPP Amended (77th Legislature, 2001)
Ch. 291, Texas Energy Policy Plan
Sec. 291.291, Revision Of State Energy Efficiency Programs (w/o FUD)
Ch. 292, Texas Building Energy Performance Standards
Sec. 292.1, Adoption Of Uniform Energy Efficiency Performance Standards
Sec. 292.101, Adoption Of Uniform Energy Efficiency Performance Standards
Sec. 292.102, Distribution Of Information And Technical Assistance
Sec. 292.103, Development Of Energy Ratings

TEPP Amended (78th Legislature, 2003)
Ch. 293, Texas Building Energy Performance Standards
Sec. 293.1, Revision Of Energy Standards Outside Of Municipalities
Sec. 293.2, Energy Efficient Building Program
Ch. 294, Texas Building Energy Performance Standards
Sec. 294.1, Certification Of Municipal Inspectors

TEPP Amended (79th Legislature, 2005)
Ch. 295, Health and Safety Code
Sec. 295.1, Development Of Creditable Reductions From Non-Credit Generating Sources
Sec. 295.2, Credit For Conservation Action Relating To Water Use

ENERGY EMISSIONS - IMPACT FACTOR

| | Use | NOx | Upgrade | Impact |
|-------------|-----|-----|------------|--------|
| Industries: | 60% | 23% | 5 – 20 yr | Factor |
| Vehicles: | 19% | 54% | 7 – 10 yr | 4 – 5 |
| Buildings: | 21% | 22% | 25 – 50 yr | 5 – 11 |

Buildings substantially impact emissions!

SOURCE: Residential Use, USEPA, 1999
Data on Emissions: TACCC 2002

WHY SPATIAL & TEMPORAL TRACKING?

Dallas-Fort Worth Region
North-Central Texas
July 20, 2003 8:00 AM

Houston-Galveston-Brazoria Region
Sulfur Texas
July 20, 2003 8:00 AM

Air Quality
Harmless
Very Unlikely
Unlikely
Likely
Moderate
Severe

Figure 10-28: Slides presented on September 25, 2008 (Part 1)

WHERE'S THE POTENTIAL FOR EE/RE?

- 41 counties represent 70.5% of the state's population
- Harris, Dallas, Tarrant, Bexar contain 40.0% of the state's population
- Housing trends follow population
- Harris, Dallas counties have the most housing starts (SF,MF)

SPATIAL & TEMPORAL TRACKING

- Required NOAA, NREL/UT & TOEG weather data sources to be gathered, meshing data filed, and prepared for use by EERE applications

IECC CODE SF, MF SAVINGS

Quantify the reduction of NOx emissions due to the implementation of 2000 IECC with 2001 Supplement for new residential construction:

- Prototype simulation models were created for both single and multifamily configurations using DOE-2.1e simulation software
- The simulation models were then modified to accommodate the different scenarios for envelope and HVAC systems found typically in residences
- These simulation models were then linked to a web-based graphic user interface and US-EPA's eGRID to convert the energy savings to NOx emissions reduction

"ecalc.tamu.edu"

HOW MUCH SAVINGS? SF & MF

PRECODE VS 2000/2001 IECC

- For both single and multifamily houses with electric/H/AC equipment have lower annual energy consumption
- For single family, a house with slab-on-grade is the least consumptive vs a house with crawl space

| | Single Family | Multifamily |
|--|---------------|-------------|
| Annual Energy Use per House (Precode vs Old) | | |
| Annual Energy Use per Household | | |

- Similarly 2-story single family house uses less energy than 1-story house
- For multifamily, less savings for code-compliance due to less window area
- 128,804 single family
- 29,972 multifamily

HOW MUCH SAVINGS? COMMERCIAL

To quantify the reduction of NOx emissions due to the implementation of ASHRAE Standard 90.1-1999:

- Prototype simulation models were created using the DOE-2.1e simulation software
- 1-story
3 story
100 story
- The models were then modified to accommodate the requirements of both ASHRAE Standard 90.1-1989 (base year) and 1999 (new construction).
- The models were then linked to a web-based graphic user interface and US-EPA's eGRID to convert the energy savings to NOx emissions reduction

HOW MUCH SAVINGS? COMMERCIAL

Comparison Between ASHRAE ASHRAE 90.1-1989 AND 1999:

- For the same building, ASHRAE 90.1-1999 is 13.4% less consumptive than ASHRAE 90.1-1989
- More stringent requirements for the lighting power density (LPD) in 1999 make up for 45% of the total decrease
- Boiler staging in 1999 also allows for a 12% decrease in the annual energy consumption as compared to 1989
- More stringent envelope requirements also help in decreasing fan and auxiliary energy consumption in 1999

| | ASHRAE 90.1-1989 | ASHRAE 90.1-1999 |
|--|------------------|------------------|
| Annual Energy Consumption (ASHRAE 90.1-1989 vs 1999) | | |

Figure 10-29: Slides presented on September 25, 2008 (Part 2)




Figure 10-30: Slides presented on September 25, 2008 (Part 3)




Figure 10-31: Slides presented on September 25, 2008 (Part 4)

METHODOLOGY: WIND ENERGY

Modeled daily electricity vs daily wind data (on-site vs NOAA).

Result: on-site, 3P CP on-site model, acceptable.

Modeled daily electricity vs daily wind data (NOAA).

Result: 3P CP NOAA model also acceptable.

METHODOLOGY: WIND ENERGY

Capacity Factors Using Daily Models

Next, compared NOAA and on-site daily models to see how well the predicted OSP electricity production. (Result: acceptable).

RESULTS: WIND ANALYSIS – ALL SITES

Method used to Analyze Total Wind Production in 2007.

Wind Power Generation in Texas

Wind Power Generation in Ozone Season Periods in Texas

Results: Weather-normalizing to 1999 produces more savings.

RESULTS: WIND ANALYSIS – ALL SITES

Final result: prediction of NOx reduction in 1999 and 2007 (annual and OSP) by county using EPA's 2007 eGRID.

| Area | 2007 NOx Reduction (t/yr) | 1999 NOx Reduction (t/yr) |
|---------------|---------------------------|---------------------------|
| ATM | 2.0E+00 | 2.0E+00 |
| CDEMO | 2.0E+00 | 2.0E+00 |
| Central | 2.0E+00 | 2.0E+00 |
| East | 2.0E+00 | 2.0E+00 |
| Gulf Coast | 2.0E+00 | 2.0E+00 |
| North Central | 2.0E+00 | 2.0E+00 |
| North | 2.0E+00 | 2.0E+00 |
| South Central | 2.0E+00 | 2.0E+00 |
| Southeast | 2.0E+00 | 2.0E+00 |
| South | 2.0E+00 | 2.0E+00 |
| West | 2.0E+00 | 2.0E+00 |

FUTURE ISSUES: WIND ANALYSIS

- Degradation?
- Distribution of power on the grid?
- Curtailment?

ISSUES: WIND ANALYSIS

Degradation?

Figure 10-32: Slides presented on September 25, 2008 (Part 5)









Figure 10-33: Slides presented on September 25, 2008 (Part 6)





Figure 10-34: Slides presented on September 25, 2008 (Part 7)

10.6 Presentation on September 30, 2008

September 30, 2008 – Presentation to the Texas Senate Natural Resources Committee about the calculation of NOx emissions reductions from energy efficiency and renewable energy, Austin, Texas



TESTIMONY TO THE SENATE COMMITTEE ON NATURAL RESOURCES

September 30, 2008

Jeff Haberi, Ph.D., P.E.
Bahman Yazdani, P.E.

Energy Systems Laboratory
Texas Engineering Experiment Station
Texas A&M University System



HISTORY – ENERGY SYSTEMS LAB

ESL is Internationally Recognized for Excellence in Building Efficiency

- Energy Efficiency in Buildings
- Continuous Commissioning® Technology
- Measurement and Verification Methodologies
- Air Conditioning / Refrigeration Technologies
- EPA for Air Pollution Reductions from Energy Efficiency





TEES TECHNOLOGY TRANSFER

ESL Founded / Host

- Hot & Humid Building Symposium
- Int'l Conference on Enhanced Building Operations
- Industrial Energy Technology Conference
- Clean Air Through Energy Efficiency Conference





Senate Bill 5 (77th Legislature, 2001)

Ch. 205. Texas Greenhouse Reduction Plan
Sec. 395.001. Adoption Of Building Energy Efficiency Programs (with PUC)

Ch. 206. Texas Building Energy Performance Standards
Sec. 395.002. Adoption Of Building Energy Efficiency Performance Standards.
Sec. 395.003. Enforcement Of Energy Standards Outside Of Municipality.
Sec. 395.007. Dissemination Of Information And Technical Assistance.
Sec. 395.008. Development Of Home Energy Ratings.

TERP Amended @ (78th Legislature, 2003)

Ch. 207. Texas Energy Efficient Residential Performance Standards
PUB 32251 Sec. 396.001. Adoption Of Energy Standards Outside Of Municipality.
PUB 32251 Sec. 396.002. Energy-Efficient Building Programs.

Ch. 208. Texas Building Energy Performance Standards

PUB 32251 Sec. 396.003. Certification Of Municipal Inspectors.

TERP Amended @ (79th Legislature, 2005)

Ch. 209. Health and Safety Code
PUB 32251 Sec. 396.004. Use of Qualified Standard-Bearer Institutions from Wind and other renewables.
PUB 32251 Sec. 396.005. Certification Action Related to Water Heater.


TERP Amended @ (80th Legislature, 2007)

Ch. 210. Health and Safety Code
(SB 2499) Sec. 398.002 added section (b)(1), (b)(2) of law SECO to adopt new editions of the IFC
based on recommendations from the Laboratory.
Sec. 398.003. SECO to adopt new editions of the IECC based on recommendations from the Laboratory.




Legislative Summary

1. Evaluation Of State Energy Efficiency Programs (with PUC).
2. Building Energy Efficiency Performance Standards.
3. Information and Technical Assistance.
4. Development of Creditable Statewide NOx Emissions Reductions Credits From Energy Efficiency and Renewable Energy.
5. Development Of Home Energy Ratings.
6. Certification of Municipal Inspectors.
7. Development of Creditable Statewide NOx Emissions Credits from Wind and Other Renewables.
8. Evaluate IECC/ASHRAE Standard for Stringency and Report to SECO.
9. Development of Standardized Report Formats for Newly Constructed Residences.




RENEWABLES: WHAT ARE THEY?

Landfill gas, hydro are next



Wind energy is the largest portion



Biomass, solar are smallest




Figure 10-35: Slides presented on September 30, 2008 (Part 1)

WIND PROJECTS IN TEXAS

Total Wind Power Generation Capacity (GW)

Year

TEES

INTEGRATED NOX SAVINGS

Integrated Emissions Savings Across Agencies (2007 & Beyond) To Report Savings To TCEQ/EPA

TCEQ

State Agencies included:

- TEES/ESL
- PUC
- SECO
- ERCOT/Wind

TEES

INTEGRATED NOx SAVINGS

2007 Integrated NOx Emissions Savings (2013)

OSD NOx reduction levels (Preliminary Estimates) All ERCOT

| Program | Reduction Level | Amount (tons/OSD) |
|--------------------------|-----------------|-------------------|
| ESL Code Compliance | 11.9 tons/OSD | |
| PUC SE5,SB7 programs | 4.8 tons/OSD | |
| SECO Political Sub. | 0.92 tons/OSD | |
| Green Power (Wind) | 26.6 tons/OSD | |
| Residential AC Retrofits | 11.0 tons/OSD | |
| Total | 58.5 tons/OSD | |

TEES

IMPACT OF THE WORK

Significant TERP Technical Contributions

- Quantification of Creditable NOx Emissions Reductions from EE/RE
- Updated Emissions & Generation Resource Integrated Database (eGRID) for Texas
- Defining Technology for Assessing Energy Efficiency Impact on Pollution Reduction
 - EPA Center of Excellence for Emissions Reduction

TEES

DIRECT APPROPRIATIONS

TERP Funding Received

- 2002: \$182,000
- 2003: \$950,421
- 2004 - 2008: \$952,019/yr

TEES

TEES/ESL Contact Information

Jeff Haberl: jeffhaberl@tees.tamus.edu

Bahman Yazdani: bahmanyazdani@tees.tamus.edu

Charles Culp: charlesculp@tees.tamus.edu

<http://eslsb5.tamu.edu>

TEES

Figure 10-36: Slides presented on September 25, 2008 (Part 2)

11 APPENDIX B

In this section, the linear regression models developed, based on 2007 wind power generation data, are presented for each wind farm. The estimated 1999 annual and OSP power production using 2007 daily models and the resulting emissions reduction are also shown in details for each wind farm. A listing of the wind farms analyzed in this year's report is illustrated in Table 11-1.

| No. | Wind Farms |
|-----|------------------------------------|
| 1 | Brazos Wind Ranch |
| 2 | Buffalo Gap 1 |
| 3 | Callahan Divide Wind Energy Center |
| 4 | Horse Hollow 1 |
| 5 | Horse Hollow 2 |
| 6 | Horse Hollow 3 |
| 7 | Horse Hollow 4 |
| 8 | Desert Sky |
| 9 | King Mountain Wind Ranch (KING_NE) |
| 10 | King Mountain Wind Ranch (KING_NW) |
| 11 | King Mountain Wind Ranch (KING_SE) |
| 12 | King Mountain Wind Ranch (KING_SW) |
| 13 | Sweetwater Wind 2 |
| 14 | Sweetwater Wind 3 |
| 15 | Sweetwater Wind 4 |
| 16 | Trent Mesa |
| 17 | Delaware Mountain Wind Farm |
| 18 | Indian Mesa I |
| 19 | Texas Wind Power Project |
| 20 | Big Spring Wind Power |
| 21 | Southwest Mesa Wind Project |
| 22 | Woodward Mountain Ranch (WOODWRD1) |
| 23 | Woodward Mountain Ranch (WOODWRD1) |
| 24 | Buffalo Gap2 |
| 25 | Capricorn Ridge Wind |
| 26 | Camp Springs Wind Energy Center |
| 27 | Lone Star – Mesquite Wind |
| 28 | Forest Creek Wind Farm |
| 29 | Sand Bluff Wind Farm |

Table 11-1: Listing of Wind Farms Analyzed for Base-year Calculations

11.1 Brazos Wind Ranch

Table 11-2: Site Information for Brazos Wind Ranch

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|----------------------------------|-------------|--------------------------|--------|----------|-----------------|-----------------|
| BRAZ_WIND | WIND | Fluvana | SCURRY | Dec-03 | 160 | Cielo/Orion/Green Mountain Ranch | Brazos Wind | Mitsubishi 1000 (160) | ERCOT | AEP-West | ONCOR | ABI |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| BRAZ_WND_WND1 | BRAZ_WIND | 99 |
| BRAZ_WND_WND2 | BRAZ_WIND | 61 |

11.1.1 Brazos Wind Ranch – BRAZ_WND_WND1




Figure 11-1: BRAZ_WND_WND1 - Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-2: BRAZ_WND_WND1 - Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non OSP Model)

Table 11-3: BRAZ_WND_WND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -421.4768 |
| Left Slope (MWh/mph-day) | 120.1077 |
| RMSE (MWh/day) | 316.5002 |
| R2 | 0.7010 |
| CV-RMSE | 37.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -440.0611 |
| Left Slope (MWh/mph-day) | 134.78 |
| RMSE (MWh/day) | 291.0298 |
| R2 | 0.7238 |
| CV-RMSE | 43.7% |

Table 11-4: BRAZ_WND_WND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | 25 | 9.47 | 19,034 | 17,885 | 6.03% | 32% | 30% |
| Feb-07 | 27 | 11.99 | 26,972 | 27,490 | -1.92% | 42% | 43% |
| Mar-07 | 31 | 11.82 | 27,909 | 30,929 | -10.82% | 38% | 42% |
| Apr-07 | 30 | 12.85 | 30,084 | 33,667 | -11.91% | 42% | 47% |
| May-07 | 31 | 9.32 | 19,636 | 21,658 | -10.30% | 27% | 29% |
| Jun-07 | 30 | 9.53 | 19,316 | 21,688 | -12.28% | 27% | 30% |
| Jul-07 | 31 | 6.95 | 12,702 | 14,493 | -14.10% | 17% | 20% |
| Aug-07 | 31 | 9.10 | 27,452 | 24,402 | 11.11% | 37% | 33% |
| Sep-07 | 30 | 9.04 | 22,570 | 21,314 | 5.57% | 32% | 30% |
| Oct-07 | 31 | 11.05 | 31,882 | 28,091 | 11.89% | 43% | 38% |
| Nov-07 | 30 | 10.37 | 26,318 | 24,710 | 6.11% | 37% | 35% |
| Dec-07 | 30 | 10.64 | 27,871 | 25,709 | 7.76% | 39% | 36% |
| Total | 357 | 10.16 | 291,745 | 292,035 | -0.10% | 34% | 34% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 41,929 | 42,154 | -0.54% | 28% | 28% |




Figure 11-3: BRAZ_WND_WND1 - Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-4: BRAZ_WND_WND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-5: BRAZ_WND_WND1 – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr |
|---|----------------------|
| 349,118 | 298,283 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
|--|------------------------------|
| 869 | 666 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.1.2 Brazos Wind Ranch – BRAZ_WND_WND2




Figure 11-5: BRAZ_WND_WND2 - Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-6: BRAZ_WND_WND2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-6: BRAZ_WND_WND2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -258.1860 |
| Left Slope (MWh/mph-day) | 72.2890 |
| RMSE (MWh/day) | 185.8624 |
| R2 | 0.7106 |
| CV-RMSE | 36.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -224.0026 |
| Left Slope (MWh/mph-day) | 76.1986 |
| RMSE (MWh/day) | 161.6706 |
| R2 | 0.7307 |
| CV-RMSE | 40.3% |

Table 11-7: BRAZ_WND_WND2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|-------------------|--------------------------|---|
| Jan-07 | 26 | 9.39 | 11,991 | 10,941 | 8.76% | 32% | 29% |
| Feb-07 | 28 | 12.04 | 16,136 | 17,144 | -6.25% | 39% | 42% |
| Mar-07 | 31 | 11.82 | 17,355 | 18,475 | -6.46% | 38% | 41% |
| Apr-07 | 30 | 12.85 | 18,367 | 20,128 | -9.59% | 42% | 46% |
| May-07 | 31 | 9.32 | 12,226 | 12,906 | -5.57% | 27% | 28% |
| Jun-07 | 30 | 9.53 | 11,521 | 12,922 | -12.16% | 26% | 29% |
| Jul-07 | 31 | 6.95 | 7,392 | 8,722 | -18.00% | 16% | 19% |
| Aug-07 | 31 | 9.10 | 16,167 | 14,547 | 10.02% | 36% | 32% |
| Sep-07 | 30 | 9.04 | 13,693 | 12,817 | 6.40% | 31% | 29% |
| Oct-07 | 31 | 11.05 | 19,452 | 16,772 | 13.78% | 43% | 37% |
| Nov-07 | 30 | 10.37 | 14,609 | 14,737 | -0.88% | 33% | 34% |
| Dec-07 | 30 | 10.64 | 16,396 | 15,338 | 6.45% | 37% | 35% |
| Total | 359 | 10.17 | 175,304 | 175,449 | -0.08% | 33% | 33% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 25,267 | 25,351 | -0.33% | 27% | 27% |




Figure 11-7: BRAZ_WND_WND2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-8: BRAZ_WND_WND2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-8: BRAZ_WND_WND2 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 208,329 | 178,234 | 516 | 401 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.2 Buffalo Gap 1- BUFF_GAP_UNIT1 120 MW)

Table 11-9: Site Information for Buffalo Gap 1

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|-------------------|---------|--------|-----------------|---------------|-----------------|--------------|--------------------------|--------|----------|-----------------|-----------------|
| BUFF_CAP | WIND | Abilene | TAYLOR | Sep-05 | 120 | AES Corporation | Buffalo Gap1 | Vestas 1.8 MW (67) | ERCOT | AEP-West | AEP-TNC | ABI |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | | | | | | | | | | | |
| BUFF_GAP_UNIT1 | BUFF_CAP | | | | 120 | | | | | | | |

11.2.1 Buffalo Gap 1 – BUFF_GAP_UNIT1 120 MW)




Figure 11-9: BUFF_GAP_UNIT1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-10: BUFF_GAP_UNIT1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-10: BUFF_GAP_UNIT1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -512.9856 |
| Left Slope (MWh/mph-day) | 143.6510 |
| RMSE (MWh/day) | 338.9861 |
| R2 | 0.7515 |
| CV-RMSE | 33.9% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -755.9293 |
| Left Slope (MWh/mph-day) | 177.5969 |
| RMSE (MWh/day) | 298.2919 |
| R2 | 0.8124 |
| CV-RMSE | 42.6% |

Table 11-11: BUFF_GAP_UNIT1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 27 | 8.61 | 22,636 | 19,802 | 12.52% | 29% | 25% |
| Feb-07 | 23 | 12.82 | 26,797 | 30,548 | -14.00% | 40% | 46% |
| Mar-07 | 31 | 11.82 | 34,028 | 36,716 | -7.90% | 38% | 41% |
| Apr-07 | 30 | 12.85 | 37,900 | 40,000 | -5.54% | 44% | 46% |
| May-07 | 31 | 9.32 | 22,775 | 25,649 | -12.62% | 26% | 29% |
| Jun-07 | 30 | 9.53 | 23,387 | 25,681 | -9.81% | 27% | 30% |
| Jul-07 | 31 | 6.95 | 14,093 | 15,624 | -10.87% | 16% | 18% |
| Aug-07 | 31 | 9.10 | 28,919 | 27,036 | 6.51% | 32% | 30% |
| Sep-07 | 30 | 9.04 | 23,852 | 24,033 | -0.76% | 28% | 28% |
| Oct-07 | 31 | 11.05 | 35,735 | 33,330 | 6.73% | 40% | 37% |
| Nov-07 | 30 | 10.37 | 34,807 | 29,287 | 15.86% | 40% | 34% |
| Dec-07 | 31 | 10.51 | 32,088 | 30,885 | 3.75% | 36% | 35% |
| Total | 356 | 10.12 | 337,016 | 338,592 | -0.47% | 33% | 33% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 44,157 | 45,358 | -2.72% | 24% | 25% |




Figure 11-11: BUFF_GAP_UNIT1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-12: BUFF_GAP_UNIT1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-12: BUFF_GAP_UNIT1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured Mwh/day |
| 410,441 | 345,536 | 968 | 701 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.3 Callahan Divide Wind Energy Center

Table 11-13: Site Information for Callahan Divide Wind Energy Center

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|------------|------------------------------------|--------------------------|--------|----------|-----------------|-----------------|
| CALLAHAN | WIND | Abilene | TAYLOR | Feb-07 | 114 | FPL Energy | Callahan Divide Wind Energy Center | GE Wind 1500 (76) | ERCOT | AEP-West | AEP-TNC | ABI |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| CALLAHAN_WND1 | CALLAHAN | 114 |

11.3.1 Callahan Divide – CALLAHAN_WND1




Figure 11-13: CALLAHAN_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-14: CALLAHAN_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-14: CALLAHAN_WND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -508.4787 |
| Left Slope (MWh/mph-day) | 150.9719 |
| RMSE (MWh/day) | 308.0617 |
| R2 | 0.7965 |
| CV-RMSE | 28.4% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -670.43 |
| Left Slope (MWh/mph-day) | 175.8471 |
| RMSE (MWh/day) | 288.3808 |
| R2 | 0.8196 |
| CV-RMSE | 37.4% |

Table 11-15: CALLAHAN_WND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 27 | 9.22 | 25290.46 | 23864.98 | 5.64% | 34% | 32% |
| Feb-07 | 28 | 12.04 | 35598.91 | 36665.27 | -3.00% | 46% | 48% |
| Mar-07 | 31 | 11.82 | 37067.78 | 39536.89 | -6.66% | 44% | 47% |
| Apr-07 | 30 | 12.85 | 39244.03 | 42957.87 | -9.46% | 48% | 52% |
| May-07 | 31 | 9.32 | 25179.73 | 27848.10 | -10.60% | 30% | 33% |
| Jun-07 | 30 | 9.53 | 26789.93 | 27885.85 | -4.09% | 33% | 34% |
| Jul-07 | 31 | 6.95 | 15738.17 | 17429.04 | -10.74% | 19% | 21% |
| Aug-07 | 31 | 9.10 | 31287.40 | 29032.70 | 7.21% | 37% | 34% |
| Sep-07 | 30 | 9.04 | 26102.97 | 26177.70 | -0.29% | 32% | 32% |
| Oct-07 | 31 | 11.05 | 38048.96 | 35949.60 | 5.52% | 45% | 42% |
| Nov-07 | 30 | 10.37 | 35599.08 | 31699.25 | 10.95% | 43% | 39% |
| Dec-07 | 31 | 10.51 | 35809.09 | 33409.59 | 6.70% | 42% | 39% |
| Total | 361 | 10.14 | 371756.52 | 372456.86 | -0.19% | 38% | 38% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 48639.21 | 49328.02 | -1.42% | 28% | 29% |




Figure 11-15: CALLAHAN_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-16: CALLAHAN_WND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-16: CALLAHAN_WND1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured Mwh/day for Modeling |
| 441,790 | 375,876 | 1,037 | 772 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.4 Horse Hollow 1

Table 11-17: Site Information for Horse Hollow 1

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|--------|-----------------|---------------|------------|----------------|--------------------------|--------|----------|-----------------|-----------------|---------|
| H_HOLLOW | WIND | Abilene | TAYLOR | Oct-05 | 213 | FPL Energy | Horse Hollow 1 | GE Energy 1.5 MW (142) | ERCOT | AEP-West | AEP-TNC | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| H_HOLLOW_WND1 | H_HOLLOW | 213 | | | | | | | | | | | |

11.4.1 Horse Hollow 1 – H_HOLLOW_WND1




Figure 11-17: H_HOLLOW_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-18: H_HOLLOW_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-18: H_HOLLOW_WND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -770.9260 |
| Left Slope (MWh/mph-day) | 241.2034 |
| RMSE (MWh/day) | 506.3179 |
| R2 | 0.7895 |
| CV-RMSE | 28.9% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -1204.21 |
| Left Slope (MWh/mph-day) | 286.0818 |
| RMSE (MWh/day) | 445.9872 |
| R2 | 0.8341 |
| CV-RMSE | 39.0% |

Table 11-19: H_HOLLOW_WND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 29 | 8.77 | 45,784 | 39,321 | 14.12% | 30% | 26% |
| Feb-07 | 28 | 12.04 | 62,790 | 59,740 | 4.86% | 42% | 40% |
| Mar-07 | 30 | 11.71 | 62,813 | 61,595 | 1.94% | 40% | 39% |
| Apr-07 | 29 | 12.73 | 67,036 | 66,697 | 0.50% | 44% | 44% |
| May-07 | 31 | 9.32 | 39,289 | 45,759 | -16.47% | 24% | 28% |
| Jun-07 | 30 | 9.53 | 39,005 | 45,796 | -17.41% | 25% | 29% |
| Jul-07 | 31 | 6.95 | 21,488 | 27,052 | -25.89% | 13% | 17% |
| Aug-07 | 31 | 9.10 | 47,572 | 43,941 | 7.63% | 29% | 27% |
| Sep-07 | 30 | 9.04 | 38,027 | 41,259 | -8.50% | 24% | 26% |
| Oct-07 | 31 | 11.05 | 56,672 | 58,721 | -3.61% | 35% | 36% |
| Nov-07 | 30 | 10.37 | 56,346 | 51,889 | 7.91% | 36% | 33% |
| Dec-07 | 31 | 10.51 | 57,464 | 54,663 | 4.87% | 35% | 33% |
| Total | 361 | 10.07 | 594,286 | 596,432 | -0.36% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 71,979 | 73,805 | -2.54% | 22% | 22% |




Figure 11-19: H_HOLLOW_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-20: H_HOLLOW_WND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-20: H_HOLLOW_WND1 – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|---|--------------------------------------|
| 713,071 | 600,871 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured Mwh/day for Modeling |
|--|---|
| 1,573 | 1,143 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.5 Horse Hollow 2

Table 11-21: Site Information for Horse Hollow 2

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|-------------------|---------------|--------|-----------------|---------------|------------|----------------------|--------------------------|--------|----------|-----------------|-----------------|
| HHOLLOW2_WIND1 | WIND | Abilene | Taylor | Jul-06 | 224 | FPL Energy | Horse Hollow Phase 2 | Mitsubishi 1000 (160) | ERCOT | AEP-West | AEP/TNC | ABI |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | |
| HHOLLOW2_WIND1 | HHOLLOW2_WIND1 | 224 | | | | | | | | | | |

11.5.1 Horse Hollow 2 – H_HOLLOW2_WIND1




Figure 11-21: H_HOLLOW2_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-22: H_HOLLOW2_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-22: H_HOLLOW2_WIND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -899.9714 |
| Left Slope (MWh/mph-day) | 228.8232 |
| RMSE (MWh/day) | 428.5336 |
| R2 | 0.8169 |
| CV-RMSE | 28.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -1049.7244 |
| Left Slope (MWh/mph-day) | 248.2213 |
| RMSE (MWh/day) | 398.2780 |
| R2 | 0.8260 |
| CV-RMSE | 40.4% |

Table 11-23: H_HOLLOW2_WIND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | 26 | 9.39 | 35,522 | 32,564 | 8.33% | 30% | 28% |
| Feb-07 | 27 | 11.91 | 47,738 | 49,296 | -3.26% | 39% | 41% |
| Mar-07 | 31 | 11.82 | 54,832 | 55,917 | -1.98% | 39% | 40% |
| Apr-07 | 30 | 12.85 | 61,861 | 61,231 | 1.02% | 46% | 45% |
| May-07 | 30 | 9.05 | 34,139 | 35,490 | -3.96% | 25% | 26% |
| Jun-07 | 30 | 9.53 | 33,677 | 38,505 | -14.34% | 25% | 29% |
| Jul-07 | 31 | 6.95 | 18,209 | 22,003 | -20.84% | 13% | 16% |
| Aug-07 | 31 | 9.10 | 40,582 | 37,984 | 6.40% | 29% | 27% |
| Sep-07 | 30 | 9.04 | 32,559 | 35,369 | -8.63% | 24% | 26% |
| Oct-07 | 29 | 10.47 | 45,161 | 43,474 | 3.74% | 35% | 33% |
| Nov-07 | 30 | 10.37 | 47,336 | 44,167 | 6.69% | 35% | 33% |
| Dec-07 | 30 | 10.36 | 46,178 | 44,109 | 4.48% | 34% | 33% |
| Total | 355 | 10.05 | 497,793 | 500,110 | -0.47% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 62,146 | 63,769 | -2.61% | 22% | 23% |




Figure 11-23: H_HOLLOW2_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-24: H_HOLLOW2_WIND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-24: H_HOLLOW2_WIND1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 617,443 | 511,815 | 1,360 | 986 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and it was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.6 Horse Hollow 3

Table 11-25: Site Information for Horse Hollow 3

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|-------------------|---------|--------|-----------------|---------------|------------|----------------------|--------------------------|--------|----------|-----------------|-----------------|
| HHOLLOW3_WND_1 | WIND | Abilene | Taylor | May-06 | 160 | FPL Energy | Horse Hollow Phase 4 | Mitsubishi 1000 (160) | ERCOT | AEP-West | AEP/TNC | MAF |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | | | | | | | | | | | |
| HHOLLOW3_WND_1 | HHOLLOW3_WND_1 | | | | 299 | | | | | | | |

11.6.1 Horse Hollow 3 – H_HOLLOW3_WIND1




Figure 11-25: H_HOLLOW3_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-26: H_HOLLOW3_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-26: H_HOLLOW3_WIND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -925.8684 |
| Left Slope (MWh/mph-day) | 258.9679 |
| RMSE (MWh/day) | 521.5584 |
| R2 | 0.7966 |
| CV-RMSE | 29.3% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -1170.6726 |
| Left Slope (MWh/mph-day) | 293.8913 |
| RMSE (MWh/day) | 459.0538 |
| R2 | 0.8335 |
| CV-RMSE | 37.0% |

Table 11-27: H_HOLLOW3_WIND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | 27 | 9.22 | 43,205 | 39,497 | 8.58% | 30% | 27% |
| Feb-07 | 27 | 11.91 | 58,936 | 58,292 | 1.09% | 41% | 40% |
| Mar-07 | 31 | 11.82 | 66,997 | 66,156 | 1.26% | 40% | 40% |
| Apr-07 | 30 | 12.85 | 73,352 | 72,078 | 1.74% | 45% | 45% |
| May-07 | 30 | 9.05 | 38,986 | 42,668 | -9.44% | 24% | 26% |
| Jun-07 | 30 | 9.53 | 39,200 | 46,265 | -18.02% | 24% | 29% |
| Jul-07 | 31 | 6.95 | 22,309 | 27,935 | -25.21% | 13% | 17% |
| Aug-07 | 31 | 9.10 | 50,904 | 47,067 | 7.54% | 31% | 28% |
| Sep-07 | 30 | 9.04 | 41,974 | 43,010 | -2.47% | 26% | 27% |
| Oct-07 | 30 | 10.77 | 59,294 | 55,952 | 5.64% | 37% | 35% |
| Nov-07 | 30 | 10.37 | 53,765 | 52,765 | 1.86% | 33% | 33% |
| Dec-07 | 29 | 10.16 | 50,565 | 49,482 | 2.14% | 32% | 32% |
| Total | 356 | 10.05 | 599,489 | 601,166 | -0.28% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 78,128 | 79,581 | -1.86% | 23% | 23% |




Figure 11-27: H_HOLLOW3_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-28: H_HOLLOW3_WIND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-28: H_HOLLOW3_WIND1 – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|---|--------------------------------------|
| 735,630 | 614,644 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
|--|---|
| 1,683 | 1,240 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.7 Horse Hollow 4

Table 11-29: Site Information for Horse Hollow 4

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|-------------------|---------------|--------|-----------------|---------------|------------|----------------------|--------------------------|--------|----------|-----------------|-----------------|
| HOLLOW4_WND | WIND | Abilene | Taylor | May-06 | 115 | FPL Energy | Horse Hollow Phase 4 | Mitsubishi 1000 (160) | ERCOT | AEP-West | AEP/TNC | ABI |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | |
| HOLLOW4_WND | HOLLOW4_WND | 112 | | | | | | | | | | |

11.7.1 Horse Hollow 4 – H_HOLLOW4_WIND1




Figure 11-29: H_HOLLOW4_WIND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-30: H_HOLLOW4_WIND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-30: H_HOLLOW4_WIND1 – Model Coefficients.

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -402.5325 |
| Left Slope (MWh/mph-day) | 128.2688 |
| RMSE (MWh/day) | 284.7249 |
| R2 | 0.7672 |
| CV-RMSE | 29.9% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -638.6235 |
| Left Slope (MWh/mph-day) | 154.9950 |
| RMSE (MWh/day) | 239.6907 |
| R2 | 0.8363 |
| CV-RMSE | 37.9% |

Table 11-31: H_HOLLOW4_WIND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | 26 | 9.39 | 24,349 | 20,855 | 14.35% | 34% | 29% |
| Feb-07 | 28 | 12.04 | 30,848 | 31,977 | -3.66% | 40% | 41% |
| Mar-07 | 31 | 11.82 | 34,539 | 34,505 | 0.10% | 40% | 40% |
| Apr-07 | 30 | 12.85 | 36,994 | 37,382 | -1.05% | 45% | 45% |
| May-07 | 31 | 9.32 | 21,331 | 24,564 | -15.16% | 25% | 29% |
| Jun-07 | 30 | 9.53 | 20,584 | 24,577 | -19.40% | 25% | 30% |
| Jul-07 | 31 | 6.95 | 11,383 | 14,836 | -30.33% | 13% | 17% |
| Aug-07 | 31 | 9.10 | 26,198 | 24,207 | 7.60% | 31% | 28% |
| Sep-07 | 30 | 9.04 | 20,895 | 22,378 | -7.10% | 25% | 27% |
| Oct-07 | 31 | 11.05 | 31,074 | 31,457 | -1.23% | 36% | 37% |
| Nov-07 | 30 | 10.37 | 32,811 | 27,817 | 15.22% | 40% | 34% |
| Dec-07 | 31 | 10.51 | 31,957 | 29,299 | 8.32% | 37% | 34% |
| Total | 360 | 10.16 | 322,962 | 323,855 | -0.28% | 33% | 33% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 39,867 | 40,760 | -2.24% | 23% | 23% |




Figure 11-31: H_HOLLOW4_WIND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-32: H_HOLLOW4_WIND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-32: H_HOLLOW4_WIND1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 383,301 | 327,448 | 866 | 633 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.8 _Desert Sky

Table 11-33: Site Information for Desert Sky

| GENSITECODE_EERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|--------------------|------------------|-------|--------|-----------------|---------------|---------|-----------------------------|--------------------------|--------|-----|-----------------|-----------------|
| INDNENR | WIND | Iraan | PECOS | Dec-01 | 160.5 | AEP | Desert Sky (Indian Mesa II) | Enron 1500 (107) | ERCOT | TXU | WTU | FST |

| SUBGENCODE_EERCOT | GENSITECODE_EERCOT | Capacity (MW) |
|--------------------|--------------------|---------------|
| INDNENR_IND_NENR | INDNENR | |
| INDNENR_IND_NENR_2 | INDNENR | |

11.8.1 Desert Sky – INDNENR_INDNENR




Figure 11-33: INDNENR_INDNENR – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-34: INDNENR_INDNENR – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model).

Table 11-34: INDNENR_INDNENR – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -186.6197 |
| Left Slope (MWh/mph-day) | 84.0785 |
| RMSE (MWh/day) | 328.4896 |
| R2 | 0.3979 |
| CV-RMSE | 49.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -556.1006 |
| Left Slope (MWh/mph-day) | 119.9466 |
| RMSE (MWh/day) | 277.9246 |
| R2 | 0.5940 |
| CV-RMSE | 43.6% |

Table 11-35: INDNENR_INDNENR – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 29 | 8.96 | 15,559 | 16,438 | -5.65% | 26% | 28% |
| Feb-07 | 27 | 11.21 | 21,095 | 20,413 | 3.23% | 38% | 37% |
| Mar-07 | 31 | 11.67 | 25,710 | 24,623 | 4.23% | 41% | 39% |
| Apr-07 | 30 | 12.99 | 24,686 | 27,159 | -10.02% | 40% | 44% |
| May-07 | 28 | 10.00 | 17,491 | 18,324 | -4.76% | 31% | 32% |
| Jun-07 | 30 | 10.19 | 20,332 | 20,097 | 1.16% | 33% | 33% |
| Jul-07 | 31 | 9.33 | 13,844 | 18,290 | -32.12% | 22% | 29% |
| Aug-07 | 31 | 10.51 | 24,683 | 21,851 | 11.47% | 39% | 35% |
| Sep-07 | 30 | 9.77 | 20,911 | 18,264 | 12.66% | 34% | 30% |
| Oct-07 | 31 | 10.27 | 25,502 | 20,990 | 17.69% | 40% | 33% |
| Nov-07 | 30 | 8.38 | 20,160 | 15,546 | 22.89% | 33% | 25% |
| Dec-07 | 31 | 9.67 | 20,619 | 19,420 | 5.82% | 33% | 31% |
| Total | 359 | 10.24 | 250,590 | 241,415 | 3.66% | 34% | 33% |
| Total in OSP (07/15-09/15) | 63 | 9.95 | 40,340 | 40,185 | 0.39% | 31% | 31% |




Figure 11-35: INDNENR_INDNENR – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-36: INDNENR_INDNENR – Predicted Capacity Factors Using Daily Models (2007)

Table 11-36: INDNENR_INDNENR – Predicted Power Production in 1999

| Annual | OSD | | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 274,334 | 254,779 | 638 | 640 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.8.2 Desert Sky – INDNENR_INDNENR_2




Figure 11-37: INDNENR_INDNENR_2 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-38: INDNENR_INDNENR_2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-37: INDNENR_INDNENR_2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|--------------------------|------------------|
| Ycp (MWh/day) | -222.6937 |
| Left Slope (MWh/mph-day) | 84.1524 |
| RMSE (MWh/day) | 323.2276 |
| R2 | 0.44 |
| CV-RMSE | 50.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -537.1206 |
| Left Slope (MWh/mph-day) | 112.8273 |
| RMSE (MWh/day) | 280.4806 |
| R2 | 0.5597 |
| CV-RMSE | 47.9% |

Table 11-38: INDNENR_INDNENR_2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 29 | 8.96 | 14,130 | 15,411 | -9.07% | 25% | 28% |
| Feb-07 | 27 | 11.21 | 18,499 | 19,461 | -5.20% | 36% | 38% |
| Mar-07 | 31 | 11.67 | 23,554 | 23,531 | 0.10% | 40% | 40% |
| Apr-07 | 30 | 12.99 | 22,328 | 26,106 | -16.92% | 39% | 45% |
| May-07 | 28 | 10.00 | 15,531 | 17,334 | -11.61% | 29% | 32% |
| Jun-07 | 30 | 10.19 | 18,422 | 19,038 | -3.34% | 32% | 33% |
| Jul-07 | 31 | 9.33 | 12,692 | 16,916 | -33.29% | 21% | 28% |
| Aug-07 | 31 | 10.51 | 23,108 | 20,119 | 12.93% | 39% | 34% |
| Sep-07 | 30 | 9.77 | 19,702 | 17,076 | 13.33% | 34% | 30% |
| Oct-07 | 31 | 10.27 | 23,300 | 19,895 | 14.61% | 39% | 33% |
| Nov-07 | 30 | 8.38 | 18,315 | 14,482 | 20.92% | 32% | 25% |
| Dec-07 | 31 | 9.67 | 18,114 | 18,324 | -1.16% | 30% | 31% |
| Total | 359 | 10.24 | 227,694 | 227,694 | 0.00% | 33% | 33% |
| Total in OSP (07/15-09/15) | 63 | 9.95 | 36,916 | 36,916 | 0.00% | 31% | 31% |




Figure 11-39: INDNENR_INDNENR_2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-40: INDNENR_INDNENR_2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-39: INDNENR_INDNENR_2 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|-----------------------------------|---|--|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 260,431 | 231,500 | 587 | 586 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.9 King Mountain Wind Ranch (KING_NE)

Table 11-40: Site Information for King Mountain Wind Ranch (KING_NE)

| GENSITECODE_E RCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-----------------------|---------------------|---------|--------|--------------------|------------------|-----------|-----------------------------|-----------------------------|--------|----------|-----------------|--------------------|
| KING_NE | WIND | McCamey | UPTON | Dec-01 | 79.3 | FPL/Cielo | King Mountain Wind Ranch | Bonus 1300 (61) | ERCOT | AEP-West | WTU | MAF |

| SUBGENCODE_E RCOT | GENSITECODE_ERCOT | Capacity (MW) |
|----------------------|-------------------|------------------|
| KING_NE_KINGNE | KING_NE | 79.3 |

11.9.1 King Mountain – KING_NE_KINGNE




Figure 11-41: KING_NE_KINGNE – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-42: KING_NE_KINGNE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-41: KING_NE_KINGNE – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -245.6178 |
| Left Slope (MWh/mph-day) | 73.5588 |
| RMSE (MWh/day) | 210.6222 |
| R2 | 0.6076 |
| CV-RMSE | 43.1% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -472.9793 |
| Left Slope (MWh/mph-day) | 98.0132 |
| RMSE (MWh/day) | 141.7817 |
| R2 | 0.7989 |
| CV-RMSE | 34.9% |

Table 11-42: KING_NE_KINGNE – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|---|
| Jan-07 | 28 | 9.58 | 11,110 | 12,853 | -15.68% | 21% | 24% |
| Feb-07 | 28 | 11.24 | 15,385 | 16,281 | -5.82% | 29% | 31% |
| Mar-07 | 31 | 10.28 | 17,267 | 15,830 | 8.33% | 29% | 27% |
| Apr-07 | 30 | 12.32 | 19,355 | 19,812 | -2.36% | 34% | 35% |
| May-07 | 31 | 9.65 | 13,741 | 14,402 | -4.81% | 23% | 24% |
| Jun-07 | 29 | 9.98 | 13,099 | 14,170 | -8.18% | 24% | 26% |
| Jul-07 | 31 | 8.01 | 8,503 | 10,128 | -19.11% | 14% | 17% |
| Aug-07 | 31 | 9.98 | 16,172 | 15,672 | 3.09% | 27% | 27% |
| Sep-07 | 30 | 8.89 | 12,915 | 11,978 | 7.26% | 23% | 21% |
| Oct-07 | 31 | 10.21 | 17,487 | 15,675 | 10.36% | 30% | 27% |
| Nov-07 | 30 | 8.90 | 10,664 | 12,315 | -15.48% | 19% | 22% |
| Dec-07 | 31 | 8.80 | 15,605 | 12,447 | 20.24% | 26% | 21% |
| Total | 361 | 9.81 | 171,303 | 171,562 | -0.15% | 25% | 25% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 25,570 | 25,785 | -0.84% | 21% | 22% |




Figure 11-43: KING_NE_KINGNE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-44: KING_NE_KINGNE – Predicted Capacity Factors Using Daily Models (2007)

Table 11-43: KING_NE_KINGNE – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|---|--------------------------------------|
| 203,501 | 173,201 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
|--|---|
| 456 | 406 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.10 King Mountain Wind Ranch (KING_NW)

Table 11-44: Site Information for King Mountain Wind Ranch (KING_NW)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|-----------|--------------------------|--------------------------|--------|----------|-----------------|-----------------|
| KING_NW | WIND | McComey | UPTON | Dec-01 | 79.3 | FPL/Cielo | King Mountain Wind Ranch | Bonus 1300 (61) | ERCOT | AEP-West | WTU | MAF |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| KING_NW_KING_NW | KING_NW | 79.3 |

11.10.1 King Mountain – KING_NW_KINGNW




Figure 11-45: KING_NW_KINGNW – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-46: KING_NW_KINGNW – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-45: KING_NW_KINGNW – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -126.0973 |
| Left Slope (MWh/mph-day) | 73.5897 |
| RMSE (MWh/day) | 292.8510 |
| R2 | 0.4449 |
| CV-RMSE | 48.1% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -462.0813 |
| Left Slope (MWh/mph-day) | 112.6409 |
| RMSE (MWh/day) | 192.1530 |
| R2 | 0.7407 |
| CV-RMSE | 35.1% |

Table 11-46: KING_NW_KINGNW – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 28 | 9.58 | 13,816 | 16,208 | -17.31% | 26% | 30% |
| Feb-07 | 28 | 11.24 | 15,817 | 19,638 | -24.15% | 30% | 37% |
| Mar-07 | 31 | 10.28 | 20,757 | 19,545 | 5.84% | 35% | 33% |
| Apr-07 | 30 | 12.32 | 23,266 | 23,409 | -0.61% | 41% | 41% |
| May-07 | 31 | 9.65 | 18,650 | 18,116 | 2.86% | 32% | 31% |
| Jun-07 | 29 | 9.98 | 17,252 | 17,645 | -2.28% | 31% | 32% |
| Jul-07 | 31 | 8.01 | 11,391 | 13,983 | -22.76% | 19% | 24% |
| Aug-07 | 31 | 9.98 | 21,409 | 20,537 | 4.07% | 36% | 35% |
| Sep-07 | 30 | 8.89 | 18,406 | 15,632 | 15.07% | 32% | 27% |
| Oct-07 | 31 | 10.21 | 22,584 | 19,390 | 14.14% | 38% | 33% |
| Nov-07 | 30 | 8.90 | 16,417 | 15,865 | 3.36% | 29% | 28% |
| Dec-07 | 31 | 8.80 | 16,197 | 16,161 | 0.22% | 27% | 27% |
| Total | 361 | 9.81 | 215,962 | 216,129 | -0.08% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 34,520 | 34,686 | -0.48% | 29% | 29% |




Figure 11-47: KING_NW_KINGNW – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-48: KING_NW_KINGNW – Predicted Capacity Factors Using Daily Models (2007)

Table 11-47: KING_NW_KINGNW – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 248,975 | 218,355 | 605 | 548 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.11 King Mountain Wind Ranch (KING_SE)

Table 11-48: Site Information for King Mountain Wind Ranch (KING_SE)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Intercon-nection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|-----------|--------------------------|--------------------------|--------|----------|------------------|-----------------|
| KING_SE | WIND | McComey | UPTON | Dec-01 | 40.3 | FPL/Cielo | King Mountain Wind Ranch | Bonus 1300 (61) | ERCOT | AEP-West | WTU | MAF |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| KING_SE_KINGSE | KING_SE | 40.3 |

11.11.1 King Mountain – KING_SE_KINGSE




Figure 11-49: KING_SE_KINGSE – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-50: KING_SE_KINGSE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-49: KING_SE_KINGSE – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -129.2091 |
| Left Slope (MWh/mph-day) | 37.2001 |
| RMSE (MWh/day) | 100.2904 |
| R2 | 0.6358 |
| CV-RMSE | 41.5% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -250.5625 |
| Left Slope (MWh/mph-day) | 51.1504 |
| RMSE (MWh/day) | 69.6177 |
| R2 | 0.8178 |
| CV-RMSE | 33.5% |

Table 11-50: King Mountain – KING_SE – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 29 | 9.48 | 5,514 | 6,477 | -17.47% | 20% | 23% |
| Feb-07 | 28 | 11.24 | 7,999 | 8,094 | -1.19% | 30% | 30% |
| Mar-07 | 31 | 10.28 | 8,599 | 7,850 | 8.70% | 29% | 26% |
| Apr-07 | 30 | 12.32 | 9,451 | 9,869 | -4.43% | 33% | 34% |
| May-07 | 31 | 9.65 | 6,383 | 7,128 | -11.68% | 21% | 24% |
| Jun-07 | 29 | 9.98 | 6,386 | 7,021 | -9.95% | 23% | 25% |
| Jul-07 | 31 | 8.01 | 4,394 | 5,074 | -15.47% | 15% | 17% |
| Aug-07 | 31 | 9.98 | 8,271 | 8,063 | 2.52% | 28% | 27% |
| Sep-07 | 30 | 8.89 | 6,389 | 6,008 | 5.97% | 22% | 21% |
| Oct-07 | 31 | 10.21 | 8,232 | 7,772 | 5.59% | 27% | 26% |
| Nov-07 | 30 | 8.90 | 5,715 | 6,083 | -6.44% | 20% | 21% |
| Dec-07 | 31 | 8.80 | 8,105 | 6,140 | 24.24% | 27% | 20% |
| Total | 362 | 9.80 | 85,438 | 85,581 | -0.17% | 24% | 24% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 13,109 | 13,226 | -0.89% | 22% | 22% |




Figure 11-51: KING_SE_KINGSE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-52: KING_SE_KINGSE – Predicted Capacity Factors Using Daily Models (2007)

Table 11-51: KING_SE_KINGSE - Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|---|--------------------------------------|
| 101,648 | 86,146 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured Mwh/day for Modeling |
|--|---|
| 234 | 208 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.12 King Mountain Wind Ranch (KING_SW)

Table 11-52: Site Information for King Mountain Wind Ranch (KING_SW)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|-----------|--------------------------|--------------------------|--------|----------|-----------------|-----------------|
| KING_SW | WIND | McComey | UPTON | Dec-01 | 79.3 | FPL/Cielo | King Mountain Wind Ranch | Bonus 1300 (61) | ERCOT | AEP-West | WTU | MAF |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| KING_SW_KIN_GSW | KING_SW | 79.3 |

11.12.1 King Mountain – KING_SW_KINGSW




Figure 11-53: KING_SW_KINGSW – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-54: KING_SW_KINGSW – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-53: KING_SW_KINGSW – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -159.9608 |
| Left Slope (MWh/mph-day) | 70.2392 |
| RMSE (MWh/day) | 221.1290 |
| R2 | 0.5702 |
| CV-RMSE | 40.1% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -417.3697 |
| Left Slope (MWh/mph-day) | 101.8961 |
| RMSE (MWh/day) | 158.9090 |
| R2 | 0.7737 |
| CV-RMSE | 32.0% |

Table 11-54: KING_SW_KINGSW – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 28 | 9.58 | 13,140 | 14,361 | -9.29% | 25% | 27% |
| Feb-07 | 28 | 11.24 | 14,820 | 17,635 | -18.99% | 28% | 33% |
| Mar-07 | 31 | 10.28 | 18,945 | 17,427 | 8.01% | 32% | 30% |
| Apr-07 | 30 | 12.32 | 21,058 | 21,155 | -0.46% | 37% | 37% |
| May-07 | 31 | 9.65 | 16,790 | 16,063 | 4.33% | 28% | 27% |
| Jun-07 | 29 | 9.98 | 15,373 | 15,693 | -2.08% | 28% | 28% |
| Jul-07 | 31 | 8.01 | 10,709 | 12,429 | -16.07% | 18% | 21% |
| Aug-07 | 31 | 9.98 | 19,146 | 18,598 | 2.86% | 32% | 32% |
| Sep-07 | 30 | 8.89 | 15,914 | 14,003 | 12.01% | 28% | 25% |
| Oct-07 | 31 | 10.21 | 19,027 | 17,279 | 9.19% | 32% | 29% |
| Nov-07 | 30 | 8.90 | 13,346 | 13,955 | -4.56% | 23% | 24% |
| Dec-07 | 1 | 11.63 | 838 | 657 | 21.61% | 44% | 34% |
| Total | 331 | 9.91 | 179,106 | 179,255 | -0.08% | 28% | 28% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 31,267 | 31,417 | -0.48% | 26% | 26% |




Figure 11-55: KING_SW_KINGSW – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-56: KING_SW_KINGSW - Predicted Capacity Factors Using Daily Models (2007)

Table 11-55: KING_SW_KINGSW – Predicted Power Production in 1999

| Annual | OSD |
|---|--|
| 1999 Estimated MWh/yr (2007 Daily Model) | 1999 OSD Estimated MWh/day (2007 Daily Model) |
| 223,819 | 548 |
| 2007 Measured MWh/yr for Modeling | 2007 OSD Measured MWh/day for Modeling |
| 197,503 | 496 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.13 Red Canyon

Table 11-56: Site Information for Red Canyon 1

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|------|--------|-----------------|---------------|------------|-------------|--------------------------|--------|-----|-----------------|-----------------|
| Red Canyon | WIND | | BORDEN | Apr-06 | 84 | FPL Energy | Red Canyon1 | | ERCOT | | BEPC | ABI |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| Red Canyon 1 | Red Canyon | 84 |

11.13.1 Red Canyon 1 – RDCANYON_RDCNY1




Figure 11-57: RDCANYON_RDCNY1 – Hourly Wind Power vs. NOAA Wind Speed (2006)




Figure 11-58: RDCANYON_RDCNY1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-57: RDCANYON_RDCNY1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -277.3935 |
| Left Slope (MWh/mph-day) | 104.2544 |
| RMSE (MWh/day) | 275.0539 |
| R2 | 0.7014 |
| CV-RMSE | 33.5% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -266.1538 |
| Left Slope (MWh/mph-day) | 113.4990 |
| RMSE (MWh/day) | 242.9929 |
| R2 | 0.7272 |
| CV-RMSE | 36.5% |

Table 11-58: RDCANYON_RDCNY1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|---|
| Jan-07 | 27 | 9.17 | 18,794 | 18,332 | 2.46% | 35% | 34% |
| Feb-07 | 28 | 12.04 | 26,698 | 27,384 | -2.57% | 47% | 49% |
| Mar-07 | 31 | 11.82 | 27,759 | 29,588 | -6.59% | 44% | 47% |
| Apr-07 | 30 | 12.85 | 29,673 | 31,877 | -7.43% | 49% | 53% |
| May-07 | 31 | 9.32 | 20,037 | 21,509 | -7.34% | 32% | 34% |
| Jun-07 | 30 | 9.53 | 19,235 | 21,469 | -11.61% | 32% | 35% |
| Jul-07 | 31 | 6.95 | 13,709 | 15,252 | -11.26% | 22% | 24% |
| Aug-07 | 31 | 9.10 | 26,261 | 23,761 | 9.52% | 42% | 38% |
| Sep-07 | 30 | 9.04 | 22,614 | 21,169 | 6.39% | 37% | 35% |
| Oct-07 | 31 | 11.05 | 30,046 | 27,111 | 9.77% | 48% | 43% |
| Nov-07 | 30 | 10.37 | 24,539 | 24,102 | 1.78% | 41% | 40% |
| Dec-07 | 31 | 10.51 | 27,488 | 25,357 | 7.75% | 44% | 41% |
| Total | 361 | 10.14 | 286,853 | 286,911 | -0.02% | 39% | 39% |
| Total in OSP (07/15-09/15) | 63 | N/A | 41,888 | 41,946 | N/A | N/A | N/A |




Figure 11-59: RDCANYON_RDCNY1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-60: RDCANYON_RDCNY1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-59: RDCANYON_RDCNY1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 334,823 | 290,032 | 836 | 665 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.14 Sweetwater Wind 2

Table 11-60: Site Information for Sweetwater Wind 2

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|------------|--------|-----------------|---------------|------------------|-------------------|--------------------------|--------|-----|-----------------|-----------------|
| SWEETWN2 | WIND | Sweetwater | NOLAN | Feb-05 | 91.5 | DKRW Development | Sweetwater Wind 2 | GE Wind 1500 (61) | ERCOT | TXU | TXU | ABI |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| SWEETWN2_WND2 | SWEETWN2 | 91.5 |

11.14.1 Sweetwater Wind 2 – SWEETWN2_WND2




Figure 11-61: SWEETWN2_WND2 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-62: SWEETWN2_WND2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-61: SWEETWN2_WND2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -420.6577 |
| Left Slope (MWh/mph-day) | 122.5278 |
| RMSE (MWh/day) | 276.1915 |
| R2 | 0.7647 |
| CV-RMSE | 31.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -534.4376 |
| Left Slope (MWh/mph-day) | 143.6373 |
| RMSE (MWh/day) | 232.4217 |
| R2 | 0.8235 |
| CV-RMSE | 36.1% |

Table 11-62: SWEETWN2_WND2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 23 | 8.97 | 15,512 | 15,603 | -0.59% | 31% | 31% |
| Feb-07 | 27 | 12.16 | 26,557 | 28,877 | -8.74% | 45% | 49% |
| Mar-07 | 31 | 11.82 | 28,679 | 31,841 | -11.02% | 42% | 47% |
| Apr-07 | 30 | 12.85 | 33,142 | 34,625 | -4.47% | 50% | 53% |
| May-07 | 31 | 9.32 | 21,794 | 22,364 | -2.62% | 32% | 33% |
| Jun-07 | 30 | 9.53 | 20,685 | 22,395 | -8.26% | 31% | 34% |
| Jul-07 | 31 | 6.95 | 13,107 | 14,286 | -8.99% | 19% | 21% |
| Aug-07 | 31 | 9.10 | 25,848 | 24,097 | 6.77% | 38% | 35% |
| Sep-07 | 30 | 9.04 | 20,720 | 21,359 | -3.09% | 31% | 32% |
| Oct-07 | 31 | 11.05 | 31,076 | 28,936 | 6.89% | 46% | 43% |
| Nov-07 | 30 | 10.37 | 29,188 | 25,488 | 12.68% | 44% | 39% |
| Dec-07 | 31 | 10.51 | 29,909 | 26,868 | 10.17% | 44% | 39% |
| Total | 356 | 10.14 | 296,216 | 296,738 | -0.18% | 38% | 38% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 40,561 | 41,055 | -1.22% | 29% | 30% |




Figure 11-63: SWEETWN2_WND2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-64: SWEETWN2_WND2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-63: SWEETWN2_WND2 – Predicted Power Production in 1999

| Annual | OSD |
|---|--|
| 1999 Estimated MWh/yr (2007 Daily Model) | 1999 OSD Estimated MWh/day (2007 Daily Model) |
| 357,326 | 860 |
| 2007 Measured MWh/yr for Modeling | 2007 OSD Measured MWh/day for Modeling |
| 303,705 | 644 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.15 Sweetwater Wind 3

Table 11-64: Site Information for Sweetwater Wind 3

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|-------------------|---------------|--------|-----------------|---------------|------------------|-------------------|--------------------------|--------|-----|-----------------|-----------------|
| SWEETWN3 | WIND | Sweetwater | NOLAN | Feb-05 | 135 | DKRW Development | Sweetwater Wind 3 | GE Wind 1500 (61) | ERCOT | TXU | TXU | ABI |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | |
| SWEETWN3_WND3 | SWEETWN3 | 135 | | | | | | | | | | |

11.15.1 Sweetwater Wind 3 – SWEETWN3_WND3




Figure 11-65: SWEETWN3_WND3 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-66: SWEETWN3_WND3 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-65: SWEETWN3_WND3 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -537.6169 |
| Left Slope (MWh/mph-day) | 158.6613 |
| RMSE (MWh/day) | 316.1784 |
| R2 | 0.8062 |
| CV-RMSE | 27.8% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -547.0923 |
| Left Slope (MWh/mph-day) | 159.6473 |
| RMSE (MWh/day) | 257.2861 |
| R2 | 0.8247 |
| CV-RMSE | 33.7% |

Table 11-66: SWEETWN3_WND3 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 23 | 8.97 | 21,625 | 20,367 | 5.81% | 29% | 27% |
| Feb-07 | 27 | 12.16 | 35,491 | 37,585 | -5.90% | 41% | 43% |
| Mar-07 | 31 | 11.82 | 39,630 | 41,450 | -4.59% | 39% | 41% |
| Apr-07 | 30 | 12.85 | 43,693 | 45,049 | -3.10% | 45% | 46% |
| May-07 | 31 | 9.32 | 28,565 | 29,169 | -2.12% | 28% | 29% |
| Jun-07 | 30 | 9.53 | 26,009 | 29,209 | -12.30% | 27% | 30% |
| Jul-07 | 31 | 6.95 | 15,527 | 17,752 | -14.33% | 15% | 18% |
| Aug-07 | 31 | 9.10 | 30,236 | 28,144 | 6.92% | 30% | 28% |
| Sep-07 | 30 | 9.04 | 25,849 | 26,906 | -4.09% | 27% | 28% |
| Oct-07 | 31 | 11.05 | 40,896 | 37,682 | 7.86% | 41% | 38% |
| Nov-07 | 30 | 10.37 | 34,766 | 33,217 | 4.46% | 36% | 34% |
| Dec-07 | 31 | 10.51 | 38,877 | 35,011 | 9.94% | 39% | 35% |
| Total | 356 | 10.14 | 381,164 | 381,540 | -0.10% | 33% | 33% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 48,038 | 48,397 | -0.75% | 24% | 24% |




Figure 11-67: SWEETWN3_WND3 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-68: SWEETWN3_WND3 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-67: SWEETWN3_WND3 – Predicted Power Production in 1999

| Annual | OSD | | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured Mwh/day for Modeling |
| 457,851 | 390,800 | 1,003 | 763 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.16 Sweetwater Wind 1

Table 11-68: Site Information for Sweetwater Wind 1

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|--------------------|---------------|--------|-----------------|---------------|-----------------|-------------------|--------------------------|--------|------|-----------------|-----------------|
| SWEETWND | WIND | Sweetwater | NOLAN | Dec-03 | 37.5 | DKR Development | Sweetwater Wind 1 | GE Wind 1500 (25) | ERCOT | LCRA | LCRA | ABI |
| SUBGENCODE_ERCOT | GENSITECODE_ERCO_T | Capacity (MW) | | | | | | | | | | |
| SWEETWND_WND1 | SWEETWND | 37.5 | | | | | | | | | | |

11.16.1 Sweetwater Wind 1 – SWEETWND_WND1




Figure 11-69: SWEETWND_WND1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-70: SWEETWND_WND1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-69: SWEETWND_WND1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -190.7497 |
| Left Slope (MWh/mph-day) | 49.5612 |
| RMSE (MWh/day) | 114.1072 |
| R2 | 0.7544 |
| CV-RMSE | 34.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -204.4797 |
| Left Slope (MWh/mph-day) | 51.8314 |
| RMSE (MWh/day) | 101.8964 |
| R2 | 0.7597 |
| CV-RMSE | 46.2% |

Table 11-70: SWEETWND_WND1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) | Measured Power Generation (MWh) | Predicted Power Generation Using Daily Model (MWh) | Diff. | CV-RMSE | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--------------------------------|---------------------------------|--|---------|---------|--------------------------|--|
| Jan-07 | 23 | 8.97 | 6,183 | 5,853 | 5.35% | 45.51% | 30% | 28% |
| Feb-07 | 28 | 12.04 | 11,182 | 11,369 | -1.68% | 34.90% | 44% | 45% |
| Mar-07 | 30 | 11.58 | 10,349 | 11,492 | -11.04% | 33.08% | 38% | 43% |
| Apr-07 | 28 | 12.77 | 9,818 | 12,383 | -26.13% | 46.49% | 39% | 49% |
| May-07 | 31 | 9.32 | 8,400 | 8,464 | -0.77% | 31.02% | 30% | 30% |
| Jun-07 | 30 | 9.53 | 7,901 | 8,461 | -7.09% | 24.04% | 29% | 31% |
| Jul-07 | 31 | 6.95 | 4,556 | 4,936 | -8.34% | 47.18% | 16% | 18% |
| Aug-07 | 31 | 9.10 | 9,289 | 8,358 | 10.02% | 35.28% | 33% | 30% |
| Sep-07 | 30 | 9.04 | 7,477 | 7,815 | -4.52% | 31.73% | 28% | 29% |
| Oct-07 | 31 | 11.05 | 12,484 | 11,086 | 11.20% | 27.40% | 45% | 40% |
| Nov-07 | 30 | 10.37 | 10,225 | 9,692 | 5.21% | 37.09% | 38% | 36% |
| Dec-07 | 30 | 10.36 | 11,356 | 9,679 | 14.77% | 36.56% | 42% | 36% |
| Total | 353 | 10.09 | 109,220 | 109,589 | -0.34% | 35.76% | 34% | 34% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 13,904 | 14,148 | -1.76% | 43.55% | 25% | 25% |




Figure 11-71: SWEETWND_WND1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-72: SWEETWND_WND1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-71: SWEETWND_WND1 – Predicted Power Production in 1999

| Annual | OSD | | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 135,245 | 112,933 | 299 | 221 |

Note: The 2006 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.17 Trent Mesa

Table 11-72: Site Information for Trent Mesa

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|------------|--------|-----------------|---------------|---------|------------|--------------------------|--------|-----|-----------------|-----------------|
| TRENT | WIND | Trent Mesa | NOLAN | Nov-01 | 150 | AEP | Trent Mesa | Enron 1500 (100) | ERCOT | TXU | TXU | ABI |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| TRENT_TRENT | TRENT | 150 |

11.17.1 Trent Mesa – TRENT_TRENT




Figure 11-73: TRENT_TRENT – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-74: TRENT_TRENT – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-73: TRENT_TRENT – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -772.1434 |
| Left Slope (MWh/mph-day) | 193.3838 |
| RMSE (MWh/day) | 401.1883 |
| R2 | 0.7911 |
| CV-RMSE | 31.6% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -836.0781 |
| Left Slope (MWh/mph-day) | 211.3899 |
| RMSE (MWh/day) | 366.6579 |
| R2 | 0.8024 |
| CV-RMSE | 40.8% |

Table 11-74: TRENT_TRENT – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|---|
| Jan-07 | 27 | 9.22 | 29,753 | 27,394 | 7.93% | 31% | 28% |
| Feb-07 | 28 | 12.04 | 42,258 | 43,583 | -3.13% | 42% | 43% |
| Mar-07 | 31 | 11.82 | 41,774 | 46,898 | -12.27% | 37% | 42% |
| Apr-07 | 30 | 12.85 | 45,646 | 51,401 | -12.61% | 42% | 48% |
| May-07 | 31 | 9.32 | 30,986 | 32,245 | -4.06% | 28% | 29% |
| Jun-07 | 30 | 9.53 | 28,946 | 32,207 | -11.27% | 27% | 30% |
| Jul-07 | 31 | 6.95 | 18,926 | 19,377 | -2.38% | 17% | 17% |
| Aug-07 | 31 | 9.10 | 36,735 | 34,027 | 7.37% | 33% | 30% |
| Sep-07 | 30 | 9.04 | 29,809 | 30,548 | -2.48% | 28% | 28% |
| Oct-07 | 31 | 11.05 | 46,186 | 42,423 | 8.15% | 41% | 38% |
| Nov-07 | 30 | 10.37 | 40,782 | 36,980 | 9.32% | 38% | 34% |
| Dec-07 | 31 | 10.51 | 42,655 | 39,050 | 8.45% | 38% | 35% |
| Total | 361 | 10.14 | 434,457 | 436,133 | -0.39% | 33% | 34% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 56,572 | 57,580 | -1.78% | 25% | 25% |




Figure 11-75: TRENT_TRENT – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-76: TRENT_TRENT – Predicted Capacity Factors Using Daily Models (2007)

Table 11-75: TRENT_TRENT – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 522,564 | 439,271 | 1,216 | 898 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.18 Delaware Mountain Wind Farm

Table 11-76: Site Information for Delaware Mountain Wind Farm

| GENSITECODE _ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Intercon- nection | Weather Station |
|-----------------------|---------------------|------|-----------|--------------------|---------------|---------------------------------|--------------------------------|-----------------------------|--------|-----|----------------------|--------------------|
| DELAWARE | WIND | | CULBERSON | Jun-99 | 30 | American National Wind Power | Delaware Mountain Wind Farm | Zond (40) | ERCOT | TXU | TXU | GDP |

| SUBGENCODE _ERCOT | GENSITECODE _ERCOT | Capacity (MW) |
|-----------------------|-----------------------|------------------|
| DELAWARE_WI ND_NWP | DELAWARE | 30 |

11.18.1 Delaware Mountain – DELAWARE_WIND_NWP




Figure 11-77: DELAWARE_WIND_NWP – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-78: DELAWARE_WIND_NWP – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-77: DELAWARE_WIND_NWP – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -104.1174 |
| Left Slope (MWh/mph-day) | 15.0940 |
| RMSE (MWh/day) | 62.9801 |
| R2 | 0.7211 |
| CV-RMSE | 35.0% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -92.7621 |
| Left Slope (MWh/mph-day) | 13.1860 |
| RMSE (MWh/day) | 33.2960 |
| R2 | 0.7415 |
| CV-RMSE | 32.5% |

Table 11-78: DELAWARE_WIND_NWP – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|-------------------------------------|--------------------------------------|---|------------|--------------------------|--|
| Jan-07 | 23 | 22.38 | 5,694 | 5,374 | 5.63% | 34% | 32% |
| Feb-07 | 23 | 21.93 | 5,725 | 5,220 | 8.83% | 35% | 32% |
| Mar-07 | 31 | 16.77 | 4,766 | 4,617 | 3.12% | 21% | 21% |
| Apr-07 | 27 | 21.96 | 6,092 | 6,138 | -0.76% | 31% | 32% |
| May-07 | 30 | 18.57 | 5,019 | 5,285 | -5.29% | 23% | 24% |
| Jun-07 | 25 | 17.05 | 3,265 | 3,833 | -17.40% | 18% | 21% |
| Jul-07 | 31 | 15.06 | 3,268 | 3,517 | -7.62% | 15% | 16% |
| Aug-07 | 29 | 14.22 | 2,777 | 2,746 | 1.13% | 13% | 13% |
| Sep-07 | 30 | 13.81 | 2,810 | 2,855 | -1.58% | 13% | 13% |
| Oct-07 | 31 | 17.59 | 4,703 | 5,001 | -6.35% | 21% | 22% |
| Nov-07 | 23 | 17.98 | 3,265 | 3,848 | -17.86% | 20% | 23% |
| Dec-07 | 30 | 21.84 | 7,813 | 6,764 | 13.42% | 36% | 31% |
| Total | 333 | 18.08 | 55,197 | 55,197 | 0.00% | 23% | 23% |
| Total in OSP (07/15-09/15) | 61 | 14.81 | 6,253 | 6,253 | 0.00% | 14% | 14% |




Figure 11-79: DELAWARE_WIND_NWP – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-80: DELAWARE_WIND_NWP – Predicted Capacity Factors Using Daily Models (2007)

Table 11-79: DELAWARE_WIND_NWP – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 62,053 | 60,501 | 90 | 103 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.19 Indian Mesa

Table 11-80: Site Information for Indian Mesa

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|-------|--------|-----------------|---------------|---|---------------|--------------------------|--------|----------|-----------------|-----------------|
| INDNNWP | WIND | Iraan | PECOS | Jun-01 | 82.5 | Orion Energy/American National Wind Power | Indian Mesa I | Vestas V-47 (125) | ERCOT | AEP-West | WTU | FST |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|----------------------|-------------------|---------------|
| INDNNWP_IND_NNWP_J01 | INDNNWP | 50.3 |
| INDNNWP_IND_NNWP_J02 | INDNNWP | 32.2 |

11.19.1 Indian Mesa – INDNNWP_INDNNWP




Figure 11-81: INDNNWP_INDNNWP- Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-82: INDNNWP_INDNNWP – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-81: INDNNWP_INDNNWP – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -233.3429 |
| Left Slope (MWh/mph-day) | 81.3796 |
| RMSE (MWh/day) | 314.1551 |
| R2 | 0.4244 |
| CV-RMSE | 51.0% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -460.1109 |
| Left Slope (MWh/mph-day) | 104.0352 |
| RMSE (MWh/day) | 249.0883 |
| R2 | 0.5781 |
| CV-RMSE | 43.3% |

Table 11-82: INDNNWP_INDNNWP – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|---|
| Jan-07 | 29 | 9.07 | 12,836 | 14,649 | -14.12% | 22% | 26% |
| Feb-07 | 27 | 11.21 | 17,688 | 18,334 | -3.65% | 33% | 34% |
| Mar-07 | 30 | 11.82 | 22,472 | 21,849 | 2.77% | 38% | 37% |
| Apr-07 | 30 | 12.99 | 21,754 | 24,706 | -13.57% | 37% | 42% |
| May-07 | 28 | 10.00 | 15,305 | 16,259 | -6.24% | 28% | 29% |
| Jun-07 | 30 | 10.19 | 17,718 | 17,871 | -0.86% | 30% | 30% |
| Jul-07 | 30 | 9.51 | 12,484 | 16,171 | -29.53% | 21% | 27% |
| Aug-07 | 31 | 10.51 | 22,081 | 19,641 | 11.05% | 36% | 32% |
| Sep-07 | 29 | 9.95 | 18,771 | 16,310 | 13.11% | 33% | 28% |
| Oct-07 | 31 | 10.27 | 21,206 | 18,682 | 11.90% | 35% | 30% |
| Nov-07 | 27 | 8.88 | 15,467 | 13,207 | 14.61% | 29% | 25% |
| Dec-07 | 31 | 9.67 | 17,061 | 17,162 | -0.59% | 28% | 28% |
| Total | 353 | 10.35 | 214,843 | 214,843 | 0.00% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 9.95 | 36,254 | 36,254 | 0.00% | 29% | 29% |




Figure 11-83: INDNNWP_INDNNWP – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-84: INDNNWP_INDNNWP – Predicted Capacity Factors Using Daily Models (2007)

Table 11-83: INDNNWP_INDNNWP – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 246,998 | 222,146 | 576 | 575 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.20 Texas Wind Power Project

Table 11-84: Site Information for Texas Wind Power Project

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|------|-----------|-----------------|---------------|---------|--------------------------|--------------------------|--------|--------------------------|-----------------|-----------------|
| KUNITZ | WIND | | CULBERSON | Jan-95 | 35 | LG&E | Texas Wind Power Project | Kenetech (112) | ERCOT | Colorado River Authority | | GDP |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|---------------------|-------------------|---------------|
| KUNITZ_WIND_LGE_J01 | KUNITZ | 24.9 |
| KUNITZ_WIND_LGE_J02 | KUNITZ | 10.1 |

11.20.1 Texas Wind Power Project – KUNITZ_WIND_LGE




Figure 11-85: KUNITZ_WIND_LGE – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-86: KUNITZ_WIND_LGE – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-85: KUNITZ_WIND_LGE – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -129.0796 |
| Left Slope (MWh/mph-day) | 13.1786 |
| RMSE (MWh/day) | 50.0871 |
| R2 | 0.7270 |
| CV-RMSE | 45.3% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -68.7809 |
| Left Slope (MWh/mph-day) | 7.6301 |
| RMSE (MWh/day) | 21.0327 |
| R2 | 0.6921 |
| CV-RMSE | 48.9% |

Table 11-86: KUNITZ_WIND_LGE – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 17 | 22.00 | 3,594 | 2,735 | 23.91% | 25% | 19% |
| Feb-07 | 21 | 21.20 | 3,157 | 3,162 | -0.15% | 18% | 18% |
| Mar-07 | 31 | 16.77 | 3,288 | 2,926 | 11.03% | 13% | 11% |
| Apr-07 | 24 | 20.63 | 3,211 | 3,427 | -6.74% | 16% | 17% |
| May-07 | 29 | 18.34 | 2,350 | 3,267 | -39.04% | 10% | 13% |
| Jun-07 | 22 | 15.17 | 770 | 1,568 | -103.54% | 4% | 8% |
| Jul-07 | 31 | 15.06 | 1,534 | 1,753 | -14.22% | 6% | 7% |
| Aug-07 | 29 | 14.22 | 985 | 1,186 | -20.34% | 4% | 5% |
| Sep-07 | 29 | 13.45 | 1,179 | 1,100 | 6.75% | 5% | 5% |
| Oct-07 | 31 | 17.59 | 2,915 | 3,206 | -9.97% | 11% | 12% |
| Nov-07 | 22 | 18.22 | 2,596 | 2,450 | 5.62% | 14% | 13% |
| Dec-07 | 27 | 20.89 | 4,962 | 3,964 | 20.11% | 22% | 17% |
| Total | 313 | 17.50 | 30,543 | 30,743 | -0.65% | 12% | 12% |
| Total in OSP (07/15-09/15) | 60 | 14.65 | 2,581 | 2,641 | -2.32% | 5% | 5% |




Figure 11-87: KUNITZ_WIND_LGE – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-88: KUNITZ_WIND_LGE – Predicted Capacity Factors Using Daily Models (2007)

Table 11-87: KUNITZ_WIND_LGE – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 40,305 | 35,617 | 38 | 43 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.21 Big Spring Wind Power

Table 11-88: Site Information for Big Spring Wind Power

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|------------|--------|-----------------|---------------|---------------|-----------------------|-----------------------------|--------|-----|-----------------|-----------------|
| SGMTN | WIND | Big Spring | HOWARD | Feb-99 | 41 | York Research | Big Spring Wind Power | Vestas V-47 (42) Vestas (4) | ERCOT | TXU | TXU | MAF |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| SGMTN_SIGNALMT | SGMTN | 41 |

11.21.1 Big Spring Wind Power – SGMTN_SIGNALMT




Figure 11-89: SGMTN_SIGNALMT – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-90: SGMTN_SIGNALMT – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-89: SGMTN_SIGNALMT – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -71.8245 |
| Left Slope (MWh/mph-day) | 32.6551 |
| RMSE (MWh/day) | 121.9463 |
| R2 | 0.4534 |
| CV-RMSE | 48.5% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -208.3962 |
| Left Slope (MWh/mph-day) | 43.9936 |
| RMSE (MWh/day) | 86.3661 |
| R2 | 0.6832 |
| CV-RMSE | 46.4% |

Table 11-90: SGMTN_SIGNALMT – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | 25 | 9.60 | 5,973 | 6,041 | -1.15% | 24% | 25% |
| Feb-07 | 27 | 10.76 | 8,153 | 7,546 | 7.45% | 31% | 28% |
| Mar-07 | 30 | 9.86 | 7,798 | 7,504 | 3.77% | 26% | 25% |
| Apr-07 | 30 | 12.32 | 8,454 | 9,912 | -17.24% | 29% | 34% |
| May-07 | 31 | 9.65 | 5,541 | 7,547 | -36.19% | 18% | 25% |
| Jun-07 | 29 | 9.98 | 5,837 | 7,370 | -26.27% | 20% | 26% |
| Jul-07 | 31 | 8.01 | 3,446 | 5,110 | -48.26% | 11% | 17% |
| Aug-07 | 31 | 9.98 | 8,095 | 7,155 | 11.61% | 27% | 23% |
| Sep-07 | 30 | 8.89 | 6,359 | 5,954 | 6.37% | 22% | 20% |
| Oct-07 | 31 | 10.21 | 9,418 | 8,112 | 13.86% | 31% | 27% |
| Nov-07 | 30 | 8.90 | 7,776 | 6,564 | 15.58% | 26% | 22% |
| Dec-07 | 31 | 8.80 | 8,550 | 6,679 | 21.88% | 28% | 22% |
| Total | 356 | 9.73 | 85,401 | 85,494 | -0.11% | 24% | 24% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 11,723 | 11,816 | -0.79% | 19% | 19% |




Figure 11-91: SGMTN_SIGNALMT – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-92: SGMTN_SIGNALMT – Predicted Capacity Factors Using Daily Models (2007)

Table 11-91: SGMTN_SIGNALMT – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling |
|---|--------------------------------------|
| 101,909 | 87,560 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
|--|---|
| 208 | 186 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.22 Southwest Mesa Wind Project

Table 11-92: Site Information for Southwest Mesa

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|------------|-----------------------------|--------------------------|--------|----------|-----------------|-----------------|
| SW_MESA | WIND | McComey | UPTON | Jun-99 | 75 | FPL Energy | Southwest Mesa Wind Project | NEG Micon (107) | ERCOT | AEP-West | WTU | MAF |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| SW_MESA_SW_MESA | SW_MESA | 75 |

11.22.1 Southwest Mesa Wind Project – SW_MESA_SW_MESA




Figure 11-93: SW_MESA_SW_MESA - Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-94: SW_MESA_SW_MESA – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-93: SW_MESA_SW_MESA – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -110.7568 |
| Left Slope (MWh/mph-day) | 67.4901 |
| RMSE (MWh/day) | 267.7022 |
| R2 | 0.4452 |
| CV-RMSE | 47.6% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -470.8379 |
| Left Slope (MWh/mph-day) | 112.6634 |
| RMSE (MWh/day) | 173.2956 |
| R2 | 0.7784 |
| CV-RMSE | 32.1% |

Table 11-94: SW_MESA_SW_MESA – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|---|
| Jan-07 | 31 | 9.46 | 12,588 | 16,352 | -29.90% | 23% | 29% |
| Feb-07 | 28 | 11.24 | 16,276 | 18,147 | -11.50% | 32% | 36% |
| Mar-07 | 31 | 10.28 | 20,371 | 18,076 | 11.26% | 37% | 32% |
| Apr-07 | 30 | 12.32 | 20,523 | 21,615 | -5.32% | 38% | 40% |
| May-07 | 31 | 9.65 | 15,976 | 16,766 | -4.94% | 29% | 30% |
| Jun-07 | 29 | 9.98 | 16,039 | 16,325 | -1.78% | 31% | 31% |
| Jul-07 | 31 | 8.01 | 11,755 | 13,368 | -13.72% | 21% | 24% |
| Aug-07 | 31 | 9.98 | 20,785 | 20,273 | 2.46% | 37% | 36% |
| Sep-07 | 30 | 8.89 | 17,310 | 14,841 | 14.26% | 32% | 27% |
| Oct-07 | 31 | 10.21 | 19,744 | 17,934 | 9.16% | 35% | 32% |
| Nov-07 | 30 | 8.90 | 15,192 | 14,697 | 3.25% | 28% | 27% |
| Dec-07 | 31 | 8.80 | 16,633 | 14,973 | 9.98% | 30% | 27% |
| Total | 364 | 9.80 | 203,192 | 203,367 | -0.09% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 8.97 | 33,981 | 34,156 | -0.52% | 30% | 30% |




Figure 11-95: SW_MESA_SW_MESA – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-96: SW_MESA_SW_MESA – Predicted Capacity Factors Using Daily Models (2007)

Table 11-95: SW_MESA_SW_MESA – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 232,435 | 203,750 | 596 | 539 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.23 Woodward Mountain Ranch (WOODWRD1)

Table 11-96: Site Information for Woodward Mountain Ranch (WOODWRD1)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|---------------|-------------------------|--------------------------|--------|----------|-----------------|-----------------|
| WOODWRD1 | WIND | McCamey | PECOS | Jul-01 | 80 | FPL/Cielo/TXU | Woodward Mountain Ranch | Vestas V-47 (121) | ERCOT | AEP-West | WTU | FST |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|-------------------|-------------------|---------------|
| WOODWRD1_WOODWRD1 | WOODWRD1 | 80 |

11.23.1 Woodward Mountain Ranch (WOODWRD1_WOODWRD1)




Figure 11-97: WOODWRD1_WOODWRD1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-98: WOODWRD1_WOODWRD1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-97: WOODWRD1_WOODWRD1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -307.6020 |
| Left Slope (MWh/mph-day) | 76.5842 |
| RMSE (MWh/day) | 213.9926 |
| R2 | 0.5846 |
| CV-RMSE | 43.6% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -487.4650 |
| Left Slope (MWh/mph-day) | 97.9257 |
| RMSE (MWh/day) | 154.8833 |
| R2 | 0.7585 |
| CV-RMSE | 31.8% |

Table 11-98: WOODWRD1_WOODWRD1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 29 | 9.07 | 9,975 | 11,234 | -0.13 | 18% | 20% |
| Feb-07 | 27 | 11.21 | 12,634 | 14,877 | -0.18 | 24% | 29% |
| Mar-07 | 31 | 11.67 | 17,558 | 18,162 | -0.03 | 29% | 31% |
| Apr-07 | 30 | 12.99 | 18,108 | 20,610 | -0.14 | 31% | 36% |
| May-07 | 28 | 10.00 | 11,646 | 12,837 | -0.10 | 22% | 24% |
| Jun-07 | 30 | 10.19 | 13,559 | 14,177 | -0.05 | 24% | 25% |
| Jul-07 | 30 | 9.51 | 11,522 | 13,153 | -0.14 | 20% | 23% |
| Aug-07 | 31 | 10.51 | 18,202 | 16,806 | 0.08 | 31% | 28% |
| Sep-07 | 29 | 9.95 | 15,623 | 13,304 | 0.15 | 28% | 24% |
| Oct-07 | 31 | 10.27 | 17,553 | 14,853 | 0.15 | 29% | 25% |
| Nov-07 | 27 | 8.88 | 10,934 | 10,053 | 0.08 | 21% | 19% |
| Dec-07 | 31 | 9.67 | 16,177 | 13,423 | 0.17 | 27% | 23% |
| Total | 354 | 10.34 | 173,490 | 173,490 | 0.00 | 26% | 26% |
| Total in OSP (07/15-09/15) | 63 | 9.95 | 30,706 | 30,706 | 0.00 | 25% | 25% |




Figure 11-99: WOODWRD1_WOODWRD1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-100: WOODWRD1_WOODWRD1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-99: WOODWRD1_WOODWRD1 – Predicted Power Production in 1999

| Annual | OSD |
|---|--|
| 1999 Estimated MWh/yr (2007 Daily Model) | 1999 OSD Estimated MWh/day (2007 Daily Model) |
| 202,553 | 488 |
| 2007 Measured MWh/yr for Modeling | 2007 OSD Measured MWh/day for Modeling |
| 178,881 | 487 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.24 Woodward Mountain Ranch (WOODWRD2)

Table 11-100: Site Information for Woodward Mountain Ranch (WOODWRD2)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station |
|-------------------|------------------|---------|--------|-----------------|---------------|---------------|-------------------------|--------------------------|--------|----------|-----------------|-----------------|
| WOODWRD2 | WIND | McCamey | PECOS | Jul-01 | 80 | FPL/Cielo/TXU | Woodward Mountain Ranch | Vestas V-47 (121) | ERCOT | AEP-West | WTU | FST |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|-------------------|-------------------|---------------|
| WOODWRD2_WOODWRD2 | WOODWRD2 | 80 |

11.24.1 Woodward Mountain Ranch (WOODWRD2_WOODWRD2)




Figure 11-101: WOODWRD2_WOODWRD2 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-102: WOODWRD2_WOODWRD2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-101: WOODWRD2_WOODWRD2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -295.3532 |
| Left Slope (MWh/mph-day) | 72.3576 |
| RMSE (MWh/day) | 189.0851 |
| R2 | 0.6167 |
| CV-RMSE | 41.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -446.4468 |
| Left Slope (MWh/mph-day) | 90.8552 |
| RMSE (MWh/day) | 134.9829 |
| R2 | 0.7806 |
| CV-RMSE | 29.5% |

Table 11-102: WOODWRD2_WOODWRD2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|--|---|--|------------|--------------------------|--|
| Jan-07 | 29 | 9.07 | 9,465 | 10,477 | -10.69% | 17% | 19% |
| Feb-07 | 27 | 11.21 | 12,170 | 13,929 | -14.45% | 23% | 27% |
| Mar-07 | 31 | 11.67 | 16,245 | 17,013 | -4.73% | 27% | 29% |
| Apr-07 | 30 | 12.99 | 17,518 | 19,331 | -10.35% | 30% | 34% |
| May-07 | 28 | 10.00 | 11,145 | 11,996 | -7.63% | 21% | 22% |
| Jun-07 | 30 | 10.19 | 13,024 | 13,253 | -1.76% | 23% | 23% |
| Jul-07 | 30 | 9.51 | 10,938 | 12,323 | -12.67% | 19% | 21% |
| Aug-07 | 31 | 10.51 | 17,262 | 15,770 | 8.65% | 29% | 26% |
| Sep-07 | 29 | 9.95 | 14,014 | 12,493 | 10.85% | 25% | 22% |
| Oct-07 | 31 | 10.27 | 16,186 | 13,887 | 14.21% | 27% | 23% |
| Nov-07 | 27 | 8.88 | 10,035 | 9,370 | 6.63% | 19% | 18% |
| Dec-07 | 31 | 9.67 | 14,376 | 12,535 | 12.80% | 24% | 21% |
| Total | 354 | 10.34 | 162,378 | 162,378 | 0.00% | 24% | 24% |
| Total in OSP (07/15-09/15) | 63 | 9.95 | 28,850 | 28,850 | 0.00% | 24% | 24% |




Figure 11-103: WOODWRD2_WOODWRD2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-104: WOODWRD2_WOODWRD2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-103: WOODWRD2_WOODWRD2 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|--------------------------------------|--|---|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr for Modeling | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day for Modeling |
| 189,790 | 167,424 | 458 | 458 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.25 Buffalo Gap2 (BUFF_GAP_UNIT2)

Table 11-104: Site Information for Buffalo Gap (BUFF_GAP_UNIT2)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|--------|-----------------|---------------|-----------------|--------------|--------------------------|--------|----------|-----------------|-----------------|---------|
| BUFF_CAP | WIND | Abilene | TAYLOR | May-07 | 233 | AES Corporation | Buffalo Gap2 | Vestas 1.8 MW (67) | ERCOT | AEP-West | AEP-TNC | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| BUFF_GAP_UNIT2 | BUFF_CAP | 233 | | | | | | | | | | | |

11.26 Buffalo Gap2 (BUFF_GAP_UNIT2)




Figure 11-105: BUFF_GAP_UNIT2 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-106: BUFF_GAP_UNIT2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-105: BUFF_GAP_UNIT2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -1378.88 |
| Left Slope (MWh/mph-day) | 294.72 |
| RMSE (MWh/day) | 582.9618 |
| R2 | 0.7619 |
| CV-RMSE | 40.4% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -1369.732 |
| Left Slope (MWh/mph-day) | 312.5814 |
| RMSE (MWh/day) | 530.11 |
| R2 | 0.809 |
| CV-RMSE | 44.4% |

Table 11-106: BUFF_GAP_UNIT2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | 27 | 8.25 | 16,789 | 29,674 | -76.75% | 11% | 20% |
| Jun-07 | 28 | 9.05 | 22,802 | 36,426 | -59.75% | 15% | 23% |
| Jul-07 | 31 | 6.95 | 19,973 | 24,624 | -23.28% | 12% | 14% |
| Aug-07 | 31 | 9.10 | 50,595 | 46,448 | 8.20% | 29% | 27% |
| Sep-07 | 30 | 9.04 | 40,246 | 41,322 | -2.67% | 24% | 25% |
| Oct-07 | 30 | 10.77 | 59,416 | 54,262 | 8.67% | 35% | 32% |
| Nov-07 | 29 | 10.16 | 57,006 | 46,958 | 17.63% | 35% | 29% |
| Dec-07 | 30 | 10.36 | 58,126 | 50,220 | 13.60% | 35% | 30% |
| Total | 236 | 9.21 | 324,954 | 329,933 | -1.53% | 25% | 25% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 75,246 | 77,676 | -3.23% | 21% | 22% |




Figure 11-107: BUFF_GAP_UNIT2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-108: BUFF_GAP_UNIT2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-107: BUFF_GAP_UNIT2 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 724,458 | 502,577 | 1,665 | 1,194 |
| 1999 (May-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (May-Dec) Measured MWh/yr | |
| 451,147 | | 337,346 | |

Note: The 2007 (May-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 245 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.27 Capricorn Ridge Wind (CAPRIDGE_CR1)

Table 11-108: Site Information for Capricorn Ridge Wind (CAPRIDGE_CR1)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|------------------|---------|----------|-----------------|---------------|------------|----------------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| CAPRIDGE_CR1 | WIND | ABILENE | Sterling | Sep-07 | 214.5 | FPL Energy | Capricorn Ridge Wind | FPL Energy | ERCOT | | LCRA | ABI | |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| CAPRIDGE_CR1 | CAPRIDGE_CR1 | 214.5 |

11.27.1 Capricorn Ridge Wind (CAPRIDGE_CR1)




Figure 11-109: CAPRIDGE_CR1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-110: CAPRIDGE_CR1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-109: CAPRIDGE_CR1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -250.3573 |
| Left Slope (MWh/mph-day) | 161.4228 |
| RMSE (MWh/day) | 546.4666 |
| R2 | 0.5433 |
| CV-RMSE | 37.5% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | |
| Left Slope (MWh/mph-day) | |
| RMSE (MWh/day) | |
| R2 | |
| CV-RMSE | |

Table 11-110: CAPRIDGE_CR1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | | | | | | | |
| Jul-07 | | | | | | | |
| Aug-07 | | | | | | | |
| Sep-07 | 15 | 10.56 | 13,908 | 21,810 | -56.81% | 18% | 28% |
| Oct-07 | 29 | 11.26 | 38,992 | 45,436 | -16.53% | 26% | 30% |
| Nov-07 | 28 | 10.57 | 46,090 | 40,759 | 11.57% | 32% | 28% |
| Dec-07 | 28 | 9.92 | 46,859 | 37,845 | 19.24% | 33% | 26% |
| Total | 100 | 10.59 | 145,850 | 145,850 | 0.00% | 28% | 28% |
| Total in OSP (07/15-09/15) | | | | | | | |




Figure 11-111: CAPRIDGE_CR1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-112: CAPRIDGE_CR1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-111: CAPRIDGE_CR1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 490,972 | 532,351 | | |
| 1999 (Sep-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Sep-Dec) Measured MWh/yr | |
| 150,290 | | 177,936 | |

Note: The 2007 (Sep-Dec) Measured MWh/yr presented in the above table includes only validated data and it was adjusted to 122 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.28 Capricorn Ridge Wind (CAPRIDGE_CR2)

Table 11-112: Site Information for Capricorn Ridge Wind (CAPRIDGE_CR2)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|------------------|---------|----------|-----------------|---------------|------------|----------------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| CAPRIDGE_CR2 | WIND | ABILENE | Sterling | Sep-07 | 149.5 | FPL Energy | Capricorn Ridge Wind | GE Energy | ERCOT | | LCRA | ABI | |

| SUBGENCODE_ERCOT | GENSITECODE_ERCO T | Capacity (MW) |
|------------------|--------------------|---------------|
| CAPRIDGE_CR2 | CAPRIDGE_CR2 | 149.5 |

11.28.1 Capricorn Ridge Wind (CAPRIDGE_CR2)




Figure 11-113: CAPRIDGE_CR2 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-114: CAPRIDGE_CR2 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-113: CAPRIDGE_CR2 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -399.4675 |
| Left Slope (MWh/mph-day) | 148.4157 |
| RMSE (MWh/day) | 374.5225 |
| R2 | 0.6879 |
| CV-RMSE | 31.8% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | |
| Left Slope (MWh/mph-day) | |
| RMSE (MWh/day) | |
| R2 | |
| CV-RMSE | |

Table 11-114: CAPRIDGE_CR2 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | | | | | | | |
| Jul-07 | | | | | | | |
| Aug-07 | | | | | | | |
| Sep-07 | 15 | 10.56 | 14,560 | 17,513 | -20.28% | 27% | 33% |
| Oct-07 | 31 | 11.05 | 41,416 | 38,453 | 7.15% | 37% | 35% |
| Nov-07 | 30 | 10.37 | 32,421 | 34,175 | -5.41% | 30% | 32% |
| Dec-07 | 31 | 10.51 | 37,700 | 35,956 | 4.62% | 34% | 32% |
| Total | 107 | 10.63 | 126,098 | 126,098 | 0.00% | 33% | 33% |
| Total in OSP (07/15-09/15) | | | | | | | |




Figure 11-115: CAPRIDGE_CR2 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-116: CAPRIDGE_CR2 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-115: CAPRIDGE_CR2 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 400,311 | 430,146 | | |
| 1999 (Sep-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Sep-Dec) Measured MWh/yr | |
| 120,091 | | 143,775 | |

Note: The 2007 (Sep-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 122 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.29 Camp Springs Wind Energy Center (CSEC_CSECG1)

Table 11-116: Site Information for Camp Springs Wind Energy Center (CSEC_CSECG1)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|--------------------|---------|--------|-----------------|---------------|------------|---------------------------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| CSEC_CSECG1 | WIND | Lubbock | Scurry | Jun-07 | 135 | FPL ENERGY | Camp Springs Wind Energy Center | GE Energy | ERCOT | | Oncor | LBB | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCO T | | | | | | | | | | | | |
| CSEC_CSECG1 | CSEC_CSEC | | | | 135 | | | | | | | | |

| SUBGENCODE_ERCOT | GENSITECODE_ERCO T | Capacity (MW) |
|------------------|--------------------|---------------|
| CSEC_CSECG1 | CSEC_CSEC | 135 |

11.29.1 Camp Springs Wind Energy Center (CSEC_CSECG1)




Figure 11-117: CSEC_CSECG1– Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-118: CSEC_CSECG1– Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-117: CSEC_CSECG1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -397.1139 |
| Left Slope (MWh/mph-day) | 141.4519 |
| RMSE (MWh/day) | 539.0513 |
| R2 | 0.4421 |
| CV-RMSE | 49.7% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -768.8942 |
| Left Slope (MWh/mph-day) | 166.2396 |
| RMSE (MWh/day) | 294.4827 |
| R2 | 0.7789 |
| CV-RMSE | 36.6% |

Table 11-118: CSEC_CSECG1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | 30 | 10.57 | 19,958 | 32,950 | -65.10% | 21% | 34% |
| Jul-07 | 31 | 8.07 | 14,849 | 20,247 | -36.36% | 15% | 20% |
| Aug-07 | 31 | 10.56 | 33,252 | 30,559 | 8.10% | 33% | 30% |
| Sep-07 | 30 | 9.67 | 28,150 | 26,740 | 5.01% | 29% | 28% |
| Oct-07 | 31 | 11.50 | 41,498 | 38,099 | 8.19% | 41% | 38% |
| Nov-07 | 30 | 10.20 | 35,323 | 31,377 | 11.17% | 36% | 32% |
| Dec-07 | 31 | 10.67 | 41,441 | 34,498 | 16.75% | 41% | 34% |
| Total | 214 | 10.18 | 214,472 | 214,472 | 0.00% | 31% | 31% |
| Total in OSP (07/15-09/15) | 63 | 9.47 | 50,735 | 50,735 | 0.00% | 25% | 25% |




Figure 11-119: CSEC_CSECG1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-120: CSEC_CSECG1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-119: CSEC_CSECG1 – Predicted Power Production in 1999

Annual

| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr |
|---|----------------------|
| 468,181 | 365,804 |

OSD

| 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
|--|------------------------------|
| 868 | 805 |

| 1999 (Jun-Dec) Estimated MWh/yr (2007 Daily Model) | 2007 (Jun-Dec) Measured MWh/yr |
|---|-----------------------------------|
| 236,787 | 214,472 |

Note: The 2007 (Jun-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 214 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.30 Lone Star – Mesquite Wind (LNCRK_G83)

Table 11-120: Site Information for Lone Star – Mesquite Wind (LNCRK_G83)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|-------------|-----------------|---------------|---------------------|-----------|--------------------------|--------|-----|-----------------|-----------------|---------|
| LNCRK_G83 | WIND | Abilene | Shackelford | Mar-07 | 200 | Horizon Wind Energy | LNCRK_G83 | Vestas 1.8 MW (67) | ERCOT | | Oncor | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| LNCRK_G83 | LNCRK_G83 | 200 | | | | | | | | | | | |

11.30.1 Lone Star – Mesquite Wind (LNCRK_G83)




Figure 11-121: LNCRK_G83– Hourly Wind Power vs. NOAA Wind Speed (2007)



Figure 11-122: LNCRK_G83– Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-121: LNCRK_G83 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -794.5221 |
| Left Slope (MWh/mph-day) | 203.2856 |
| RMSE (MWh/day) | 453.1796 |
| R2 | 0.7340 |
| CV-RMSE | 36.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -413.2860 |
| Left Slope (MWh/mph-day) | 123.3985 |
| RMSE (MWh/day) | 225.3374 |
| R2 | 0.7856 |
| CV-RMSE | 37.6% |

Table 11-122: LNCRK_G83 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | | | | | | | |
| Jul-07 | 31 | 6.95 | 8,415 | 16,127 | -91.64% | 6% | 11% |
| Aug-07 | 31 | 9.10 | 25,294 | 22,032 | 12.90% | 17% | 15% |
| Sep-07 | 30 | 9.04 | 23,730 | 28,019 | -18.07% | 16% | 19% |
| Oct-07 | 30 | 10.77 | 40,497 | 41,957 | -3.60% | 28% | 29% |
| Nov-07 | 30 | 10.37 | 41,313 | 39,388 | 4.66% | 29% | 27% |
| Dec-07 | 30 | 10.36 | 47,261 | 39,337 | 16.77% | 33% | 27% |
| Total | 182 | 9.42 | 186,511 | 186,859 | -0.19% | 21% | 21% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 37,734 | 37,974 | -0.63% | 12% | 13% |




Figure 11-123: LNCRK_G83 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-124: LNCRK_G83 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-123: LNCRK_G83 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 523,340 | 374,047 | 785 | 599 |
| 1999 (Jul-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Jul-Dec) Measured MWh/yr | |
| 208,662 | | 188,561 | |

Note: The 2007 (Mar-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 306 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.31 Forest Creek Wind Farm (MCDLD_FCW1)

Table 11-124: Site Information for Forest Creek Wind Farm (MCDLD_FCW1)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|----------|-----------------|---------------|------------|------------------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| MCDLD_FCW1 | WIND | ABILENE | STERLING | Jan-07 | 125 | Airtricity | Forest Creek Wind Farm | Siemens | ERCOT | | TXU-ED | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| MCDLD_FCW1 | MCDLD_FCW1 | 125 | | | | | | | | | | | |

11.31.1 Forest Creek Wind Farm (MCDLD_FCW1)




Figure 11-125: MCDLD_FCW1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-126: MCDLD_FCW1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-125: MCDLD_FCW1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -443.894 |
| Left Slope (MWh/mph-day) | 142.9576 |
| RMSE (MWh/day) | 386.7189 |
| R2 | 0.6902 |
| CV-RMSE | 36.4% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -574.7724 |
| Left Slope (MWh/mph-day) | 169.8109 |
| RMSE (MWh/day) | 315.6254 |
| R2 | 0.7796 |
| CV-RMSE | 38.6% |

Table 11-126: MCDLD_FCW1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | 27 | 9.17 | 12,567 | 23,423 | -86.38% | 16% | 29% |
| Feb-07 | 28 | 12.04 | 31,982 | 35,772 | -11.85% | 38% | 43% |
| Mar-07 | 31 | 11.82 | 36,123 | 38,603 | -6.87% | 39% | 42% |
| Apr-07 | 30 | 12.85 | 40,746 | 41,805 | -2.60% | 45% | 46% |
| May-07 | 31 | 9.32 | 26,136 | 27,524 | -5.31% | 28% | 30% |
| Jun-07 | 30 | 9.53 | 27,826 | 27,533 | 1.05% | 31% | 31% |
| Jul-07 | 31 | 6.95 | 15,560 | 18,370 | -18.06% | 17% | 20% |
| Aug-07 | 31 | 9.10 | 34,332 | 30,143 | 12.20% | 37% | 32% |
| Sep-07 | 30 | 9.04 | 27,183 | 26,551 | 2.33% | 30% | 30% |
| Oct-07 | 31 | 11.05 | 41,152 | 35,207 | 14.45% | 44% | 38% |
| Nov-07 | 29 | 10.17 | 34,153 | 29,295 | 14.22% | 39% | 34% |
| Dec-07 | 31 | 10.51 | 38,914 | 32,801 | 15.71% | 42% | 35% |
| Total | 360 | 10.12 | 366,674 | 367,027 | -0.10% | 34% | 34% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 51,546 | 51,900 | -0.69% | 27% | 27% |




Figure 11-127: MCDLD_FCW1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-128: MCDLD_FCW1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-127: MCDLD_FCW1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 435,455 | 371,766 | 1,074 | 818 |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.32 Sand Bluff Wind Farm (MCDLD_SBW1)

Table 11-128: Site Information for Sand Bluff Wind Farm (MCDLD_SBW1)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|------------------|---------|----------|-----------------|---------------|------------|----------------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| MCDLD_SBW1 | WIND | ABILENE | STERLING | Jan-07 | 90 | Airtricity | Sand Bluff Wind Farm | Siemens | ERCOT | | TXU-ED | ABI | |

| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) |
|------------------|-------------------|---------------|
| MCDLD_SBW1 | MCDLD_SBW2 | 90 |

11.32.1 Sand Bluff Wind Farm (MCDLD_SBW1)




Figure 11-129: MCDLD_SBW1 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-130: MCDLD_SBW1 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-129: MCDLD_SBW1 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -30.3215 |
| Left Slope (MWh/mph-day) | 41.0793 |
| RMSE (MWh/day) | 194.4011 |
| R2 | 0.4151 |
| CV-RMSE | 49.6% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -133.7765 |
| Left Slope (MWh/mph-day) | 60.3486 |
| RMSE (MWh/day) | 132.4880 |
| R2 | 0.7050 |
| CV-RMSE | 37.4% |

Table 11-130: MCDLD_SBW1 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | 17 | 10.99 | 2,566 | 7,160 | -179.03% | 7% | 19% |
| Mar-07 | 27 | 12.00 | 9,208 | 12,486 | -35.60% | 16% | 21% |
| Apr-07 | 29 | 12.92 | 11,831 | 14,517 | -22.70% | 19% | 23% |
| May-07 | 31 | 9.32 | 8,394 | 10,923 | -30.13% | 13% | 16% |
| Jun-07 | 30 | 9.53 | 9,343 | 10,829 | -15.90% | 14% | 17% |
| Jul-07 | 31 | 6.95 | 7,765 | 8,529 | -9.84% | 12% | 13% |
| Aug-07 | 30 | 8.88 | 13,374 | 12,072 | 9.73% | 21% | 19% |
| Sep-07 | 29 | 8.85 | 12,442 | 10,286 | 17.32% | 20% | 16% |
| Oct-07 | 25 | 9.75 | 13,001 | 9,258 | 28.79% | 24% | 17% |
| Nov-07 | 30 | 10.37 | 16,043 | 11,866 | 26.03% | 25% | 18% |
| Dec-07 | 22 | 9.23 | 11,609 | 7,670 | 33.93% | 24% | 16% |
| Total | 301 | 9.82 | 115,574 | 115,597 | -0.02% | 18% | 18% |
| Total in OSP (07/15-09/15) | 62 | 8.09 | 21,958 | 21,981 | -0.11% | 16% | 16% |




Figure 11-131: MCDLD_SBW1 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-132: MCDLD_SBW1 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-131: MCDLD_SBW1 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 163,514 | 140,148 | 452 | 354 |
| 1999 (Feb-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Feb-Dec) Measured MWh/yr | |
| 149,417 | | 128,245 | |

Note: The 2007 Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 365 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.33 Sweetwater (SWEETWN2_WND24 18 MW)

Table 11-132: Site Information for Sweetwater (SWEETWN2_WND24)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|--------|-----------------|---------------|------------------|---------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| SWEETWN2_WND24 | WIND | Abilene | HOLIAN | Apr-07 | 18 | DKRW Development | SWEET WIND 24 | | ERCOT | | LCRA | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| SWEETWN2_WND24 | SWEETWN2_WND24 | 18 | | | | | | | | | | | |

11.33.1 Sweetwater (SWEETWN2_WND24)




Figure 11-133: SWEETWN2_WND24 – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-134: SWEETWN2_WND24 – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-133: SWEETWN2_WND24 – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -101.8787 |
| Left Slope (MWh/mph-day) | 23.2669 |
| RMSE (MWh/day) | 34.0359 |
| R2 | 0.8608 |
| CV-RMSE | 26.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -96.6399 |
| Left Slope (MWh/mph-day) | 22.4031 |
| RMSE (MWh/day) | 41.7246 |
| R2 | 0.7789 |
| CV-RMSE | 47.9% |

Table 11-134: SWEETWN2_WND24 – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | 30 | 9.53 | 3,270 | 3,615 | -10.55% | 25% | 28% |
| Jul-07 | 31 | 6.95 | 1,650 | 1,933 | -17.16% | 12% | 14% |
| Aug-07 | 31 | 9.10 | 3,671 | 3,373 | 8.12% | 27% | 25% |
| Sep-07 | 29 | 9.12 | 3,014 | 3,220 | -6.81% | 24% | 26% |
| Oct-07 | 30 | 10.87 | 4,572 | 4,556 | 0.36% | 35% | 35% |
| Nov-07 | 30 | 10.37 | 4,249 | 4,184 | 1.55% | 33% | 32% |
| Dec-07 | 29 | 10.16 | 4,127 | 3,904 | 5.42% | 33% | 31% |
| Total | 210 | 9.43 | 24,554 | 24,783 | -0.94% | 27% | 27% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 5,489 | 5,651 | -2.95% | 20% | 21% |




Figure 11-135: SWEETWN2_WND24 – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-136: SWEETWN2_WND24 – Predicted Capacity Factors Using Daily Models (2007)

Table 11-135: SWEETWN2_WND24 – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 58,591 | 42,677 | 121 | 87 |
| 1999 (Jun-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Jun-Dec) Measured MWh/yr | |
| 30,361 | | 25,021 | |

Note: The 2007 (Apr-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 275 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.34 Sweetwater (SWEETWN4_WIND4A)

Table 11-136: Site Information for Sweetwater (SWEETWN4_WIND4A)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------|--------|-----------------|---------------|---------------------|---------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| SWEETWN4_WND4A | WIND | Abilene | NOLAN | Apr-07 | 120 | DKRW/ Babcock Brown | SWEET WIND 4A | Mitsubishi | ERCOT | | LCRA | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | | | | | | | | | | | | |
| SWEETWN4_WND4A | SWEETWN4_WND4A | | | | 120 | | | | | | | | |

11.34.1 Sweetwater (SWEETWN4_WIND4A)




Figure 11-137: SWEETWN4_WIND4A – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-138: SWEETWN4_WIND4A – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-137: SWEETWN4_WIND4A – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -480.5448 |
| Left Slope (MWh/mph-day) | 135.6657 |
| RMSE (MWh/day) | 272.0618 |
| R2 | 0.7712 |
| CV-RMSE | 30.1% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|-------------------------|
| Ycp (MWh/day) | -457.1491 |
| Left Slope (MWh/mph-day) | 128.6757 |
| RMSE (MWh/day) | 222.1949 |
| R2 | 0.8121 |
| CV-RMSE | 35.4% |

Table 11-138: SWEETWN4_WIND4A – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|-------------------|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | 27 | 9.92 | 20,063 | 23,395 | -16.61% | 26% | 30% |
| Jul-07 | 26 | 7.17 | 10,792 | 12,590 | -16.66% | 14% | 17% |
| Aug-07 | 28 | 9.43 | 23,002 | 21,264 | 7.56% | 29% | 26% |
| Sep-07 | 28 | 8.92 | 17,772 | 20,062 | -12.89% | 22% | 25% |
| Oct-07 | 30 | 11.15 | 34,215 | 30,974 | 9.47% | 40% | 36% |
| Nov-07 | 30 | 10.37 | 26,671 | 27,777 | -4.15% | 31% | 32% |
| Dec-07 | 31 | 10.51 | 32,443 | 29,290 | 9.72% | 36% | 33% |
| Total | 200 | 9.70 | 164,958 | 165,352 | -0.24% | 29% | 29% |
| Total in OSP (07/15-09/15) | 57 | 8.44 | 35,814 | 36,168 | -0.99% | 22% | 22% |




Figure 11-139: SWEETWN4_WIND4A – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-140: SWEETWN4_WIND4A – Predicted Capacity Factors Using Daily Models (2007)

Table 11-139: SWEETWN4_WIND4A – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 381,096 | 301,049 | 792 | 628 |
| 1999 (Jun-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Jun-Dec) Measured MWh/yr | |
| 199,353 | | 176,505 | |

Note: The 2007 (Apr-Dec) Measured MWh/yr presented in the above table includes only validated data and was also adjusted to 275 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7.

11.35 Sweetwater (SWEETWN4_WIND4B)

Table 11-140: Site Information for Sweetwater (SWEETWN4_WIND4B)

| GENSITECODE_ERCOT | Renewable Energy | City | County | Date in Service | Capacity (MW) | Company | Facility | Wind Turbine Information | Region | PCA | Interconnection | Weather Station | Remarks |
|-------------------|-------------------|---------------|--------|-----------------|---------------|---------------------|---------------|--------------------------|--------|-----|-----------------|-----------------|---------|
| SWEETWN4_WND4B | WIND | Abilene | NOLAN | Apr-07 | 105 | DKRW/ Babcock Brown | SWEET WIND 4B | Siemens | ERCOT | | LCRA | ABI | |
| SUBGENCODE_ERCOT | GENSITECODE_ERCOT | Capacity (MW) | | | | | | | | | | | |
| SWEETWN4_WND4B | SWEETWN4_WND4B | 105 | | | | | | | | | | | |

11.35.1 Sweetwater (SWEETWN4_WIND4B)




Figure 11-141: SWEETWN4_WIND4B – Hourly Wind Power vs. NOAA Wind Speed (2007)




Figure 11-142: SWEETWN4_WIND4B – Daily Wind Power vs. NOAA Wind Speed (Using OSP and Non-OSP Model)

Table 11-141: SWEETWN4_WIND4B – Model Coefficients

Using Non-OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -443.9256 |
| Left Slope (MWh/mph-day) | 126.2999 |
| RMSE (MWh/day) | 261.5789 |
| R2 | 0.7649 |
| CV-RMSE | 33.2% |

Using OSP Model:

| IMT Coefficients | NOAA Daily Model |
|-----------------------------|------------------|
| Ycp (MWh/day) | -408.8710 |
| Left Slope (MWh/mph-day) | 123.0498 |
| RMSE (MWh/day) | 207.5254 |
| R2 | 0.8112 |
| CV-RMSE | 34.6% |

Table 11-142: SWEETWN4_WIND4B – Comparison of Predicted Power vs. Measured Power

| Month | No. Of Days | Average Daily Wind Speed (MPH) NOAA | Measured Power Generation (MWh) NOAA | Predicted Power Generation Using Daily Model (MWh) NOAA | Diff. NOAA | Measured Capacity Factor | Capacity Factor Using Daily Model NOAA |
|----------------------------|-------------|---|--|---|---|--------------------------|--|
| Jan-07 | | | | | | | |
| Feb-07 | | | | | | | |
| Mar-07 | | | | | | | |
| Apr-07 | | | | | | | |
| May-07 | | | | | | | |
| Jun-07 | 30 | 9.53 | 19,718 | 22,785 | -15.55% | 26% | 30% |
| Jul-07 | 31 | 6.95 | 11,906 | 13,850 | -16.33% | 15% | 18% |
| Aug-07 | 31 | 9.10 | 23,729 | 22,065 | 7.01% | 30% | 28% |
| Sep-07 | 29 | 8.87 | 18,357 | 19,785 | -7.78% | 25% | 27% |
| Oct-07 | 30 | 11.15 | 33,236 | 28,935 | 12.94% | 44% | 38% |
| Nov-07 | 29 | 10.43 | 26,033 | 25,323 | 2.73% | 36% | 35% |
| Dec-07 | 31 | 10.51 | 30,402 | 27,375 | 9.96% | 39% | 35% |
| Total | 211 | 9.49 | 163,380 | 160,116 | 2.00% | 31% | 30% |
| Total in OSP (07/15-09/15) | 63 | 8.20 | 37,832 | 38,059 | -0.60% | 24% | 24% |




Figure 11-143: SWEETWN4_WIND4B – Predicted Wind Power in OSP Using NOAA Wind Speed (2007)




Figure 11-144: SWEETWN4_WND4B – Predicted Capacity Factors Using Daily Models (2007)

Table 11-143: SWEETWN4_WND4B – Predicted Power Production in 1999

| Annual | | OSD | |
|---|----------------------|--|------------------------------|
| 1999 Estimated MWh/yr (2007 Daily Model) | 2007 Measured MWh/yr | 1999 OSD Estimated MWh/day (2007 Daily Model) | 2007 OSD Measured MWh/day |
| 358,870 | 282,625 | 786 | 601 |
| 1999 (Jun-Dec) Estimated MWh/yr (2007 Daily Model) | | 2007 (Jun-Dec) Measured MWh/yr | |
| 189,153 | | 165,703 | |

Note: The 2007 (Apr-Dec) Measured MWh/yr presented in the above table included only validated data and it was also adjusted to 275 days. Therefore, this number could be different from the original ERCOT data shown in Table 3-7

12 APPENDIX C

- 12.1 Data Files for Wind Energy Production and Weather Files for the Modeling
WT-2009 HARC DATA.xls
- 12.2 Papers Presented
Liu, Z., Haberl, J. S., Baltazar, J. C., Culp, C., Yazdani, B., Chandrasekaran, V., 2008.
“Calculating Emissions Reduction from Renewable Energy Programs and Its Application to the
Wind Farms in the Texas ERCOT Region,” *16th Symposium on Improving Building Systems in
Hot and Humid Climates, Dallas TX, December 16-17, 2008*