

Moving Towards Net-Zero Energy of Existing Building on Hot Climate

Dr. Ali Alajmi¹, Dr. Adel Ghonaim², and Dr. Hosny Abou-Ziyan¹

¹Department of Mechanical Engineering, College of Technological Studies

²Department of Applied Science, College of Technological Studies

Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Outline


- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Background

- Overview of the country consumption per capita
- Overview of the country CO₂ per capita
- Definition of Net-Zero Energy Building (NZEB)
- Definition of near Net-Zero Energy Building (nNZEB)
- Why NZEB of existing building?


Energy Consumption: Annual per capita

Units: kWh per person



Carbon Emissions: Annual per capita

Units: Metric tons of CO2 per person



Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Net-Zero or near Net-Zero Energy Building

- Net-Zero Energy Buildings (NZEBS) are:

$$E_{Annual\ Renewable} = E_{Annual\ consumed}$$

- It is called near Net-Zero Energy Building (nNZEB) if:

$$E_{Annual\ Renewable} \approx E_{Annual\ consumed}$$

- European countries has issued a legislation that public buildings have to be nearly zero energy building by the end of year 2018
- ASHRAE assign a target of net zero energy buildings fulfillment by 2031

Why NZEB of Existing Buildings?

**75% to 80% of All Buildings
That will Exist in 2030**

Exist Today



Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Studied Building Status and Energy Consumption

- A two-story institutional facility, that houses the Mechanical Engineering Department (MED), College of Technological Studies(CTS)
- The total floor area of 7020 square meters (offices, classrooms, laboratories, and workshops)




HVAC Description


- 4 air-cooled centrifugal chillers with capacity of 429 kW (122 ton) each.
- 14 CV AHUs for offices, class rooms, and laboratories.
- 29 FCUs for the workshops

First and Ground Floors Layout

First



Ground



Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Phase-I: Energy Conservation at Minimum Cost

➤ Level I – Walk-Through Assessment



Level I – Walk-Through Assessment

...cont.



Level I – Walk-Through Assessment

...cont.



Level I – Walk-Through Assessment

...cont.




Level I – Walk-Through Assessment


...cont.




Measuring Data



Survey Outcomes



Measuring Data




Annual Building Consumption

Building Consumptions Vs. Benchmarking

Actual Building Energy Consumption (kWh/m ² .year)		Typical Building Energy Consumption (kWh/m ² .year)*	
2008	2009	2008	2009
599	622	295	327

*Normalized to be similar to the actual building specification.

Annual Building Consumption




Energy Conservation with Minimum Cost

Table 1: Energy conservation with minimum cost


(% energy savings are based on the average building consumption of 4.44 GWh).

<i>No.</i>	<i>Recommended Actions</i>	<i>Energy saving GWh/year</i>	<i>% energy saving</i>
1	<i>Schedule lighting operation</i>	0.10	2.3
2	<i>Schedule office equipment</i>	0.01	0.2
3	<i>Reduce infiltration</i>	0.18	4.1
<i>Total</i>		0.29	6.5


Building Energy Consumption




Average energy consumption during full day for the different operation scenarios



Energy consumption during day time and night time for chilled water plant



Proposed water distribution system for chilled water plant



Additional Energy Conservation with Minimum Cost

Table 3: Summary of chiller energy saving for different proposed strategies
(% energy savings are based on the chiller consumption of 1900 MWh).

<i>Chillers Operation</i>	<i>Energy Saving MWh/year</i>	<i>% Energy Saving</i>
<i>Select the best operation scenario</i>	84.5	4.5
<i>Switch off chillers during non-occupied period (overnight)</i>	250.1	13.2
<i>Reduce chillers capacity by half during vacation</i>	53.7	2.8
<i>Reduce pumps capacity by half</i>	19.8	1.0
<i>Total (% energy savings with respect to chiller consumption)</i>	408.1	21.5
<i>Total (% energy savings with respect to building consumption)</i>	408.1	9.2

Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.


Phase-II: Energy Conservation with Investment

Monitoring and Analysis of the Building Performance



Phase-II: Energy Conservation with Investment

Mini-Data loggers Locations




Phase-II: Energy Conservation with Investment

AHU Variables Measurements



Data Analysis



Installation of BMS


Upgrade the HVAC System Control



Installation of BMS



Installation of BMS



Installation of BMS



Installation of BMS




Energy Conservation with Investment

Table 2: Energy conservation with investment.

(% energy savings are based on the average building consumption of 4.44 GWh).

<i>No.</i>	<i>Recommendations</i>	<i>Energy saving GWh/ year</i>	<i>% energy saving</i>
<i>1</i>	<i>Control Indoor Temperature to 24 °C</i>	<i>1.040</i>	<i>23.4</i>
<i>2</i>	<i>Set-back Temperature to 28 °C</i>	<i>0.250</i>	<i>5.6</i>
<i>3</i>	<i>Turn off HVAC during weekends</i>	<i>0.590</i>	<i>13.3</i>
<i>4</i>	<i>Proper maintenance and operation</i>	<i>0.056</i>	<i>1.3</i>
<i>5</i>	<i>Efficient lighting (T5)</i>	<i>0.100</i>	<i>2.3</i>
<i>6</i>	<i>Increase roof insulation</i>	<i>0.014</i>	<i>0.3</i>
	<i>Total</i>	<i>2.050</i>	<i>46.2</i>

Phase I&II Energy Consumption Reduction



Phase I&II Cost Analysis

		<i>Savings Analysis</i>		
		<i>Annual cost savings (USD/yr)¹</i>	<i>Cost of energy audit team or retrofit (USD)</i>	<i>Simple payback period (yr)</i>
<i>energy reduction in phase-I</i>	<i>Lighting schedule</i>	<i>13,408</i>		
	<i>Equipment schedule</i>	<i>1,190</i>	<i>18311</i>	<i>0.5</i>
	<i>Reduce infiltration (close doors)</i>	<i>23,490</i>		
<i>energy reduction in phase-II</i>	<i>Control indoor temperature</i>	<i>136,886</i>		
	<i>Temperature setback to 28 °C</i>	<i>33,660</i>	<i>109,869</i>	<i>0.5</i>
	<i>Turn off HVAC during weekends</i>	<i>78,509</i>		
	<i>Select the best operation scenario</i>			
	<i>Switch off chillers during non-occupied period (overnight)</i>	<i>4,896</i>	<i>5,250</i>	<i>1.1</i>
	<i>Reduce chillers capacity by half during vacation</i>			
	<i>Reduce pumps capacity by half</i>			
	<i>Efficient lightings (T5)</i>	<i>13,558</i>	<i>16,261</i>	<i>1.2</i>
	<i>Increase roof insulation by 2.5 cm</i>	<i>1,680</i>	<i>7,325</i>	<i>4.4</i>
	<i>HVAC maintenance</i>	<i>7,336</i>	<i>10,071</i>	<i>1.4</i>

Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Phase-III: Building Integrated Photovoltaic


- Study the feasibility of using any of the renewable source of energy
- Analyze the building energy consumption profile
- Select the appropriate renewable type and capacity.




Integrating PV on Existing Building

- Analyze the different sections of energy consumption.
- A Simulation program (DesignBuilder) has been used to predicted the hourly energy consumption.


A Yearly Load Profile



PV Annual Energy Generation



Building with the Integrated PV



Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Concluding Remarks

- Implementation of phases I & II' recommendations yields reduction of annual consumption from 4.44 GWh to about 1.56 GWh in 2011 as recorded by the building meter.
- The EUI reduces from about 632 to 222 KWh/m² compared to:
 - ✓ 171 KWh/m²; EIA 2003, and
 - ✓ local practical limits (315 to 410 KWh/m²).
- Retrofitting the lighting system and operation strategies will save about 0.508 GWh which reduces the annual energy consumption to about 1.052 GWh (equivalent EUI of about 150 KWh/m²).

Concluding Remarks ... cont.

- Replacing the existing reciprocating chillers will save more than half the current chillers consumption, i.e. 0.160 GWh.
- Improving the HVAC auxiliaries may lead to a considerable energy saving of about 0.1 GWh.
- The above items will lower the annual consumption to only 0.792 GWh.

Concluding Remarks ... cont.

- Integration of the PV modules in buildings results in annual energy generation of about 0.273 GWh.
- This left an annual energy required of about 0.519 GWh which should be supplied using conventional sources.
- The ongoing research on solar cells claims fast developing with respect to higher efficiency and lower cost. Nowadays, the laboratory scale solar cells reach efficiency up to 40% (Atwater, 2008).

Concluding Remarks ... cont.

- Alternatively, with the current used PV efficiency, the area required to balance the power should be increased.
- In conclusion, the forgoing discussion indicates that the mid-size existing buildings can be converted into NZEBs or nNZEB and the decision may depend on the investment required for the conversion.
- Preliminary energy audit of the building results in an annual energy saving of about 290 MWh which is equivalent to 6.5% of the annual consumption.

Outline

- Background
- Introduction
- Studied Building Status and Energy Consumption
- Phase-I: Energy Conservation at Minimum Cost
- Phase-II: Energy Conservation with Investment
- Phase-III: Building Integrated Photovoltaic (BIPV)
- Concluding Remarks
- Conclusions.

Conclusion

- Detailed energy conservation with reasonable investments yields an annual energy savings of about 2.458 GWh which is equivalent to about 55.4% of the annual building consumption
- Efficient operation strategies can reduce the energy consumption of the chillers by about 21.5% which is equivalent to 9.2% of the building energy consumption.
- Efficient energy conservation saves annual energy consumption of the building that is twelve times the energy generated by the PV modules

Conclusion

- The performance of BIPV systems is greatly influenced by the variation in both array slope and azimuth angle
- The integration of PV modules into the building produces about 27% of the building energy consumption and can cover the lighting and equipment load in the building
- The optimum BIPV can avoid CO₂ emission of about 160 tone/year

Conclusion

- Costs and efficiency of PV modules change dramatically and this will make BIPV systems cost-effective in the near future.
- Nearly NZEB can be achieved in existing buildings
- The results of the present work should encourage governments for wide installation of solar energy systems to keep our environment healthy and clean.

Thanks

