

WORLD-CLASS OUTSTANDING INTERNATIONAL
PROGRAM | EXHIBITION | NETWORKING

OIL CONTAMINATION FOR AMMONIA CHILLER COMPRESSOR 51-C1301A



42nd Turbomachinery
29th Pump SYMPOSIA



GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Authors

Mr. Abdulkareem Al-Ghamdi

Reliability Engineering Department Manager

Saudi International Petrochemical Co.

Area of Expertise: Engineering Management, RCM, RBI, Vibration Diagnostics, Maintenance Planning

Experience: >25years of experience in O&G, and Petrochemical sector

Mr. Ali Shallwani

Rotating Equipment Engineer

Saudi International Petrochemical Co.

Area of Expertise: Vibration Diagnostic, Maint. & Overhaul, Safety Reviews



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Equipment Description

Type	Screw Compressor
Process Gas	Ammonia
Driver	Motor
Flow Rate	41,958 kg/hr
Suction Pressure	5.4barg
Suction Temperature	11C
Discharge Pressure	20.7barg
Power Consumption	3,000 kW
Speed	3,550rpm



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

What was the problem?

- Recurring trip of 51-C1301A on low value for differential transmitter 51PDI13104.

What does this protection do?


- It measures low differential between lube discharge pressure and process discharge pressure.
- Prevent low lubrication for the bearings and rotating parts.



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

How was it getting tripped?



What was it?

During the run – differential across oil filter was low (<0.20barg).
No alarm / trip on oil filter differential pressure.
Suction Strainer was the next trap – this 20mesh strainer was found choked with blackish material




The strainer size was increased to 40mesh, and lube oil system was operated for period of 3days. During this run, there was no differential across oil filter.




42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

After flushing?



Apollo RCA



CONDITION CAUSE

Investigation

During the course of investigation following was realized,

1. The traces of contamination were also observed on other identical units 51-C1301 B/C.
2. No quality control document illustrating proper flushing of this equipment was tracked.
3. The equipment was commissioned in Dec, 2009 – but was never under continuous run for years due to gaps related to change over frequency, and limitation of electrical system.
4. Varnish material from internals.
5. While draining the lube oil samples from two different points i.e. oil separator and lube oil cooler – we observed white / milky foam from the drain – this was Ammonia which then vaporized in the open atmosphere leaving behind lube oil in the bottle.



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Investigation



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Lab tests of particle examination

Physical characteristics				
Organic & volatile @ 550°C	(on-dry basis)	wt. %	=	74.6
Inorganic matter	(on-dry basis)	wt. %	=	25.6
Chemical constituents after removal of Organic & Volatile @ 550°C				
Silicon dioxide	(SiO ₂)	wt. %	=	0.38
Aluminum oxide	(Al ₂ O ₃)	wt. %	=	0.07
Iron oxide	(Fe ₂ O ₃)	wt. %	=	13.4
Calcium oxide	(CaO)	wt. %	=	0.29
Magnesium oxide	(MgO)	wt. %	=	0.08
Sulphur trioxide	(SO ₃)	wt. %	=	0.08
Sodium oxide	(Na ₂ O)	wt. %	=	0.30
Potassium oxide	(K ₂ O)	wt. %	=	0.03
Copper oxide	(CuO)	wt. %	=	0.02
Zinc oxide	(ZnO)	wt. %	=	24.1
Manganese oxide	(MnO)	wt. %	=	0.20
Nickel oxide	(NiO)	wt. %	=	LT 0.01
Vanadium oxide	(V ₂ O ₅)	wt. %	=	LT 0.01
Phosphate	(PO ₄)	wt. %	=	60.4

- Vogel's Quantitative Inorganic Analysis, 4th Edition, Published by Longman Group Ltd., London, U. K.
- N. H. Furman (Editor) Standard Methods of Chemical analysis, 6th Edition, Published by Robert E. Krieger Publishing Co., Florida, U. S. A.

Lab tests of particle examination

Chemical constituents after removal of Organic & Volatile @ 550°C

Silicon dioxide	(SiO ₂)	wt.%	=	7.80
Aluminum oxide	(Al ₂ O ₃)	wt.%	=	0.94
Iron oxide	(Fe ₂ O ₃)	wt.%	=	31.0
Calcium oxide	(CaO)	wt.%	=	4.34
Magnesium oxide	(MgO)	wt.%	=	1.90
Sulphur trioxide	(SO ₃)	wt.%	=	LT 0.01
Chloride	(Cl)	wt.%	=	LT 0.01
Sodium oxide	(Na ₂ O)	wt.%	=	0.60
Potassium oxide	(K ₂ O)	wt.%	=	0.07
Copper oxide	(CuO)	wt.%	=	0.05
Zinc oxide	(ZnO)	wt.%	=	18.6
Manganese oxide	(MnO)	wt.%	=	0.24
Titanium oxide	(TiO ₂)	wt.%	=	0.02
Lead oxide	(PbO)	wt.%	=	LT 0.01
Phosphorous pentaoxide	(P ₂ O ₅)	wt.%	=	30.4
Vanadium oxide	(V ₂ O ₅)	wt.%	=	LT 0.01
Nickel oxide	(NiO)	wt.%	=	0.08
Chromium oxide	(Cr ₂ O ₃)	wt.%	=	0.23
Loss on Ignition @ 950°C	(LOI)	wt.%	=	2.20

Corrosion of Internals

1. The material of construction of piping and other equipment is Carbon Steel. Ammonia isn't corrosive.
2. The lube oil analysis confirmed that the moisture ingress was less than $<100\text{ppm}$.
3. Based on above facts, we inferred that the possibility of corrosion internals is remote.

Inherent Contamination

1. Lack of record to validate and/or negate the possibility of inherent contamination within system.



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Overall Performance of Separator


1. The non-satisfactory performance of the separator d/s the compressor was common observation for all the 03 equipment.
2. Traces of oil in Ammonia coolers was observed.
3. Traces of Ammonia in lube oil system was observed.



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Visual Inspection



42nd Turbomachinery
29th Pump SYMPOSIA

GEORGE R. BROWN CONVENTION CENTER
9.30 – 10.3.2013

Corrective Actions

thru flushing (Alkyl Benzene)



thru hydro-jetting



thru vacuuming



42nd Turbomachinery
29th Pump SYMPOSIUM

GEORGE R. BROWN CONVENTION CENTER
9.30 - 10.3.2013

Outcome


1. Post flushing, and vacuum run, the compressor was taken into service.
2. During first two trials, the compressor tripped on low pressure differential protection.
3. During both the trials, the suction strainer was found choked.
4. During third trial, the compressor was operating with stable differential, however the differential across the filter was high ($> 2.0\text{ barg}$)
5. Post-filter replacement. The compressor was taken into service.
6. Compressor has been operating smooth since then.



Outcome

Database:	Sipchem.rbm	Point:	P1 - 51-C1301A
Area:	51 - Utility Area	Sample:	4768
Equipment:	E18 - 51-C1301-A@15 Degree,Comp	Sample Date:	1/31/2013 1:40:07 AM

Wear	0
Ferrous Idx	0.0
LCont Ferrous	0
LCont NonFe	0
FW Index	
WDA Severity	



SIPCHEM
Reliability Engineering Dept.
Condition Monitoring Group
359-9999EXT-1054
ssrinivasa@sipchem.com

Ref Oil | No Reference Oil

Contamination	30
OilLife Idx	
Contam Idx	9.8
% Water	.0098
LCont Droplet	0
P/MI >4	12,231
P/MI >6	7,677
P/MI >14	873
P/MI >22	163
P/MI >38	15
P/MI >70	5.0
ISO PC >4	21
ISO PC >6	20
ISO PC >14	17
NAS Part Cnt	12
SAE Part Cnt	0

Chemistry	0
Chemical Idx	
Dielectric	2.30
DV Visc 40C	51.6
DV Visc Chng%	12.2
PC Dielectric	
PC Diel Idx	
PC Color Idx	
PC L. Absorb	

Observations	
Oil smells like ammonia	

Actions	
---------	--

